



ECMPS Client Tool

Version 1.* 2022 Q2

Emissions Evaluation Report

September 13, 2022 03:17 PM

Facility Name: Harrington Station

Facility Details

Facility ID (ORISPL): 6193
Monitoring Plan Location IDs: 061B
State: TX
County: Potter County
Year/Quarter: 2021 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.
	HOURGEN-14-A	You reported one or more daily calibration tests that will not fulfill your daily calibration testing requirement, because these tests were performed while the unit was not operating and you have not reported a prior online-offline calibration demonstration. These tests have been assigned a CalculatedTestResult of "IGNORED", and they can be viewed on the Daily Calibration tab of the View Detailed Emissions Screen. If you intend to use offline tests to fulfill your daily calibration testing requirement, you must conduct an online-offline calibration demonstration.
	HOURGEN-16-A	You reported one or more daily interference checks that will not fulfill your daily testing requirement for your stack flow monitors, because these tests were performed while the unit was not operating. These tests have been assigned a CalculatedTestResult of "IGNORED". They can be viewed on the Other Daily Tests tab of the View Detailed Emissions Screen.

QA Status Errors

Unit/Stack/ Pipe	Category Description	Severity	Check Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
061B	Leak Check Status Evaluation	CRIT1	OOC-Test Failed	The prior leak check for Component ID 014 completed on 09/10/2021 failed.	10/01/2021 00	10/11/2021 21	262
					10/12/2021 19	10/12/2021 19	1
					10/12/2021 22	10/17/2021 16	115
					10/18/2021 13	10/19/2021 00	12
					10/19/2021 18	11/05/2021 21	412
					11/08/2021 18	11/16/2021 18	193
					11/17/2021 07	11/18/2021 06	24
					11/18/2021 08	11/18/2021 21	14
					11/19/2021 21	11/23/2021 15	91

Facility Name: Harrington Station

Facility ID (ORISPL): 6193

Emissions Evaluation Report

September 13, 2022 03:17 PM

Unit/Stack/ Pipe	Category Description	Severity	Check Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
061B	Leak Check Status Evaluation	CRIT1	OOC-Test Failed	The prior leak check for Component ID 014 completed on 09/10/2021 failed.	11/24/2021 15	12/05/2021 00	250
					12/05/2021 19	12/09/2021 19	97
					12/10/2021 12	12/11/2021 19	32
					12/12/2021 16	12/24/2021 00	273
					12/24/2021 16	12/26/2021 01	34
					12/26/2021 17	12/30/2021 05	85
					12/30/2021 07	12/30/2021 19	13
					12/31/2021 23	12/31/2021 23	1