



# ECMPS Client Tool

Version 1.\* 2022 Q2

## Emissions Evaluation Report

September 7, 2022 11:29 AM

**Facility Name:** Lincoln Combustion Turbine

### Facility Details

Facility ID (ORISPL): 7277  
Monitoring Plan Location IDs: 10  
State: NC  
County: Lincoln County  
Year/Quarter: 2021 Q1  
Total Hours: 2160

### Evaluation Results

#### General Errors

Severity	Check Code / Result	Result Message
INFORM	<a href="#">HOURGEN-13-B</a>	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

#### QA Status Errors

Unit/Stack/ Pipe	Category Description	Severity	Check Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
10	Fuel Flowmeter QA Status Evaluation	CRIT1	<a href="#">OOC-Accuracy Test Aborted</a>	The applicable prior accuracy test for ComponentID 102 with TestNumber AAA was aborted.	03/31/2021 12	03/31/2021 12	1
			<a href="#">OOC-PEI Test Aborted</a>	The applicable prior PEI for ComponentID 102 with TestNumber AAA was aborted.	03/31/2021 12	03/31/2021 12	1