



# ECMPS Client Tool

Version 1.\* 2022 Q2

## QA/Cert Test Evaluation Report

November 19, 2022 04:34 PM

**Facility Name:** Lincoln Combustion Turbine

### Facility Details

Facility ID (ORISPL): 7277  
State: NC  
County: Lincoln County

### Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
6	FFACCTT	U06G-033119 03/31/2019 08:00	062/GFFM	CRIT1	<a href="#">FFACCTT-11-E</a>	You reported a TestResultCode of "FAILED", but the results recalculated or determined from the other reported values indicate that the test passed.
				INFORM	<a href="#">FFACCTT-4-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		U06G-052521 05/25/2021 09:00	062/GFFM	INFORM	<a href="#">FFACCTT-4-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		U6O-091421 10/01/2021 09:00	062/GFFM	FATAL	<a href="#">FFACCTT-14-B</a>	A Fuel Flowmeter Accuracy Test with this test number has been previously submitted. You must assign a different test number.