



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

October 11, 2022 02:47 PM

Facility Name: NCEMC Anson Plant

Facility Details

Facility ID (ORISPL): 56249
State: NC
County: Anson County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
ES5-A	FF2LBAS	FF2B-Q32021-09A-17 08/12/2021 17	09A/GAS	CRIT1	FF2LBAS-12-A	The value -1 in the field NumberOfHoursExcludedCofiring for this test is not within the range of valid values. This value must be greater than or equal to zero.
				INFORM	FF2LBAS-2-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.