



# ECMPS Client Tool

Version 1.\* 2022 Q1

## Emissions Evaluation Report

March 31, 2022 03:17 PM

**Facility Name: Chalk Point**

### Facility Details

Facility ID (ORISPL): 1571  
Monitoring Plan Location IDs: \*\*GT3  
State: MD  
County: Prince George's County  
Year/Quarter: 2021 Q4  
Total Hours: 2208

### Evaluation Results

#### General Errors

Severity	Check Code / Result	Result Message
CRIT1	<a href="#">HOURGEN-3-D</a>	You have reported LTFF as the heat input method for this configuration, but you have not reported a long-term fuel flow record for this reporting period.
INFORM	<a href="#">HOURGEN-13-B</a>	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

#### Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
**GT3	CRIT1	<a href="#">HOURDHV-38-B</a>	The AdjustedHourlyValue reported in the DHV record for HIT is inconsistent with the recalculated value.	10/28/2021 14	10/28/2021 14	1
				11/04/2021 18	11/05/2021 00	7
				11/09/2021 11	11/09/2021 12	2
				11/16/2021 10	11/16/2021 12	3
				11/18/2021 19	11/19/2021 00	6
		<a href="#">HOURDHV-41-B</a>	The AdjustedHourlyValue reported in the DHV record for SO2M is inconsistent with the recalculated value.	10/28/2021 14	10/28/2021 14	1
				11/04/2021 19	11/04/2021 19	1
				11/04/2021 21	11/04/2021 23	3
				11/09/2021 11	11/09/2021 12	2
				11/16/2021 11	11/16/2021 12	2
				11/18/2021 20	11/18/2021 23	4

Facility Name: Chalk Point

Facility ID (ORISPL): 1571

## Emissions Evaluation Report

March 31, 2022 03:17 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
**GT3	CRIT1	<a href="#">HOURLHV-43-B</a>	The AdjustedHourlyValue reported in the DHV record for CO2M is inconsistent with the recalculated value.	10/28/2021 14	10/28/2021 14	1
				11/04/2021 18	11/05/2021 00	7
				11/09/2021 11	11/09/2021 12	2
				11/16/2021 10	11/16/2021 12	3
				11/18/2021 19	11/19/2021 00	6
		<a href="#">HOURLHV-45-B</a>	The AdjustedHourlyValue reported in the DHV record for NOXM is inconsistent with the recalculated value.	10/28/2021 14	10/28/2021 14	1
				11/04/2021 18	11/05/2021 00	7
				11/09/2021 11	11/09/2021 12	2
				11/16/2021 10	11/16/2021 12	3
				11/18/2021 19	11/19/2021 00	6

### Summary Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
**GT3	CRIT1	<a href="#">HOURAGG-3-A</a>	The CurrentReportingPeriodTotal of 645.500 reported in the Summary Value record for CO2M for the reporting period is inconsistent with the recalculated value of 0.0.
		<a href="#">HOURAGG-4-A</a>	The CurrentReportingPeriodTotal of 10727.000 reported in the Summary Value record for HIT for the reporting period is inconsistent with the recalculated value of 0.
		<a href="#">HOURAGG-7-A</a>	The CurrentReportingPeriodTotal of 0.080 reported in the Summary Value record for NOXR for the reporting period is inconsistent with the recalculated value of 0.
		<a href="#">HOURAGG-8-A</a>	The CurrentReportingPeriodTotal of 0.400 reported in the Summary Value record for NOXM for the reporting period is inconsistent with the recalculated value of 0.0.
		<a href="#">HOURAGG-10-C</a>	The YearToDateTotal of 1808.800 in the Summary Value record for CO2M is inconsistent with the recalculated value of 1163.300.
		<a href="#">HOURAGG-12-H</a>	The YearToDateTotal of 1.300 in the Summary Value record for NOXM is inconsistent with the recalculated value of 0.900.
		<a href="#">HOURAGG-14-H</a>	The YearToDateTotal of 27399.000 in the Summary Value record for HIT is inconsistent with the recalculated value of 16672.000.