



# ECMPS Client Tool

Version 1.\* 2022 Q1

## Emissions Evaluation Report

March 31, 2022 03:15 PM

### Facility Name: Scattergood Generating Station

#### Facility Details

Facility ID (ORISPL): 404  
Monitoring Plan Location IDs: 1  
State: CA  
County: Los Angeles County  
Year/Quarter: 2021 Q1  
Total Hours: 2160

### Evaluation Results

#### General Errors

Severity	Check Code / Result	Result Message
INFORM	<a href="#">HOURGEN-13-B</a>	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.
	<a href="#">HOURGEN-18-A</a>	The current active primary fuel type defined in the monitoring plan is inconsistent with the prior year operating hours by fuel type. Please update the primary fuel type in the monitoring plan to match the prior year predominant fuel type by operating hours.
	<a href="#">HOURGEN-25-A</a>	The format is invalid for daily calibration cylinder id(s) !DT0018566. A cylinder id can only contain alphanumeric capitalized characters, hyphens, and periods.