



ECMPS Client Tool

Version 1.* 2022 Q2

QA/Cert Test Evaluation Report

November 16, 2022 03:30 PM

Facility Name: Thomas A. Smith Energy Facility

Facility Details

Facility ID (ORISPL): 55382
State: GA
County: Murray County

Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
CCCT3	ONOFF	311-H 12/01/2017 08	311/NOX	CRIT1	ONOFF-34-B	You reported a value of "1" as the Online Upscale APS Indicator for the test, but you must use the standard performance specification criteria for SO2 and NOX components when the instrument span is greater than or equal to 200.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		311-L 12/01/2017 08	311/NOX	CRIT1	ONOFF-41-A	You did not provide OnlineZeroAPSIndicator, which is required for this test.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		312-H 05/12/2021 08	312/NOX	CRIT1	ONOFF-32-B	You reported a value of "1" as the Offline Upscale APS Indicator for the test, but you must use the standard performance specification criteria for SO2 and NOX components when the instrument span is greater than or equal to 200.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		312-L 05/12/2021 08	312/NOX	CRIT1	ONOFF-36-A	You did not provide TestResultCode, which is required for this test.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		320-H 12/01/2017 08	320/O2	CRIT1	ONOFF-35-C	You reported a value of "1" as the Online Zero APS Indicator for the test, but you must use the standard performance specification criteria for CO2 and O2 components.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		321-H-O2 01/13/2020 08	321/O2	CRIT1	ONOFF-33-C	You reported a value of "1" as the Offline Zero APS Indicator for the test, but you must use the standard performance specification criteria for CO2 and O2 components.
				INFORM	ONOFF-23-C	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.