



ECMPS Client Tool

Version 1.* 2022 Q2

Emissions Evaluation Report

September 23, 2022 12:05 PM

Facility Name: Delray

Facility Details

Facility ID (ORISPL): 1728
Monitoring Plan Location IDs: CTG121
State: MI
County: Wayne County
Year/Quarter: 2019 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

QA Status Errors

Unit/Stack/ Pipe	Category Description	Severity	Check Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
CTG121	Appendix E Status Analysis	CRIT1	OOC-Expired	The prior Appendix E test TestNumber APPE-Q32014-NO2 -1 for MonitoringSystemID NO2 has expired.	10/01/2019 14	10/01/2019 14	1

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
CTG121	INFORM	HOURAE-9-H	The ParameterValueForFuel in the HPFF record for NOXR for FuelCode PNG could not be recalculated due to errors listed above.	10/01/2019 14	10/01/2019 14	1
		HOURCV-16-A	The AdjustedHourlyValue in the DHV record for NOX could not be recalculated due to errors listed above.	10/01/2019 14	10/01/2019 14	1
		HOURCV-41-A	The AdjustedHourlyValue in the DHV record for NOXR could not be recalculated due to errors listed above.	10/01/2019 14	10/01/2019 14	1

Summary Data Errors

Facility Name: Delray

Facility ID (ORISPL): 1728

Emissions Evaluation Report

September 23, 2022 12:05 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
CTG121	CRIT1	HOURAGG-7-E	The CurrentReportingPeriodTotal in the Summary Value record for NOXR could not be recalculated because of errors listed above.
		HOURAGG-8-E	The CurrentReportingPeriodTotal in the Summary Value record for NOXM could not be recalculated because of errors listed above.