



ECMPS Client Tool

Version 1.* 22 Q2 Build 1

Emissions Evaluation Report

May 23, 2022 11:19 AM

Facility Name: La Cygne

Facility Details

Facility ID (ORISPL): 1241
Monitoring Plan Location IDs: 1
State: KS
County: Linn County
Year/Quarter: 2021 Q4
Total Hours: 2208

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.

Sorbent Trap Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
1	CRIT1	MATSTRP-5-A	For Trap 156 at 11/04/2021 6:00:00 AM, the BeginDate/Hour is inconsistent with the EndDate/Hour.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
1	CRIT1	MATSGFM-1-B	For GFM 157, you reported a sorbent train GFM Component ID that does not match a sorbent train Component ID record.	11/11/2021 17	11/12/2021 04	12
				11/12/2021 10	11/12/2021 18	9
				11/13/2021 05	11/14/2021 16	36
			For GFM 158, you reported a sorbent train GFM Component ID that does not match a sorbent train Component ID record.	11/11/2021 17	11/12/2021 04	12
				11/12/2021 10	11/12/2021 18	9
				11/13/2021 05	11/14/2021 16	36
		MATSMHV-6-E	You reported sorbent trap system 156 in the MATS MHV record for HGC, but the emissions report does not contain a sorbent trap record for the system that was active during the current hour.	11/11/2021 17	11/12/2021 04	12
				11/12/2021 10	11/12/2021 18	9
				11/13/2021 05	11/14/2021 16	36

Facility Name: La Cygne
Facility ID (ORISPL): 1241