



# ECMPS Client Tool

Version 1.\* 2022 Q2

## QA/Cert Test Evaluation Report

October 12, 2022 04:24 PM

Facility Name: Lincoln Combustion Turbine

### Facility Details

Facility ID (ORISPL): 7277  
State: NC  
County: Lincoln County

### Evaluation Results

Unit/Stack Identifier	Test Type	Test Number Test Date/Hour	Sys / Comp ID / Type	Severity	Check Code	Result
9	APPE	09NOX2016-1 02/29/2016 16:10	410/NOXE	CRIT1	<a href="#">APPE-36-A</a>	You did not provide GasHeatInput, which is required for Operating Level 1 Run Number 1 Gas System ID 200.
					<a href="#">APPE-37-A</a>	The reported TotalHeatInput is not consistent with the value recalculated from the Appendix E oil and gas records for Operating Level 1 Run Number 1.
					<a href="#">APPE-41-A</a>	The AverageHourlyHeatInputRate reported for Operating Level 1 is inconsistent with the value recalculated from the run and fuel data for the operating level.
					<a href="#">APPE-44-A</a>	The HourlyHeatInputRate for Operating Level 1 Run Number 1 does not correspond to the hourly heat input rate recalculated from the start and end times and heat input derived from the Appendix E gas and oil records.
		09NOX2016-2 03/01/2016 15:50	400/NOXE	INFORM	<a href="#">APPE-4-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
				CRIT1	<a href="#">APPE-30-A</a>	You did not report a value for OilMass in the oil flow record for Operating Level 1 Run Number 1 Oil System ID 100. You must report a value for OilMass when you are using an OILM system.
				INFORM	<a href="#">APPE-4-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
				INFORM	<a href="#">APPE-4-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
		09NOX2021-1 03/01/2021 15:19	410/NOXE	INFORM	<a href="#">APPE-4-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.
				CRIT1	<a href="#">APPE-32-B</a>	You defined an invalid OilGCV for Operating Level 1 Run Number 1 Oil System ID 100. This value must be greater than zero and less than 20,000.
		09NOX2021-2 03/02/2021 14:39	400/NOXE	INFORM	<a href="#">APPE-4-C</a>	This test has already been submitted and will not be resubmitted. If you wish to resubmit this test, please contact EPA for approval.