



ECMPS Client Tool

Version 1.* 2022 Q1

Emissions Evaluation Report

March 16, 2022 02:50 PM

Facility Name: Gulf Clean Energy Center

Facility Details

Facility ID (ORISPL): 641
Monitoring Plan Location IDs: CS1BYP, CS1FGD, CS2BYP, 4, 5, 6, 7
State: FL
County: Escambia County
Year/Quarter: 2021 Q2
Total Hours: 2184

Evaluation Results

General Errors

Severity	Check Code / Result	Result Message
INFORM	HOURGEN-13-B	The emissions quarterly report cannot be resubmitted until you contact the EPA for permission. After the EPA grants permission, you will need to log in to the EPA host system to retrieve the permission record. You will then need to reevaluate this file prior to submitting.
	HOURGEN-14-A	You reported one or more daily calibration tests that will not fulfill your daily calibration testing requirement, because these tests were performed while the unit was not operating and you have not reported a prior online-offline calibration demonstration. These tests have been assigned a CalculatedTestResult of "IGNORED", and they can be viewed on the Daily Calibration tab of the View Detailed Emissions Screen. If you intend to use offline tests to fulfill your daily calibration testing requirement, you must conduct an online-offline calibration demonstration.

Hourly Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
CS1BYP	ADMNOVR	MATSHOD-6-A	MATS Derived Hourly Value records were reported for MATS Hg Rate, but no supporting method exists.	04/19/2021 12	04/19/2021 17	6
				04/20/2021 02	04/21/2021 17	40
				05/02/2021 09	05/07/2021 18	130
		MATSHOD-9-A	MATS Derived Hourly Value records were reported for MATS SO2 Rate, but no supporting method exists.	04/19/2021 12	04/19/2021 17	6
				04/20/2021 02	04/21/2021 17	40
				05/02/2021 09	05/07/2021 18	130
CS1FGD	CRIT1	HOURAPP-14-A	The heat input reported at the units is not consistent with the heat input reported at the stacks in this configuration.	05/24/2021 16	05/24/2021 16	1

Facility Name: **Gulf Clean Energy Center**

Emissions Evaluation Report

Facility ID (ORISPL): **641**

March 16, 2022 02:50 PM

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message	Begin Date / Hour	End Date / Hour	Consecutive Hours
CS2BYP	ADMNOVR	MATSHOD-6-A	MATS Derived Hourly Value records were reported for MATS Hg Rate, but no supporting method exists.	05/18/2021 15	05/20/2021 10	44
				05/20/2021 12	06/30/2021 23	996
		MATSHOD-9-A	MATS Derived Hourly Value records were reported for MATS SO2 Rate, but no supporting method exists.	05/18/2021 15	05/20/2021 10	44
				05/20/2021 12	06/30/2021 23	996

Summary Data Errors

Unit/Stack/ Pipe	Severity	Check Code / Result	Result Message
6	CRIT1	HOURAGG-4-A	The CurrentReportingPeriodTotal of 1253517.000 reported in the Summary Value record for HIT for the reporting period is inconsistent with the recalculated value of 1253683.
		HOURAGG-14-H	The YearToDateTotal of 4435323.000 in the Summary Value record for HIT is inconsistent with the recalculated value of 4435489.000.