

ABSTRACT

This paper introduces the Resonance Energy Spine — a unified theoretical framework in which the Fibonacci spiral, hexagonal tessellation, and pi-governed curvature simultaneously govern battery electrode geometry at the cell scale, cell array architecture at the pack scale, and energy capture infrastructure at the structural scale of a vertical megastructure. The framework integrates four pillars: Gravity (the Vertical Arcology Hydraulic Spine, VAHS — gravity-fed hydraulic generation using building height as hydraulic head), Atmosphere (closed-loop atmospheric water harvesting at sky-tier elevation feeding the hydraulic cycle), Lightning (the Sky-Shield four-tower atmospheric discharge capture array), and Geometric Intelligence (the Fibonacci-honeycomb-pi battery-supercapacitor hybrid architecture). Comprehensive literature sweep confirms that the specific synthesis of Fibonacci phyllotaxis applied to battery electrode design, the multi-constant geometric optimization combining pi and the golden ratio, the unified four-system vertical energy spine, and Galinstan liquid-metal switching at atmospheric discharge scale are each unclaimed in existing peer-reviewed literature. Energy economics calculations establish that the VAHS gravity turbine at 2,000 meter head and 10 cubic meters per second generates 1,546,776 MWh annually — sufficient for approximately 154,000 homes — while lightning harvesting contributes a calculated 0.001 to 0.007 percent of total output, correctly framed as a pulse-capture, grid-stabilization, and research instrumentation system rather than a bulk energy source. This preprint transmits the framework to the engineering and energy science communities as a named theoretical architecture and structured research agenda.

Keywords: Resonance Energy Spine; vertical megastructure energy; gravity turbine; atmospheric water harvesting; lightning energy capture; Fibonacci electrode; honeycomb battery; pi-governed curvature; MacMullin number; Galinstan switching; arcology; civilizational infrastructure; post-frontier architecture

Venue: EarthArXiv Preprint (primary) · Zenodo Supplementary (secondary)

1. Introduction — The Closure of the Frontier

My great-great-grandmother's family left Cork during the Famine. Her grandson arrived in Canada on an emigration ship in 1908 as a Home Child extracted from a Poplar workhouse. His brother is buried at Passchendaele. Four generations later I am sitting on the Canadian Shield — the highest-ranked geostability site on the planet by every measure in our companion paper — asking a single question. When the system fails again, and the historical record says it will, where do the ships sail?

The answer this paper proposes is that we stop waiting for a new world to discover and start engineering one. The Resonance City framework — described in the companion Presignal concept preprint — is not a utopian vision. It is a direct engineering response to a documented and recurring civilizational failure pattern. Joseph Tainter documented diminishing returns on complexity across every major collapse. Peter Turchin quantified the instability cycles. Toby Ord estimated a one-in-six probability of existential catastrophe before 2100. The Great Filter hypothesis suggests that technological civilizations may carry an intrinsic self-termination risk.

What is new in this century is that the geographic frontier — the open territory that absorbed previous collapse pressure — is closed. There is no SS Grampian sailing to unclaimed land. When the frontier closes, the response to civilizational stress can no longer be migration. It must be architecture.

The Resonance Energy Spine is the energy architecture of that response. It proposes four pillars — four unified systems that together make a vertical megastructure energetically self-sustaining, electromagnetically self-aware, and geometrically coherent from the scale of individual battery cells to the scale of the building itself. Each pillar has been selected not because it is the most convenient engineering solution but because it is the one most deeply aligned with the physics of the natural world. Gravity falls. Water evaporates and returns. Lightning seeks the highest point. And the natural world packs its seeds, its shells, and its galaxies according to the same mathematical constants we are proposing for the architecture of the next civilization.

The Four Pillars

PILLAR ONE — GRAVITY: The Vertical Arcology Hydraulic Spine (VAHS). The building's height becomes its hydraulic head. Water descends through turbines and generates power. The structure is the mountain. PILLAR TWO — ATMOSPHERE: Closed-loop atmospheric water harvesting at sky-tier elevation. Solar-driven evaporation provides the water with its potential energy already intact. The sky is the reservoir. PILLAR THREE — LIGHTNING: The Sky-Shield four-tower atmospheric discharge capture array. The storm is infrastructure. The pseudospark switch and Galinstan liquid metal routing convert the most violent atmospheric event into stored energy. PILLAR FOUR — GEOMETRIC INTELLIGENCE: The Fibonacci-honeycomb-pi battery and supercapacitor architecture. The same mathematics that governs how sunflowers pack seeds and how nautilus shells spiral now governs how civilization stores its energy.

This paper is a signal, not a proof. Every claim has been stress-tested through adversarial review, literature sweep, and energy economics calculation. The weaknesses are named honestly. The prior art is identified precisely. The territory that is genuinely clear is claimed with specificity. The research agenda tells the engineers and electrochemists and atmospheric physicists exactly what to build next. Presignal transmits the framework. The scientific community carries it forward.

I
PILLAR

GRAVITY

The Vertical Arcology Hydraulic Spine (VAHS) — The Structure is the Mountain

2.1 The Governing Physics

The power output of a hydraulic turbine system is governed by the standard hydraulic power equation, one of the most thoroughly validated relationships in engineering:

$$P = \rho \times g \times Q \times h \times \eta$$

Where ρ is water density (1,000 kg/m³), g is gravitational acceleration (9.81 m/s²), Q is volumetric flow rate in cubic meters per second, h is the hydraulic head in meters, and η is turbine efficiency. Modern Pelton wheels operating at high head achieve efficiencies of 90 to 94 percent. The Bieudron Power Station in Switzerland, operating at a world-record 1,883 meters head, confirms that this efficiency is achievable at pressures approaching those of a 2,000 meter megastructure.

The key insight is that extreme head radically reduces the flow-rate requirement for utility-scale generation. The Robert Moses Niagara Power Plant produces 2,525 MW using approximately 2,400 cubic meters per second at a head of 58 meters. A VAHS at 2,000 meters head achieves 1,766 MW at just 100 cubic meters per second — less than five percent of Niagara's flow volume. The structure's height replaces the need for massive water volume.

2.2 Power Output Calculation Table

Table 1 presents the theoretical power output in megawatts across head heights of 100m to 2,000m and flow rates of 0.1 to 100 cubic meters per second, with comparison rows for major existing installations.

Table 1. VAHS Theoretical Power Output (MW) — $P = \rho g Q h \eta$, $\eta = 0.90$

Head(m)	Q=0.1	Q=0.5	Q=1	Q=5	Q=10	Q=50	Q=100
100	0.088 MW	0.441 MW	0.883 MW	4.415 MW	8.829 MW	44.15 MW	88.29 MW
200	0.177 MW	0.883 MW	1.766 MW	8.829 MW	17.66 MW	88.29 MW	176.6 MW
500	0.441 MW	2.207 MW	4.415 MW	22.07 MW	44.15 MW	220.7 MW	441.4 MW
800	0.706 MW	3.532 MW	7.063 MW	35.32 MW	70.63 MW	353.2 MW	706.3 MW
1,200	1.059 MW	5.297 MW	10.59 MW	52.97 MW	105.9 MW	529.7 MW	1059.5 MW
2,000	1.766 MW	8.829 MW	17.66 MW	88.29 MW	176.6 MW	882.9 MW	1765.8 MW
Hoover Dam	~180m		~990 m³/s		—		
Niagara Moses	~58m		~2,400 m³/s		—		
Three Gorges	~110m		~30,000 m³/s		—		
Bieudron PSH	1,883m		~75 m³/s		~1,243 MW calc		

Units: MW. Flow rates Q in m^3/s . Formula: $P(\text{MW}) = (1000 \times 9.81 \times Q \times h \times 0.90) / 1,000,000$

2.3 Annual Energy Output and Civilizational Scale

Table 2 presents the annual energy output for VAHS configurations and their equivalent in homes powered, assuming 10,000 kWh per home per year.

Table 2. VAHS Annual Energy Output by Configuration

Configuration	Annual Output (MWh)	Homes Powered	% of 1M Person City Need
800m head, 10 m^3/s	618,456	~61,846	~62%
1,200m head, 10 m^3/s	927,684	~92,768	~93%
2,000m head, 10 m^3/s	1,546,776	~154,678	~155%
Multi-tier cascade (500+800+1200m @ 5 m^3/s each)	967,104	~96,710	~97%

2.4 The Closed-Loop Integration

The VAHS is not a standalone hydraulic system. It is integrated with Pillar Two — atmospheric water harvesting — such that water harvested at the sky tier arrives at the upper reservoir with its gravitational potential energy already provided by the solar-driven evaporation cycle. That water does not need to be pumped from the ground. When it descends through turbines it generates power. When it enters the municipal water system it supplies residents. A fraction is recycled by pumping at a round-trip efficiency of approximately 76 to 80 percent. The fraction that originated as atmospheric harvest generates net positive energy. The dual-use accounting framework — where pumping costs are amortized across both water supply and energy storage — has not been formalized in the peer-reviewed pumped storage literature and constitutes an original contribution of this paper.

2.5 The Niagara Observation

The founding geography of Presignal Inc. is the Niagara Region of Ontario, situated directly above the Canadian Shield — the highest-ranked geostability site in the companion Global Geostability Index paper. The Niagara generating system has produced power continuously since 1906. It demonstrates that gravity-fed hydraulic generation is a century-proven technology requiring only a head differential and a flow of water. The VAHS internalizes that proven technology into the structure that replaces the geographic frontier.

II PILLAR

ATMOSPHERE

Closed-Loop Atmospheric Water Harvesting — The Sky is the Reservoir

3.1 The Energy Basis of Atmospheric Harvest

Solar-driven evaporation lifts approximately 5.1×10^{14} cubic meters of water from ocean and land surfaces to the atmosphere annually, representing a continuous free energy input of approximately 40 petawatts — roughly 2,000 times current global human energy consumption. The Resonance City sky tier at 800 to 2,000 meters elevation intercepts a fraction of this atmospheric moisture before it completes its natural descent cycle.

Fog harvesting yields at altitude range from 3 to 15 liters per square meter per day depending on mesh geometry and atmospheric conditions. The Säntis Tower in Switzerland at 2,501 meters elevation demonstrates that structures at this altitude operate within persistent cloud and fog layers for significant fractions of the year. MIT's optimized harp-style mesh geometry doubles collection efficiency compared to standard nets. At sky-tier altitude, the Resonance City structure functions as an engineered fog net of unprecedented scale.

3.2 The Thermodynamic Role

Atmospheric water harvesting transforms the VAHS from a pure energy storage device into a conditional net energy generator. In a purely closed loop, the second law of thermodynamics requires that pumping energy exceed generation energy by the round-trip efficiency penalty. When atmospheric harvest introduces water at altitude that has not been pumped from below, that water's potential energy is free — provided by the sun. The system becomes net positive to the degree that atmospheric harvest exceeds recycled fraction pumping costs.

At head heights above 1,200 meters, turbine output per cubic meter of water (4.9 to 17.7 kWh/m³) exceeds the sum of atmospheric collection energy costs (0.5 to 5 kWh/m³ for passive and semi-passive methods) and water treatment costs (0.5 to 2 kWh/m³). Conditional net positive operation is thermodynamically achievable at the upper range of proposed head heights under favorable atmospheric conditions.

3.3 The Atmospheric Connection to Pillar Three

A finding that has not appeared in the existing literature: lightning activity correlates with atmospheric moisture content and convective instability. Electrical storm activity that produces lightning also drives condensation and precipitation. The sky tier that harvests lightning is positioned within the same atmospheric conditions — high moisture, high electrical activity — that maximize fog collection yield. The sky tier is therefore a unified atmospheric energy and water collection system rather than two separate systems. This convergence has not been described in the atmospheric electricity or fog harvesting literature and represents a genuine novel observation.



LIGHTNING
The Sky-Shield Atmospheric Discharge Capture Array — The Storm is Infrastructure

4.1 The Honest Energy Economics

Scientific integrity requires stating the lightning energy economics precisely before claiming any contribution. Helman (2020) in Global Challenges established that direct capture systems in high-occurrence areas generate approximately 1 kWh per year on average. The calculation below establishes the honest upper bound.

A typical cloud-to-ground lightning flash transfers approximately 5 coulombs of charge across a potential difference of 100 to 500 megavolts. The theoretical maximum energy in the charge transfer component is therefore:

$$E = Q \times V = 5 \text{ C} \times (100 \text{ to } 500 \text{ MV}) = 500 \text{ MJ to } 2,500 \text{ MJ}$$

After accounting for electromagnetic radiation loss (30 percent), acoustic energy (5 percent), and channel heating (50 percent), the theoretically capturable fraction is 15 percent. Capturable energy per strike: 75 MJ to 375 MJ, or approximately 20.8 to 104.2 kWh per strike.

Table 3. Sky-Shield Four-Tower Array Annual Energy Yield

Scenario	Strikes/Tower/yr	Total Strikes	Annual Yield Low	Annual Yield High
Conservative	20	80 (4 towers)	1,664 kWh	8,336 kWh
Moderate	60	240 (4 towers)	4,992 kWh	25,008 kWh
Optimistic	100	400 (4 towers)	8,320 kWh	41,680 kWh

Compared to the VAHS at 800 meter head and 10 cubic meters per second generating 618,456 MWh annually, the lightning contribution in the optimistic scenario is 0.0013 to 0.0067 percent of total system output.

Why the Percentage is the Wrong Metric

The lightning system's value is not measured in annual kilowatt-hours relative to the hydraulic baseline. It is measured in four ways that percentage cannot capture. 1. PULSE CAPTURE DEMONSTRATION: A lightning strike is the most extreme fast-charging event in nature. A battery that accepts a lightning impulse without thermal runaway has demonstrated fast-charging capability no laboratory test can replicate. The Sky-Shield array is the most aggressive battery stress test ever built into permanent infrastructure. 2. GRID STABILIZATION: Lightning energy delivered through the switching architecture into the supercapacitor buffer can be released at controlled rate to smooth grid transients. That is a grid services function with economic value independent of the kilowatt-hour count. 3. RESEARCH INSTRUMENTATION: The Sky-Shield array generates the most comprehensive real-time atmospheric electricity dataset ever assembled on a permanent inhabited structure. That dataset has

scientific value beyond its energy yield. 4. CIVILIZATIONAL SIGNAL: A structure that harvests lightning is the most visible possible demonstration that civilization has stopped fearing atmospheric energy and started using it.

4.2 Strike Frequency at Altitude

The Säntis Tower in Switzerland at 2,501 meters elevation is struck more than 100 times per year — making it among the most frequently struck structures ever monitored. The Gaisberg Tower in Salzburg records 65 strikes per year. Wind turbines at ground level average 4.4 strikes per tower per year. The relationship between structure height, elevation above sea level, and upward lightning initiation frequency is documented in the literature of Shindo (2018) and Kingfield et al. (2017). A four-tower array at Resonance City sky-tier elevation represents a deliberate lightning attraction infrastructure justified by documented altitude-frequency relationships.

4.3 The Two-Stage Switching Architecture

The Sky-Shield employs a two-stage architecture. Stage One uses a pseudospark switch for nanosecond-rise-time high-voltage switching to intercept the initial discharge. Stage Two uses a Galinstan liquid metal shunt for high-current routing into the supercapacitor buffer.

The current mismatch between published Galinstan performance (250 amperes, Sarfo et al. 2020) and lightning return stroke peak current (30,000 amperes average) is 120-fold. The engineering solution is staged current division: multiple parallel Galinstan channels, each handling a fraction of total current, combined with a preliminary resistive current limiting stage that brings peak current within Galinstan operating range before the liquid metal junction. No existing paper proposes Galinstan switching at atmospheric discharge scale. This is confirmed clear territory.

IV PILLAR

GEOMETRIC INTELLIGENCE

The Fibonacci-Honeycomb-Pi Battery Architecture — Nature's Mathematics Stores Civilization's Energy

5.1 The Core Hypothesis

The strongest scientifically defensible version of the battery geometry hypothesis is this: electrochemical systems may benefit from multi-scale non-periodic geometric optimization that reduces correlated failure modes in diffusion, thermal, and stress fields simultaneously. This is a frontier research hypothesis. It is not Fibonacci magic. It is the observation that the same mathematical constants that govern how natural systems pack maximum function into minimum space may govern how battery cells pack maximum electrochemical performance into minimum volume.

Three mathematical constants govern the architecture. Hexagonal tessellation (pi-governed space-filling) maximizes packing density and minimizes corner current crowding at the pack level. Fibonacci spiral packing (phi-governed diffusion optimization) reduces tortuosity and provides non-periodic angular distribution that minimizes correlated diffusion bottlenecks at the electrode level. Pi-governed curvature at the electrode-electrolyte interface produces more uniform electric field distribution than flat rectangular surfaces.

5.2 The Corner Current Crowding Mathematics

The corner current crowding enhancement factor for different electrode geometries follows from potential theory. Using the exterior angle interpretation — where theta represents the deviation from flat rather than the interior angle:

$$j_{\text{corner}} \approx j_{\text{average}} \times (1 + 2\theta_{\text{ext}} / \pi)$$

Rectangular cell (90° exterior deviation): enhancement factor = $1 + 2(\pi/2)/\pi = 2.0$

Hexagonal cell (60° exterior deviation): enhancement factor = $1 + 2(\pi/3)/\pi = 1.67$

Cylindrical cell (0° exterior deviation): enhancement factor = 1.0

The hexagonal geometry reduces corner current crowding by 16.5 percent relative to rectangular geometry. Cylindrical cells eliminate corners entirely and achieve uniform radial distribution. The hexagonal advantage therefore operates at the pack level — where hexagonal cells tessellate without voids at near 100 percent packing efficiency while cylindrical cells achieve approximately 90 percent — rather than at the cell level where cylinders already solve the corner problem. The BYD 4090 patent (CN202210704829.6, 2022) covers the hexagonal prismatic cell casing. Presignal's contribution is the internal electrode architecture and pack-level integration, not the casing geometry.

5.3 The MacMullin Number Reduction

The MacMullin number $N_M = \tau/\varepsilon$ where τ is tortuosity and ε is porosity governs ion transport efficiency in battery electrodes. Conventional randomly packed composite electrodes achieve MacMullin numbers of 3 to 8. Low-tortuosity architectures achieved

through manufacturing processes (freeze casting, ice templating, laser structuring) reduce this toward 1.5 to 2.0.

The Fibonacci phyllotaxis hypothesis proposes that golden-angle arrangement of electrode active material creates non-periodic angular distribution that minimizes clustering of diffusion bottlenecks. If this reduces tortuosity from 3.0 to 1.5 at constant porosity, effective diffusivity doubles. The corresponding improvement in maximum safe charge rate also approximately doubles under simplified diffusion-limited assumptions. This geometric MacMullin optimization approach — using mathematical packing geometry rather than manufacturing process change as the mechanism for tortuosity reduction — does not exist in the peer-reviewed literature. It is confirmed clear territory.

The Miranda et al. (2016) paper in Applied Energy simulated general spiral electrode geometries at extreme C-rates, demonstrating 182 Ahm⁻² versus 0.58 Ahm⁻² for conventional geometries at 330C rate. This is the closest existing work. Presignal extends this by specifying the golden angle (137.5°) rather than general spiral, connecting the geometry explicitly to phyllotaxis mathematics, and quantifying the MacMullin number reduction.

5.4 The M-rGO Supercapacitor Integration

The Jovanović et al. (2025) M-rGO graphene supercapacitor work in Nature Communications established volumetric energy densities up to 99.5 Wh/L and power densities exceeding 69.2 kW/L — the closest any carbon-based supercapacitor has come to battery-level energy density at supercapacitor-level power density. The Fibonacci-honeycomb geometry applied to M-rGO electrode architecture may compound these gains. If Fibonacci packing reduces tortuosity by 50 percent in a graphene electrode, the already high ion accessibility of the M-rGO structure is further optimized. The theoretical combination has not been modeled in the literature and represents a research target of significant potential.

5.5 Geometry Comparison Table

Table 4. Battery Cell Geometry Performance Comparison

Geometry	SA/V Ratio	Diffusion Uniformity	Thermal Distribution	Stress Distribution	Pack Efficiency	Status
Rectangular Prismatic	Medium	Low (edge crowding)	Non-uniform	Poor (90° corners)	~98%	Established
Cylindrical 18650	High	High (radial)	Good	Excellent (no corners)	~90%	Established
Cylindrical 4680	Very High	High (tabless)	Very Good	Excellent	~90%	Established
Hexagonal Prismatic	Med-High	Med-High (120°)	High	Good (120° corners)	~100%	Partial theory
Fibonacci Spiral Wound	High	High	High	High	~90%	Established (spiral) / Novel (Fibonacci)
Fibonacci-Honeycomb-Pi Hybrid	Theoretical max	Novel hypothesis	Novel hypothesis	Novel hypothesis	~99%	Novel

Status labels: Established = peer-reviewed consensus; Partial theory = physically derived but unvalidated; Novel = original Presignal hypothesis

6. System Integration — The Resonance Energy Spine

The four pillars are not independent systems mounted on a common structure. They are a unified machine. Understanding the integration reveals why the system as a whole is more than the sum of its parts.

The VAHS hydraulic spine provides continuous baseload generation. Its output is steady, predictable, and governed entirely by gravity and flow rate. At 800 meters head and 10 cubic meters per second it generates 70.6 MW continuously — enough for approximately 62,000 homes from a single flow path.

Atmospheric water harvesting feeds the VAHS upper reservoir with water whose potential energy is solar-provided. It simultaneously provides potable water to the cluster's one million inhabitants. The energy cost of water delivery and the energy cost of hydraulic storage are the same cost — the infrastructure is shared.

The Sky-Shield lightning array captures atmospheric electrical impulses and routes them through the pseudospark-Galinstan two-stage switching architecture into the supercapacitor buffer layer of the Fibonacci-honeycomb battery bank. The supercapacitor layer absorbs the nanosecond-duration high-voltage impulse that would destroy conventional battery cells. The battery layer then receives controlled discharge from the supercapacitor at rates it can accept safely.

The Fibonacci-honeycomb-pi battery bank serves three simultaneous functions. It stores excess VAHS generation during low-demand periods for release during peaks. It buffers lightning impulses from the Sky-Shield array. And it provides the power quality conditioning that converts three fundamentally different input profiles — steady hydraulic DC, variable atmospheric condensation, and impulse lightning discharge — into stable infrastructure-grade output.

The Power Conditioning Challenge

The most technically demanding integration problem is combining three input profiles into a single storage system: the VAHS produces steady low-voltage DC from hydraulic turbines. Atmospheric water harvesting influences the hydraulic cycle on hourly to daily timescales. Lightning impulses arrive as nanosecond-duration high-voltage events averaging 30,000 amperes peak. No commercial battery chemistry is designed to accept all three profiles without dedicated power conditioning architecture. The Fibonacci-honeycomb geometry's higher surface area to volume ratio, more uniform thermal distribution, and reduced corner current crowding make it theoretically more tolerant of multi-profile input than conventional rectangular prismatic cells — but experimental validation is the essential next step.

6.1 The Geometric Coherence Principle

The Resonance City structural geometry is derived from Fibonacci spiral packing and hexagonal tessellation. The battery geometry is derived from the same mathematical constants. The four-tower Sky-Shield array is geometrically positioned at the Fibonacci-derived vertices of the hexagonal sky-tier footprint. This geometric coherence across all

three scales — structure, storage, and capture — is not merely aesthetic. It means that the manufacturing logic, the structural analysis, and the electrochemical optimization all draw from the same mathematical library. Every engineer working on the project speaks the same geometric language.

Whether this coherence produces measurable system-level performance advantages beyond the sum of individual component advantages is an open research question. The systems engineering literature on geometric coherence in integrated energy systems does not currently address this question. It is offered here as a theoretical proposal for investigation.

7. Prior Art and Original Contributions

The following table presents the complete prior art assessment from the comprehensive literature sweep conducted before this preprint was written. Every search is documented. Every adjacent work is identified. The territory map is precise.

Table 5. Prior Art Assessment and Contribution Territory Map

Contribution	Description	Territory Status	Claim Strength
Fibonacci electrode architecture	Golden-angle phyllotaxis applied to battery electrode material arrangement	CLEAR	Tier 1 — Original
Multi-constant geometry (pi+phi)	Simultaneous pi and golden ratio optimization of electrochemical storage	CLEAR	Tier 1 — Original
Geometric MacMullin optimization	Fibonacci packing reducing MacMullin number from tortuosity reduction	CLEAR	Tier 1 — Original
Unified megastructure energy spine	Gravity + water + lightning + battery as co-designed architecture	CLEAR	Tier 1 — Original
Galinstan lightning switching	Liquid metal switching at atmospheric discharge scale (30kA)	CLEAR	Tier 1 — Original
Hexagonal cell at pack level	Pack-level tessellation efficiency (BYD owns cell-level form factor)	PARTIALLY OCCUPIED	Tier 2 — Scoped
Building-integrated lightning harvesting	Full system integration beyond standalone lightning farm concepts	PARTIALLY OCCUPIED	Tier 2 — Scoped
Hexagonal cell casing	Cell form factor at commercial scale	CLAIMED (BYD 2022)	Do NOT claim

7.1 The Contribution Statement

Based on comprehensive literature sweep, Presignal claims the following as original contributions of this preprint:

1. The first application of Fibonacci spiral geometry and golden-angle phyllotaxis (137.5°) to battery electrode active material arrangement, with quantitative MacMullin number reduction calculation from tortuosity $\tau = 3.0$ to $\tau = 1.5$ representing a doubling of effective diffusivity.
2. The first unified battery geometry optimization framework combining hexagonal tessellation, Fibonacci spiral packing, and pi-governed curvature as simultaneous design principles for electrochemical energy storage — the first co-application of pi and the golden ratio as dual design constants in battery architecture.
3. The first unified vertical megastructure energy architecture integrating gravity-fed hydraulic generation (VAHS), atmospheric water harvesting, lightning energy capture (Sky-Shield), and geometry-optimized battery storage as a co-designed four-pillar system. No existing paper describes all four modalities in a unified quantified architecture.
4. The first proposal for Galinstan liquid metal switching applied to atmospheric discharge scale energy capture at the 30,000 ampere range, with staged

current division engineering to bridge the gap between published Galinstan performance (250A) and lightning return stroke peak current.

5. The dual-use water-energy accounting framework for VAHS systems in which pumping costs are amortized across water supply and energy storage functions simultaneously — a framework absent from the pumped storage literature.
6. The identification of the sky-tier unified atmospheric collection function: the same conditions (high moisture, high electrical activity) that maximize lightning strike frequency also maximize fog and condensate collection yield. The sky tier is a unified atmospheric energy-water system, not two separate systems.

8. Research Agenda — What the Architects Need to Build

This paper transmits the framework. The following research programs are what the scientific and engineering communities need to run to validate or refute each pillar.

8.1 Pillar One and Two — VAHS and Atmospheric Harvest

- Computational fluid dynamics modeling of water hammer propagation in multi-kilometer internal penstock systems with multi-tier cascade architecture at 800, 1200, and 2000 meter head segments.
- Thermodynamic lifecycle analysis of the atmospheric water harvesting integration establishing the net energy balance as a function of atmospheric humidity, collection surface area, and head height for candidate craton interior sites.
- Structural resonance analysis of coupled fluid-structure dynamics in a supertall building containing utility-scale internal hydraulic flow.
- Material science assessment of penstock options for 10 to 20 MPa static pressure with cyclic loading from daily generation and storage cycles.
- Scaled prototype: a 10-meter tower with VAHS hydraulic loop and atmospheric water harvesting integration to validate round-trip efficiency in real atmospheric conditions.

8.2 Pillar Three — Sky-Shield Lightning Array

- Scaled four-tower array at a high-elevation test site — the Säntis Tower research infrastructure is an ideal partner location given existing 100-plus strikes per year documentation.
- Laboratory-scale pseudospark and Galinstan two-stage switching prototype at intermediate current levels (500 to 5,000 amperes) to characterize switching speed and energy capture fraction before field deployment.
- Measurement of actual energy capture fraction per strike at laboratory scale to validate the 15 percent theoretical capture efficiency assumption.
- Long-term Galinstan durability study under repeated high-current impulse cycling over 1,000 to 10,000 simulated lightning impulse events.

8.3 Pillar Four — Fibonacci-Honeycomb-Pi Battery

- COMSOL Multiphysics multi-physics simulation comparing Fibonacci-packed electrode against random-sphere-packed electrode: coupled diffusion-thermal-mechanical model measuring effective diffusion coefficient, thermal distribution uniformity, and stress field distribution.
- Two-photon polymerization lithography fabrication of a hexagonal micro-lattice electrode at laboratory scale.
- Synchrotron X-ray computed tomography to visualize ion concentration gradients during a 10C charge cycle in the Fibonacci-honeycomb prototype versus a standard 4680 cylindrical cell.
- Application of Fibonacci-honeycomb geometry to M-rGO graphene supercapacitor electrodes (following Jovanović et al. 2025 baseline) to test whether geometry optimization compounds the M-rGO performance gains.

- Manufacturing pathway study for hexagonal electrode stacks using stack architecture rather than jelly roll winding to avoid the circular mandrel dependency.

8.4 System Integration

- Power electronics topology design for combining steady hydraulic DC, variable atmospheric input, and nanosecond lightning impulse into a single battery bank — specifically identifying multilevel converter or hybrid energy storage architecture capable of handling all three input profiles.
- Economic modeling of the full Resonance Energy Spine comparing total cost of ownership against conventional SMR baseload plus lithium-ion storage at equivalent capacity, incorporating dual-use water-energy cost amortization.

9. Limitations

This paper is a theoretical framework. Every limitation is named honestly because named limitations are the map that tells the next researcher where to go.

- The Fibonacci electrode tortuosity reduction hypothesis is unvalidated experimentally. The MacMullin number improvement from $\tau = 3.0$ to $\tau = 1.5$ is a theoretical calculation. Laboratory validation is required before this claim can be elevated from hypothesis to finding.
- The Galinstan switching architecture has a 120-fold current mismatch between published performance (250A) and lightning return stroke peak current (30,000A). The staged current division solution is proposed but not prototyped.
- Lightning harvesting contributes 0.001 to 0.007 percent of total system energy output. Its value is correctly framed as pulse capture, grid services, and research instrumentation rather than bulk energy generation. Papers that cite this work should not overstate the lightning energy contribution.
- The VAHS gravity turbine at 2,000 meter head generates pressure at the base of 19.62 MPa (196 bar). This is within the engineering range of high-strength steel penstocks but has not been demonstrated inside an inhabited building structure.
- The manufacturing pathway for hexagonal electrode stacks does not currently exist at commercial scale. The research agenda addresses this but it is a real barrier to near-term implementation.
- The Resonance City cluster context assumed in this paper — a million-person inhabited vertical megastructure — does not yet exist. The energy architecture is designed for a structure that is itself a theoretical proposal. Validation must proceed in stages from laboratory prototype to scaled pilot before the full system is buildable.

10. Conclusions

The frontier is closed. The SS Grampian does not sail anymore. There is no unclaimed territory capable of absorbing the pressure of civilizational failure. What Daniel Dominey found when he arrived in Canada in 1908 — a comparatively stable geological platform, lower complexity, the possibility of reconstruction — must now be engineered rather than discovered.

The Resonance Energy Spine names the energy architecture of that engineering response. Four pillars. Gravity provides the baseload. Atmosphere provides the water and the hydraulic feedstock. Lightning provides the pulse and the demonstration. Geometric intelligence provides the storage that makes the whole system cohere.

None of these pillars requires new physics. Pelton turbines at extreme head are proven at Bieudron. Pumped storage is the dominant global grid-scale storage technology. Atmospheric water harvesting is an active commercial field. Graphene supercapacitors approaching battery energy density are published in Nature Communications in 2025. Lightning strike frequency at altitude is documented in detail at the Sântis Tower. Hexagonal geometry is understood from the first principles of the honeybee.

What is new is the synthesis. The four pillars together form a closed energy architecture that no single existing engineering domain has assembled. The Fibonacci-honeycomb-pi geometry that governs the battery cells is the same geometry that governs the floor plates of the building and the arrangement of the lightning capture towers. The mathematics of the natural world — the golden angle that sunflowers use, the hexagon that bees use, the spiral that nautilus shells use — is the mathematics of the architecture.

This paper does not prove the system works. It names the system clearly enough that the people who will prove it can find it. The signal is transmitted. The architects of civilization have the blueprint. What comes next is theirs to build.

References

- [1] Helman, D.S. (2020). Lightning for energy and material uses: A structured review. *Global Challenges*, 4(10). DOI: 10.1002/gch2.201900045
- [2] Jovanović, S., et al. (2025). Multiscale reduced graphene oxide for high-energy and high-power supercapacitors. *Nature Communications*. DOI: 10.1038/s41467-025-xxxxx
- [3] Miranda, D., et al. (2016). Computer simulations of the influence of geometry in the performance of conventional and unconventional lithium-ion batteries. *Applied Energy*, 165, 318-328. DOI: 10.1016/j.apenergy.2015.12.068
- [4] Sarfo, K.A., Taylor, S.E., & O'Mullane, A.P. (2020). Investigating liquid metal Galinstan as a high current carrier. *ACS Applied Electronic Materials*. DOI: 10.1021/acsaelm.0c00551
- [5] Rakov, V.A., & Uman, M.A. (2003). *Lightning: Physics and Effects*. Cambridge University Press. ISBN: 978-0521583275
- [6] Kingfield, D.M., et al. (2017). Antenna towers attract additional lightning strikes. *Geophysical Research Letters*. DOI: 10.1002/2017GL073889
- [7] Shindo, T. (2018). Lightning striking characteristics to tall structures. *IEEJ Transactions on Electrical and Electronic Engineering*, 13(7).
- [8] BYD Company. (2022). Hexagonal prismatic battery cell. Chinese Patent CN202210704829.6.
- [9] SOM / Energy Vault. (2024). EVc building-integrated pumped hydro storage concept. Energy Vault Inc., Westlake Village CA.
- [10] Bergant, A., Simpson, A.R., & Tijsseling, A.S. (2006). Water hammer with column separation. *Journal of Fluids and Structures*, 22(2). DOI: 10.1016/j.jfluidstructs.2005.08.010
- [11] Holzer, L., et al. (2023). Tortuosity and microstructure effects in porous media. *Springer Series in Materials Science*, Vol. 333.
- [12] Sedajova, V., et al. (2022). Nitrogen doped graphene with diamond-like bonds. *Energy & Environmental Science*. DOI: 10.1039/D1EE03549A

- [13] Tainter, J.A. (1988). The Collapse of Complex Societies. Cambridge University Press.
- [14] Ord, T. (2020). The Precipice. Bloomsbury Publishing. ISBN: 978-1526600219
- [15] Jakosky, B.M., et al. (2015). MAVEN observations of Mars atmosphere. Science, 350(6261). DOI: 10.1126/science.aad0210
- [16] Carter, J.E. (2026). Geological Pathway Diversity Model (GPDM). EarthArXiv. DOI: 10.31223/X5J47D
- [17] Carter, J.E. (2026). The Vertical Arcology Hydraulic Spine (VAHS). Zenodo Preprint. DOI: pending
- [18] IEC 62305-1:2024. General principles of lightning protection.
- [19] Ge, S., et al. (2009). Did Zipingpu Reservoir trigger the 2008 Wenchuan earthquake? Geophysical Research Letters. DOI: 10.1029/2009GL040349
- [20] Mongird, K., et al. (2020). Energy Storage Technology and Cost Characterization Report. PNNL-28866. DOI: 10.2172/1573487
-

Presignal Research Initiative

Presignal Inc. · Niagara Region, Ontario, Canada
jubecrew@gmail.com · ORCID 0009-0004-1363-304X
ufosworldwide.com/presignal