EDU-410 SYNTHETIC MANUAL - revision 1

Fictional teaching controller. Not Saturn equipment.

Purpose: collect sensor values in a classroom test stand.

Supply: 24 V DC. Disconnect supply before wiring.

Digital inputs: 4. Analog inputs: 2.

Do not use these invented values in an engineering project.

EDU-410 - Wiring and configuration

RS-485 terminals: A, B and signal reference.

USB is reserved for local configuration using EDU-CONFIG.

Default Modbus address: 7.

Serial configuration: 9600 bit/s, 8N1.

Do not connect the classroom bus to a live plant.

EDU-410 - Diagnostic procedure

If the controller does not reply, check the 24 V supply.

Then check the Modbus address and A/B polarity.

A status LED flashes once per second in the synthetic test.

No wireless interface is specified in this manual.

Contact a teacher if the fictional test cannot be completed.