EDU-420 SYNTHETIC MANUAL - revision 1

Fictional teaching gateway. Not Saturn equipment.

Supply: 12 V DC. Network interface: Ethernet.

Application protocol: Modbus TCP.

This example has no wireless module.

The example is a teaching document, not real product advice.

EDU-420 - Network configuration

Default IPv4 address: 192.0.2.42.

Modbus TCP port: 502.

The address belongs to the documentation-only TEST-NET range.

Connect the isolated classroom network before the test.

Do not connect this example to a production network.

EDU-420 - Troubleshooting

If Ethernet is unavailable, check link and 12 V supply.

Then check the configured IPv4 address and TCP port 502.

No BACnet behavior is implemented in this synthetic manual.

Restore the classroom configuration after testing.

End of the authored fictional manual.