

3.30**swell threshold**

voltage magnitude specified for the purpose of detecting the start and the end of a swell

3.31**time aggregation**

combination of several sequential values of a given parameter (each determined over identical time intervals) to provide a value for a longer time interval

NOTE Aggregation in this standard always refers to time aggregation.

3.32**underdeviation**

the absolute value of the difference between the measured value and the nominal value of a parameter, only when the value of the parameter is lower than the nominal value

3.33**voltage dip**

temporary reduction of the voltage magnitude at a point in the electrical system below a threshold

NOTE 1 Interruptions are a special case of a voltage dip. Post-processing may be used to distinguish between voltage dips and interruptions.

NOTE 2 A voltage dip is also referred to as sag. The two terms are considered interchangeable; however, this standard will only use the term voltage dip.

3.34**voltage swell**

temporary increase of the voltage magnitude at a point in the electrical system above a threshold

3.35**voltage unbalance**

condition in a polyphase system in which the r.m.s. values of the line voltages (fundamental component), and/or the phase angles between consecutive line voltages, are not all equal

[IEV 161-08-09, modified]

NOTE 1 The degree of the inequality is usually expressed as the ratios of the negative- and zero-sequence components to the positive-sequence component.

NOTE 2 In this standard, voltage unbalance is considered in relation to 3-phase systems.

4 General**4.1 Classes of measurement methods**

For each parameter measured, three classes (A, S and B) are defined. For each class, measurement methods and appropriate performance requirements are included.

– Class A

This class is used where precise measurements are necessary, for example, for contractual applications that may require resolving disputes, verifying compliance with standards, etc. Any measurements of a parameter carried out with two different instruments complying with the requirements of Class A, when measuring the same signals, will produce matching results within the specified uncertainty for that parameter.