

PORTER SUBDIVISION | LOTS 1 & 2

1005 & 1009 ROLLINS AVENUE, PRINCE GEORGE'S COUNTY, MARYLAND

DETAILS: USE THE COUNTY STANDARD; REPRODUCED DETAILS ARE NOT TO SCALE

Pavement
2 1/2" min.
Graded Aggregate Subbase
Under Concrete Curb and Gutter

Standard Concrete Curb and Gutter
1/4" slope
1'-2"
3/4" R.
1/4" R.
1 1/2"

Depressed Concrete Curb and Gutter @ Driveway
(See note No. 6 below)

Depressed Concrete Curb and Gutter @ Sidewalk Ramp
(See note No. 6 below)

Spill Concrete Curb and Gutter
(See note No. 1 below)

General Notes

- Use of spill concrete curb and gutter requires special Departmental approval, except for "Urban Major Collector Road" design.
- The slope (*) of a spill concrete curb and gutter pan shall be equal to the cross slope of roadway paving.
- Install expansion joints using 1/2" preformed non-extruding joint filler, at 100' intervals, at the beginning and end of curves with less than 100' radii, at structures, and at midpoints of curb returns.
- All construction joints shall be located at 10' intervals. The contraction joints shall be constructed to a depth equal to 1/4 of the depth of the thickness of the concrete.
- All concrete shall be Class I (MSHA Mix No. 3) air-entrained, unless otherwise approved by the Department. The surface shall be brush finished.
- The depressed concrete curb and gutter sections shall be used at all driveway aprons and sidewalk ramps.
- Preformed joint fillers shall conform to M 153. The bituminous fiber type joint shall conform to M 213, with the bitumen content determined using T 164.
- Granite curb and gutter may be required under certain conditions.
- Provide uniform subgrade under entire roadway section.
- All new construction within the County right-of-way shall comply with Federal accessibility guidelines of the Americans with Disabilities Act and Fair Housing regulations.

APPROVED:

DIRECTOR

DATE

REVISION DATE:

APPROVED BY:

DEPARTMENT OF PUBLIC WORKS
AND TRANSPORTATION
Prince George's County, MD

Concrete Curb
and Gutter

STD.
300.01

Heavy line shown around sidewalk ramp denotes typical 1/2" preformed expansion joint placement.

R/W line
4/5' Sidewalk
5' min.
Sod
6/8" Hiker/Biker Trail
12:1 max.
1:10 max.
1/2" Expansion joint
Top Landing
Flared ramp sides
6' min.
4' min.
6' min.
Typical curb and gutter
Contraction joint
2' x 4' Detectable warning surfaces across full ramp width
1/2" Expansion joint (Both sides, front and rear of ramp)

The concrete sidewalk ramp shall be located in the middle of the curbed fillet. See Standard 300.05 for additional information.

Construct concrete slab under detectable warning surface, 6" thick x full width of ramp.

Detail - Flared Sidewalk Ramp
(See Notes 7 & 8)

1/2" expansion joint
2% max. slope
Typical roadway paving
4" Graded Aggregate Base
10"

Section A-A

General Notes

1.6" min./2.35" max.
0.9" dia. min.
1.4" dia. max.
0.45" dia.
0.2" Height

Detectable Warning Surface
Raised Truncated Domes

1. All new concrete sidewalk ramps and depressed curbs constructed within the County right-of-way shall comply with the Federal accessibility guidelines of the Americans with Disabilities Act. See Standard 300.01 for depressed curb requirements.

2. All sidewalk ramps and their approaches shall be designed and constructed so that water will not accumulate on walking surfaces.

3. The sidewalk ramp shall be constructed with the least possible running slope, not to exceed 12:1.

4. All concrete shall be Class 1 (MSHA Mix No. 3) air-entrained unless otherwise approved by the Department. The surface shall be broom finished.

5. Provide 4" thick graded aggregate base material under all concrete sidewalk and sidewalk ramps.

6. Detectable warning surface shall be 1" thick (hollow tile) diamond-hard vitrified polymer material, embedded into concrete with truncated dome pattern as specified above, and shall contrast visually with the adjacent surface (either dark-on-light or light-on-dark.) Color requirements: Use brick red panel with brick crosswalk and dark gray panel at all other locations.

7. Detectable warning surface shall be installed 6 to 8 inches behind the curb line, extend two feet in the direction of travel over the full width of the ramp, and shall be embedded so as to be flush with the surrounding surface.

8. FOR SKEWED APPLICATIONS DETECTABLE WARNING SHALL BE PLACED SUCH THAT THE DOMES CLOSEST TO THE BACK OF THE CURB ARE NO LESS THAN 0.5" AND NO MORE 3.0" FROM THE BACK OF CURB. TRUNCATED DOME SURFACES SHALL BE FABRICATED TO PROVIDE FULL DOMES ONLY.

APPROVED:

DIRECTOR

DATE

REVISION DATE:

APPROVED BY:

DEPARTMENT OF PUBLIC WORKS
AND TRANSPORTATION
Prince George's County, MD

Concrete Sidewalk
Ramp Type "A"

STD.
300.07

WATER AND SEWER CONNECTION SKETCH - SOURCE REFERENCE. Page 2 of the supplied WSSC connection document. Reproduced without converting its unlabelled private width into a legal dimension. See C-001 for the corrected working route.

GENERAL COORDINATION: the recorded plat condition governs driveway arrangement. Separate aprons as drawn remain subject to DPW&T determination. The frontage walk must meet the applicable county standard or approved modification.

Revision 03/14/12 Specifications and Standards for Roadways and Bridges Section III – 45

Revision 03/14/12 Specifications and Standards for Roadways and Bridges Section III – 51

C-004 | COUNTY DETAILS AND UTILITY REFERENCE

REVISION 1 | 09 SEPTEMBER 2026 | PROFESSIONAL REVIEW