

PORTER SUBDIVISION | LOTS 1 & 2

1005 & 1009 ROLLINS AVENUE, PRINCE GEORGE'S COUNTY, MARYLAND

RECORDED PLAT CONDITIONS - COMPLETE

1. Development of this property shall be in accordance with the approved Stormwater Management Concept Plan 41230-2006-00, or any approved revisions thereafter.
2. Approval of this plat is based upon a reasonable expectation that public water and sewer service will be available when needed, and is conditioned on fulfilling all of the Washington Suburban Sanitary Commission authorization DA 4916 Z 08 commitments.
3. The applicant, his heirs, successors and or assignees shall utilize an abutting driveway design, constructed per DPW&T standards and requirements. Separate, standard residential driveway aprons shall be provided along Rollins Avenue, if deemed appropriate by DPW&T upon the issuance of street construction permits.

ADJOINERS OF RECORD

NORTHEAST: LOTS 13, 14 AND 15 - Addition to Pleasant Park, Plat Book VJ 185, Plat 76

SOUTHWEST: LOT 12 - Addition to Pleasant Park, Plat Book VJ 185, Plat 76

NORTHWEST: OUTLOT A - Addition to Pleasant Park, Plat Book VJ 185, Plat 76

NORTHWEST: JEAN M. YOUNG - L.14377 F.589

ACROSS ROLLINS AVENUE: MAITLAND W. DADE - L.11452 F.473

ACROSS ROLLINS AVENUE: PATRICIA L. FERRELL - L.12766 F.721

ACROSS ROLLINS AVENUE: VALLE GARGAN SUBDIVISION - P.B. WWW 19, P. 41

ACROSS ROLLINS AVENUE: EDWARD B. ROLLINS, TRUSTEE, ET AL - L.12790 F.155

BOUNDARY CONTROL

The recorded plat supplies the boundary survey/control for this drawing. Original owner/surveyor signatures apply to that recorded instrument. Horizontal control: NAD83. Existing contour interval: 2 ft. Field control and proposed grades require survey and civil design coordination.

POINT	EASTING NAD83	NORTHING NAD83
A	1340254.7066	440194.1578
B	1340447.7902	440229.9981
C	1340488.3440	440011.4450

LOT DRAINAGE CALCULATIONS

PARAMETER	LOT 1	LOT 2
Area (SF)	9598	8008
Roof (SF)	1,196	1,196
Impervious union (SF)	1617.50	1617.50
Impervious (%)	16.85	20.20
Composite C pre	0.250	0.250
Composite C post	0.368	0.391
Tc / I10	5 min / 6.71 in/hr	5 min / 6.71 in/hr
Q10 pre (CFS)	0.370	0.308
Q10 post (CFS)	0.544	0.483
WQv screening (CF)	161.3	154.7

Q = C i A; A in acres. Weighted C uses roof/paving 0.95 and pervious area 0.25. Impervious areas use geometric unions of the dwelling, driveway, stoop and corrected leadwalk.

Rainfall: NOAA Atlas 14, Volume 2 Version 3, 38.8752 N / 76.9019 W; 10-year, 5-minute intensity 6.71 in/hr. Tc is the existing model's five-minute minimum; final drainage design must validate the actual flow path and surface classification.

WQv = P Rv A / 12; P = 1.0 inch; Rv = 0.05 + 0.009 I (I in percent). This is a screening water-quality volume, not proof of current ESDv, recharge or channel-protection compliance.

Frontage paving is excluded from lot catchments and listed in the disturbance takeoff. Final drainage analysis must include its receiving system and all upstream tributary areas.

GRADING AND DRAINAGE CRITERIA

Design positive drainage away from foundations and protect adjoining land. Show finished-floor, corner, garage, critical spot and facility elevations in the final engineering design.

Coordinate driveway profiles with garage slabs and existing curb grades. County site/road checklist: driveway 1% minimum / 12.5% maximum; provide compliant accessible pedestrian cross slopes.

Keep utility trenching, trees, building projections and drywell construction clear of each other. Protect the proposed drywell receiving areas during construction.

ENVIRONMENTAL RECORD

M-NCPPC staff report for Preliminary Plan 4-06111 documents NRI/116/06 (September 21, 2006), a woodland exemption issued June 7, 2007, and Concept 41230-2006-00 (May 21, 2007) proposing drywells on both lots.

That review reports no streams, wetlands, 100-year floodplain or Marlboro clay on site and identifies Adelphia, Sassafras and Westphalia soil series. These are historical agency findings, not new onsite measurements. The exemption letter and current concept documentation remain application attachments.

Source: M-NCPPC, Porter Property staff report, 4-06111, pages 2-3. A copy is included in the source folder.

PARCEL-INTERSECTION SOIL MAPPING

AeB: Adelphia-Holmdel-Urban land complex, 0 to 5 percent slopes; HSG B/D; Somewhat poorly drained; hydric No; K .24.

AeB: Adelphia-Holmdel-Urban land complex, 0 to 5 percent slopes; HSG C; Moderately well drained; hydric No; K .37.

AeB: Adelphia-Holmdel-Urban land complex, 0 to 5 percent slopes; HSG D; None; hydric No; K None.

Soil map-unit properties are regional mapping data. Facility design requires site-specific infiltration and groundwater investigation.

BUILDING DESIGN COORDINATION

Kingsworth drawing 260811 provides a 36-foot main house with an optional 10-foot ONE-CAR garage and a nominal 26-foot depth. The 46 x 26 site footprint includes that garage. A two-car garage is not represented by the source drawing.

The supplied architectural source contains a basement foundation and rear areaway. The actual basement/areaway option, floor heights and wall sections must be coordinated with the full building design. This civil revision does not purport to supply missing architectural or structural sheets.

PROFESSIONAL CERTIFICATION

I hereby certify that these documents were prepared or approved by me, and that I am a duly licensed professional engineer under the laws of the State of Maryland.

SIGNATURE / DATE

LICENSE NUMBER / EXPIRATION

OWNER / APPLICANT / CONTACT