

SUPPORT SPACING VS CABLE OD		
SUPPORT SPACING ON CENTER MAXIMUM	CABLE OD	CLAMPS BETWEEN SUPPORTS.
4' (1220MM)	<0.300"	2' (610MM)
6' (1830MM)	>0.300"	3' (915MM)

IMPORTANT: ACTUAL SIZES OF HANGERS, BOLTS, NUTS AND FASTENERS ARE TO BE ADJUSTED FOR THE WEIGHT SUPPORTED AND AREA SEISMIC CONDITIONS. PROVIDE SEISMIC BRACING (NOT SHOWN) WHERE REQUIRED. COMPLY WITH "SYSTEM 1850" UL FIRE RESISTANCE DIRECTORY.

C:\USERS\JUSIS\MY DOCUMENTS\ACADE 2026\EDATA\PROJ\CAD POWER DISTRIBUTION\STEEL STRUT CHANNEL.DWG

Autodesk®

C:\USERS\ASUS\My Documents\ACADE 2026\ACADE
 CAD FILE IN: C:\USERS\ASUS\My Documents\ACADE 2026\ACADE
 SHEET NO: *OF 4*