



# SHIV ELECTRICAL & ENGINEERING WORKS

(AN ISO 9001: 2015 CERTIFIED)

## Works (Routine) Test Certificate

1.	EQUIPMENT TESTED	LOW TENSION- L.T. C.T (Epoxy Resin Type)
2.	CUSTOMER NAME	dev chugh
3.	SPECIFICATIONS	The Following Routine Test conforming to IS:2705/1992
4.	RATIO	800/5A
5.	RATED VOLTAGE	415 KV
6.	H S V	
7.	BURDEN	5VA
8.	ACCURACY CLASS:	0.5
9.	I L	0.66 KV
10.	FREQUENCY	50 Hz
11.	S. T .C	5 KA for 1 Sec.
12.	The Following Test have been Conducted on above CT	
I.	Verification of terminal marking and Polarity test	OK
II.	Ratio & Phase Error Test on CT	OK ( Result Attached )
III.	Power Frequency dry withstand test between primary winding & earth ( Secondary terminal shorted together and earthed)	28 KV (rms) Withstood
IV.	Power Frequency dry withstand test between Secondary winding & earth	3 KV (rms) Withstood
V.	Over Voltage Inter-turn Test on secondary winding at rated current for 60 sec	Withstood
VI.	Partial Discharge Test as per IS 11322/1985	Withstood
VII.	PRIMARY Terminal Marking	P1-P2
VIII.	SECONDARY Terminal Marking	S1-S2

### 13. RATIO & PHASE ANGLE ERROR TEST

SR NO.	CURRENT RATIO	BURDEN	TYPE OF ERROR	PERCENTAGE OF RATED PRIMARY CURRENT				
				120%	100%	20%	5%	1%
SE-9103-A	50/5A	5 VA	CURRENT ERROR IN %	-0.070	-0.072	-0.131	-0.228	-0.264
			PHASE ERROR IN MIN.	0.26	0.10	0.50	3.84	3.84
SE-9103-B	50/5A	5 VA	CURRENT ERROR IN %	-0.044	-0.045	-0.074	-0.101	-0.114
			PHASE ERROR IN MIN.	0.38	0.36	1.28	3.04	4.10
SE-9103-C	50/5A	5 VA	CURRENT ERROR IN %	-0.039	-0.044	-0.083	-0.128	-0.156
			PHASE ERROR IN MIN.	0.18	-0.06	0.94	3.30	5.64



Testing Engineer  
SHIV ELECTRICAL & ENGINEERING WORKS  
Panipat (HARYANA)

Dated: 08.04.2024

Factory & Office: VPO- Brahman Majra, Bahadaur Road, Panipat-132103(HR.)

Email: shivelectrical414@gmail.com