

Visionera Pvt Ltd

Sujathanagar, Pendurthi, Visakhapatnam, Andhra Pradesh, 531173

GSTIN: 37AAJCV0447L1ZX

Ph: 9347475257

E-mail: bdo2.zy@myntreal.com

Annexure - C

Project Completion Report for Grid-Connected Rooftop

PM Surya Ghar Application Reference Number	NP-APEP
Discom Solar Roof Top Registration No	NP-APEPD
SC No	123456789
Installed by Vendor	Visionera Pvt Ltd
Title of the Project	3KW ON GRID SOLAR ROOF TOP
SPV Capacity (kWp)	3KW
Category of the organization / beneficiary	Ruttala Bala Krishana
Name of the contact person	Ruttala Bala Krishana
Address of contact person	12-22, Kameswari Nagar, Tamarana Village
State	Andhra Pradesh
District / City	Visakhapatnam-531113
Mobile	9676399937
Email	ruttalabalakrishna81@gmail.com
Aadhaar Card Number (For Residential)	777022122155
Latitude	123456
Longitude	236548
DISCOM	APEPDCL
Sanction Load	3KW

Technology Description & System Design / Specification

(Compliance to BIS / IEC Standards is mandatory)

Solar PV Module	APS
Power of each PV Module	Each 550W
Number of Modules	6 Nos
Cumulative Capacity of Modules	3KW
Solar cell technology	550
Tilt Angle of Modules	15
Module efficiency	Attached
Azimuth	—
Indigenous or imported (Cell)	Indigenous
RFID passed inside or outside	INSIDE

Indigenous or imported (Module)	Indigenous
Inverter	APS APSG
Type of inverter	Grid
Power of each PCU / Nos of inverters	01 No
Capacity / Power of PCU / inverters	3
Type of Charge Controller / MPPT	3KW MPPT Inverter
Inverter efficiency	97
Grid connectivity level phase	Single
Grid connectivity level Voltage	240.0V

Signature of Vendor (With Stamp & Seal)

T. Jyothirmai

Stamp



This is a Computer Generated Document

