

Visionera Pvt Ltd

Sujathanagar, Pendurthi, Visakhapatnam, Andhra Pradesh, 531173

GSTIN: 37AAJCV0447L1ZX

Ph: 9347475257

E-mail: bdo2.zy@myntreal.com

Annexure - C

Project Completion Report for Grid-Connected Rooftop

PM Surya Ghar Application Reference Number	NP-APEPD26-10329538
Discom Solar Roof Top Registration No	10329538
SC No	115451I900019647
Installed by Vendor	Visionera Pvt Ltd
Title of the Project	3KW ON GRID SOLAR ROOF TOP
SPV Capacity (kWp)	3KW
Category of the organization / beneficiary	korapolu Manikyam
Name of the contact person	korapolu Manikyam
Address of contact person	3-172, Saradanagar, Bhaligattam, Narsipatnam, Anakapalli
State	Andhra Pradesh
District / City	Anakapalli-531116
Mobile	7416685458
Email	koruprolumanikyam5@gmail.com
Aadhaar Card Number (For Residential)	510136422811
Latitude	17.658437
Longitude	82.614575
DISCOM	APEPDCL
Sanction Load	3KW

Technology Description & System Design / Specification

(Compliance to BIS / IEC Standards is mandatory)

Solar PV Module	Vikram Solar
Power of each PV Module	Each 550W
Number of Modules	6 Nos
Cumulative Capacity of Modules	3KW
Solar cell technology	Shark 590-Monocrystalline
Tilt Angle of Modules	vfgcfvh
Module efficiency	Attached
Azimuth	—
Indigenous or imported (Cell)	Indigenous
RFID passed inside or outside	INSIDE

Indigenous or imported (Module)	Indigenous
Inverter	3S Solutions ghgj
Type of inverter	bgvn
Power of each PCU / Nos of inverters	01 No
Capacity / Power of PCU / inverters	3KWp
Type of Charge Controller / MPPT	3KW MPPT Inverter
Inverter efficiency	cx
Grid connectivity level phase	Single Phase
Grid connectivity level Voltage	240.0V

Signature of Vendor (With Stamp & Seal)

T. Jyothirmai

