

Visionera Pvt Ltd

Sujathanagar, Pendurthi, Visakhapatnam, Andhra Pradesh, 531173

GSTIN: 37AAJCV0447L1ZX

Ph: 9347475257

E-mail: bdo2.zy@myntreal.com

Annexure - C

Project Completion Report for Grid-Connected Rooftop

PM Surya Ghar Application Reference Number	10510458
Discom Solar Roof Top Registration No	10510458
SC No	115451I900013872
Installed by Vendor	Visionera Pvt Ltd
Title of the Project	3KW ON GRID SOLAR ROOF TOP
SPV Capacity (kWp)	3
Category of the organization / beneficiary	KHWAJA NIYAZ
Name of the contact person	KHWAJA NIYAZ
Address of contact person	3-3-230, Saradanagar, Narsipatnam
State	Andhra Pradesh
District / City	Visakhapatnam-531116
Mobile	9490128796
Email	kdnaran4@gmail.com
Aadhaar Card Number (For Residential)	910183691647
Latitude	17.659286
Longitude	82.612976
DISCOM	APEPDCL
Sanction Load	3

Technology Description & System Design / Specification

(Compliance to BIS / IEC Standards is mandatory)

Solar PV Module	Australian Premium Solar (India) Limited
Power of each PV Module	Each 550W
Number of Modules	6 Nos
Cumulative Capacity of Modules	3
Solar cell technology	MONO PERC
Tilt Angle of Modules	12
Module efficiency	Attached
Azimuth	—
Indigenous or imported (Cell)	Indigenous
RFID passed inside or outside	INSIDE

Indigenous or imported (Module)	Indigenous
Inverter	APS APSG-1-3
Type of inverter	Grid
Power of each PCU / Nos of inverters	01 No
Capacity / Power of PCU / inverters	3
Type of Charge Controller / MPPT	3KW MPPT Inverter
Inverter efficiency	98%
Grid connectivity level phase	Single Phase
Grid connectivity level Voltage	240.0V

Signature of Vendor (With Stamp & Seal)

T. Jyothirmai

Stamp



This is a Computer Generated Document