

AREA PROTECTED	NO. OF NOZZLES	K FACTOR	SPRAY ANGLE	TRIGGER HEADS	LINE No. 1	LINE No. 2	LINE No. 3	LINE No. 9	LINE NO. 10	LINE NO. 11	TAG A TAG B	TAG C TAG D	TAG E TAG F	TAG G TAG H	TAG   TAG	I TAG K TAG I	L TAG M	TAG N TAG O	TAG P TAG AA	DV SKID NO	SUCTION COLLECTION HEAD NO.
COMPRESSOR (530-K-101)	21	50	140°	21	4"-WF-9286-Q35A	4"-WF-9261-Q35A	4"-WF-9262-Q15A	4"-WF-9260-Q35A	1"-AI-1775-S10A		1						1				SCH-27
COMPRESSOR (530-K-201)	21	50	140°	21	4"-WF-9277-Q35A	4"-WF-9270-Q35A	4"-WF-9271-Q15A	4"-WF-9269-Q35A	1"-AI-1774-S10A	1/2"-AI-9020-S10A	9024A 9024B	9024C 9024D	9024E 9024F	9024G 9024H	90241 9024	9024K 9024	L 9024M	9024N 9024C	9024P SP-014	4 DVS-24	SCH-28
COMPRESSOR (530-K-301)	21	50	140°	21	4"-WF-9268-Q35A	4"-WF-9279-Q35A	4"-WF-9280-Q15A	4"-WF-9278-Q35A	1"-AI-1773-S10A	1/2"-AI-9021-S10A	9025B 9025B	9025C 9025D	9025E 9025F	9025G 9025H	90251 9025	9025K 9025	L 9025M	9025N 90250	9025P SP-015	5 DVS-25	SCH-29

## GENERAL NOTES:

A. FOR STANDARD SYMBOLS AND NOMENCLATURE SEE DRAWINGS 50489-530-020-PID-1104.001 & 1105.001. B. ALL EQUIPMENT NUMBERS SHOWN ON THIS P&ID ARE PRECEDED BY 530-. C. FOR ESDV, SBDV AND MOV DETAILS SEE DRAWINGS 50489-530-020-PID-1106.001 & 1107.001 D. FOR MISCELLANEOUS PIPING DETAILS SEE DRAWING 50489-530-020-PID-1108.001. E. FOR TYPICAL VALVING, DRAINAGE AND GENERAL ARRANGEMENT OF LEVEL INSTRUMENTATION,

PUMPS AND CONTROL VALVES SEE DRAWING 50489-530-020-PID-1109.001.

- 1. UV/IR FLAME DETECTORS AUTOMATICALLY DETECT FIRE AND WHEN ACTIVATED A SIGNAL IS SENT TO THE F&G PANEL IN THE CCR. 2. AIR SET IS FITTED WITH AIR FILTER, REGULATOR AND PI.
- 3. RO SUPPLIED TO GIVE PRESSURE/LOSS CHARACTERISTICS OF THE DELUGE VALVE. 4. 4 WAY SUCTION COLLECTION HEAD IS INSTALLED TO ALLOW SECONDARY SUPPLY OF WATER TO DELUGE SYSTEM.
- 5. DELUGE VALVE IS DIAPHRAGM TYPE DESIGNED FOR DELUGE OPERATION AND BE UL LISTED AND FM APPROVED 6. TRIGGER HEAD CONFIGURATION 1/2" FUSABLE PLUGS OVER PROTECTED EQUIPMENT ON A GENERAL 3 x 3 METRE MATRIX
- 7. 2 VALVES REQUIRED IN BYPASS LINE TO PREVENT UNNECESSARY LOSS OF WATER DUE TO GATE VALVE PASSING.
- 8. ADEQUATE DRAINAGE IS PROVIDED AROUND DELUGE SYSTEM TO AVOID ACCUMULATION OF WATER AROUND THE EQUIPMENT
- 9. PROVISION ARE MADE FOR PRESSURE TESTING AS PER NFPA 15 CLAUSE NO.
- 6.4.4 & 6.4.4.5 NEAR THE HYDRAULICALY REMOTEST NOZZLE.
- 10. DELUGE VALVES SHALL BE HELD CLOSED BY AIR PRESSURE SUPPLIED FROM THE INSTRUMENT AIR SYSTEM. 1. DELUGE VALVES SHALL FULLY OPEN WITHIN 10 SECONDS ON REMOVE OF INSTRUMENT AIR BY A. REMOTE OPERATION OF A PUSH BUTTON AT THE MAIN FIRE AND GAS PENEL, LOCATED IN THE CONTROL ROOM, TO ENERGIZE A SOLENOID VALVES IN INSTRUMENT AIR SUPPLY TO DELUGE VALVE

B. LOCAL OPERATION OF A MECHANICAL AIR RELEASE UNIT OF DELUGE VALVE STATION.

- 12. SPRAY NOZZLE IS CONSTRUCTED FROM MAINE BRASS. 13. DELUGE VALVE STATIONS ARE PROTECTED FROM RADIATED HEAT BY THE PROVISION OF
- METAL RADIATION SHIELDS. 14. PIPE MOC (AS PER KOC-L-009):
- 3" SIZE AND BELOW: 90-10 COPPER NIKEL TO ASTM B 466 UNS. 4" SIZE AND ABOVE : CARBON STEEL API 5L GRB WITH PHENOLIC EPOXY COATING. 15. FLANGE INSULATION KITS ARE PROVIDED AT DISSIMILAR METAL JUNCTIONS HAVING ELECTROMOTIVE POTENTIAL DIFFERENCE GREATER THAN 0.05V
- AS PER CLAUSE 7.3.1.17 OF KOC-L-009. 16. INTERNALLY COATED UG PIPING ARE FLANGED SPOOLS AS PER KOC-L-009.
- 17. FLUSHING DRAIN PIT IS ACCESSIBLE FROM GROUND LEVEL. 18. THE UNDERGROUND SECTION SHALL BE EXTERNALLY COATED WITH 3 LAYERS EXTRDED HDPE AS PERKOC-PO04 PART 6, REV-2 WITH THE INTERNAL PHENOLIC EPOXY ON THE PIPING SHALL BE
- AS PER KOC-P-005 REV-1. 19. THE ABOVE GROUND PIPING SECTION ARE COATED WITH SYSTEM A1—1 OF KOC—P—001 REV 3 20. TOP CHAMBER OF DELUGE VALVE IS CONNECTED TO WATER LINE & TO WATER INLET OF ACTUATOR WHEN THE AIR PRESSURE DROPS DUE TO DETECTION OF FIRE THE DIAPHRAGM OF ACTUATOR IS LIFTED AND ALLOWS THE WATER PRESSURIZING DIAPHRAM OF DELUGE VALVE TOP CHAMBER TO DRAIN. THIS RELESES THE PRESSURE IN THE TOP CHAMBER OF DELUGE VALVE

## LEGENDS:

	SYMBOL	DESCRIPTION							
>	S——FW S	FIRE WATER PIPING							
	$\downarrow$	SPRAY NOZZLE							
		REDUCER							
		GATE VALVE							
	—D	END CAP							

## DEFEDENCE DEAWINGS.

ALLOWING THE DELUGE VALVE TO OPEN.

REFERENCE DRAWINGS:									
50489-530-000-CAL-1015	HYDRAULIC CALCULATION FOR WATER SPRAY SYSTEM FOR TANK VAPOUR COMPRESSOR								
KOC-L-009	KOC STANDARD FOR FIRE PROTECTION SYSTEMS								
50489-530-000-LAD-1065	FIRE WATER NETWORK LAYOUT								

			Daysak	7	Q Cyl		
	<b>Z</b> 0	ISSUED FOR AS-BUILT	PAK/DEU	NIJ	SRA	RAK	12.08.18
	01	RE-ISSUED FOR CONSTRUCTION	PAK/DEU	NIJ	SRA	RAK	16.07.16
	0	ISSUED FOR CONSTRUCTION	PAK/DEU	NIJ	SRA	RAK	13.05.16
	В	ISSUED FOR APPROVAL	PAK/DEU	NIJ	SRA	RAK	10.12.15
	A	ISSUED FOR APPROVAL	PAK/DEU	NIJ	SRA	RAK	20.04.15
Ī	REV.	DESCRIPTION	DRAWN	CHECKED	HOD	PEM	DATE
	I\∟V.	DESCRIFTION	DIVAMIN	CHLCKLD	APP	RD.	DAIL
		CONTRACTO	JB BEMBI	7/1			

CONTRACTOR REVISION



CONTRACTOR DETAILS:-



LARSEN & TOUBRO LIMITED

DEPT/ DIVISON: ENGINEERING

DESIGNATION: AGM

SIGNATURE:

VAIBHAV VERMA

12-Aug-2018

LARSEN & TOUBRO LIMITED FARIDABAD

NEW GATHERING CENTRE GC-30 IN NORTH KUWAIT

DOCUMENT TITLE:-PIPING & INSTRUMENTATION DIAGRAM DELUGE WATER SPRAY SYSTEM FOR TANK VAPOUR COMPRESSOR (530-K-101/201/301)

DDO IECT NO									
PROJECT NO	DRAWING NO.								
	CONTRACTOR DRG. NO.	REV.	KOC DRG. NO.	RE					
	50489-530-000-PID-1127.001	ZO							
FF1000	SHEET NO. 1 OF 2		SHEET NO.						
EF1902	COMPANY DRG. NO.	REV.							
	SHEET NO.								