

AREA PROTECTED	NO. OF NOZZLES	K FACTOR	SPRAY ANGLE	TRIGGER HEADS	LINE No. 1	LINE No. 2	LINE No. 3	LINE No. 4	LINE NO. 10	LINE NO. 11	TAG A TAG B	TAG C TAG D	TAG E TAG F	TAG G TAG	H TAG I	TAG J T	AG K TAG	L TAG M	TAG N TAG O	TAG P TAG AA	DV SKID NO.	SUCTION COLLECTION HEAD NO.
LP SEPARATORS (530-C-101)	56	50	140	56	8"-WF-9071-Q35A	8"-WF-9072-Q35A	8"-WF-9073-Q15A	8"-WF-9074-Q15A	1"-AI-1767-S10A	1/2"-AI-9009-S10A	9001A 9001B	9001C 9001D	9001E 9001F	9001G 9001	H 9001I	9001J 9	001K 900	1L 9001M	9001N 90010	9001P SP-001	DVS-07	SCH-11
LP SEPARATORS (530-C-201)	56	50	140°	56	8"-WF-9133-Q35A	8"-WF-9080-Q35A	8"-WF-9081-Q15A	8"-WF-9082-Q15A	1"-AI-1766-S10A	1/2"-AI-9010-S10A	9002A 9002B	9002C 9002D	9002E 9002F	9002G 9002	H 9002I	9002J 9	002K 900	2L 9002M	9002N 90020	9002P SP-002	DVS-08	SCH-12
LP SEPARATORS (530-C-301)	56	50	140°	56	8"-WF-9134-Q35A	8"-WF-9088-Q35A	8"-WF-9089-Q15A	8"-WF-9090-Q15A	1"-AI-1768-S10A	1/2"-AI-9011-S10A	9003A 9003B	9003C 9003D	9003E 9003F	9003G 9003	H 9003I	9003J 9	003K 900	3L 9003M	9003N 9003O	9003P SP-003	DVS-09	SCH-13

GENERAL NOTES:

A. FOR STANDARD SYMBOLS AND NOMENCLATURE SEE DRAWINGS 50489-530-020-PID-1104.001 & 1105.001. B. ALL EQUIPMENT NUMBERS SHOWN ON THIS P&ID ARE PRECEDED BY 530-. C. FOR ESDV, SBDV AND MOV DETAILS SEE DRAWINGS 50489-530-020-PID-1106.001 & 1107.001 D. FOR MISCELLANEOUS PIPING DETAILS SEE DRAWING 50489-530-020-PID-1108.001. E. FOR TYPICAL VALVING, DRAINAGE AND GENERAL ARRANGEMENT OF LEVEL INSTRUMENTATION, PUMPS AND CONTROL VALVES SEE DRAWING 50489-530-020-PID-1109.001.

1. UV/IR FLAME DETECTORS AUTOMATICALLY DETECT FIRE AND WHEN ACTIVATED

A SIGNAL IS SENT TO THE F&G PANEL IN THE CCR.

2. AIR SET IS FITTED WITH AIR FILTER, REGULATOR AND PI.

3. RO SUPPLIED TO GIVE PRESSURE/LOSS CHARACTERISTICS OF THE DELUGE VALVE.

4 WAY SUCTION COLLECTION HEAD IS INSTALLED TO ALLOW SECONDARY

4. SUPPLY OF WATER TO DELUGE SYSTEM.

5. DELUGE VALVE IS DIAPHRAGM TYPE DESIGNED FOR DELUGE OPERATION AND BE UL LISTED AND FM APPROVED

6. TRIGGER HEAD CONFIGURATION 1/2" FUSABLE PLUGS OVER PROTECTED EQUIPMENT ON A GENERAL 3 imes 3 METRE MATRIX

7. 2 VALVES REQUIRED IN BYPASS LINE TO PREVENT UNNECESSARY LOSS

OF WATER DUE TO GATE VALVE PASSING.

8. ADEQUATE DRAINAGE IS PROVIDED AROUND DELUGE SYSTEM TO AVOID

ACCUMULATION OF WATER AROUND THE EQUIPMENT

9. PROVISION ARE MADE FOR PRESSURE TESTING AS PER NFPA 15 CLAUSE NO. 6.4.4 & 6.4.4.5 NEAR THE HYDRAULICALY REMOTEST NOZZLE.

10. DELUGE VALVES ARE HELD CLOSED BY AIR PRESSURE SUPPLIED FROM THE INSTRUMENT AIR SYSTEM.
11. DELUGE VALVES SHALL FULLY OPEN WITHIN 10 SECONDS ON REMOVE OF INSTRUMENT AIR BY:
A. REMOTE OPERATION OF A PUSH BUTTON AT THE MAIN FIRE AND GAS PENEL, LOCATED IN THE CONTROL ROOM, TO ENERGIZE A SOLENOID VALVES IN INSTRUMENT AIR SUPPLY TO DELUGE VALVE B. LOCAL OPERATION OF A MECHANICAL AIR RELEASE UNIT OF DELUGE VALVE STATION.

12. SPRAY NOZZLE IS CONSTRUCTED FROM MAINE BRASS.

13. DELUGE VALVE STATIONS ARE PROTECTED FROM RADIATED HEAT BY THE PROVISION OF

METAL RADIATION SHIELDS. 14. PIPE MOC (AS PER KOC-L-009):

ALLOWING THE DELUGE VALVE TO OPEN.

3" SIZE AND BELOW: 90-10 COPPER NIKEL TO ASTM B 466 UNS.
4" SIZE AND ABOVE: CARBON STEEL API 5L GRB WITH PHENOLIC EPOXY COATING.
15. FLANGE INSULATION KITS ARE PROVIDED AT DISSIMILAR METAL JUNCTIONS HAVING ELECTROMOTIVE POTENTIAL DIFFERENCE GREATER THAN 0.05V
AS PER CLAUSE 7.3.1.17 OF KOC-L-009.

16. INTERNALLY COATED UG PIPING ARE FLANGED SPOOLS AS PER KOC-L-009.

18. THE UNDERGROUND SECTION ARE EXTERNALLY COATED WITH 3 LAYERS EXTRDED HDPE AS PERKOC—P004 PART 6, REV—2 WITH THE INTERNAL PHENOLIC EPOXY ON THE PIPING ARE

AS PER KOC-P-005 REV-1.

19. THE ABOVE GROUND PIPING SECTION ARE COATED WITH SYSTEM A1-1 OF KOC-P-001 REV 3

20. TOP CHAMBER OF DELUGE VALVE IS CONNECTED TO WATER LINE & TO WATER INLET OF ACTUATOR WHEN THE AIR PRESSURE DROPS DUE TO DETECTION OF FIRE THE DIAPHRAGM OF ACTUATOR IS LIFTED AND ALLOWS THE WATER PRESSURIZING DIAPHRAM OF DELUGE VALVE TOP CHAMBER TO DRAIN. THIS RELESES THE PRESSURE IN THE TOP CHAMBER OF DELUGE VALVE

	LEGENDS:	
	SYMBOL	DESCRIPTION
>	S FW	FIRE WATER PIPING
	\downarrow	SPRAY NOZZLE
		REDUCER
		GATE VALVE
	——D	END CAP

REFERENCE DRAW	INGS:
50489-530-000-CAL-1003	HYDRAULIC CALCULATION FOR WATER SPRAY SYSTEM FOR LP WET CRUDE SEPARATOR
KOC-L-009	KOC STANDARD FOR FIRE PROTECTION SYSTEMS

50489-530-000-LAD-1065 FIRE WATER NETWORK LAYOUT

50489-530-000-LAD-1066 FIRE WATER SPRAY SYSTEM LAYOUT FOR LP SEPARATOR

		Daspake	the	Rou	D.	
ZO	ISSUED FOR AS-BUILT	PAK/DEU	NIJ	SRA	RAK	12.08.18
0	ISSUED FOR CONSTRUCTION	PAK/DEU	NIJ	SRA	RAK	13.05.16
В	ISSUED "INCORPORATED CLIENT COMMENTS"	PAK/DEU	NIJ	SRA	RAK	15.10.15
A	ISSUED FOR APPROVAL	PAK/DEU	NIJ	SRA	RAK	10.04.15
REV.	DESCRIPTION	DRAWN	CHECKED	HOD	PEM	DATE
1\L V.	DESCRIPTION	DIVAWIN	OTILONED	APP	RD.	DATE

CONTRACTOR REVISION



CONTRACTOR DETAILS:-

AS-BUILT
LARSEN & TOUBRO LIMITED

DEPT/ DIVISON: ENGINEERING

DESIGNATION: AGM

VAIBHAV VERMA

12-Aug-2018

NAME:

SIGNATURE :

LARSEN & TOUBRO LIMITED
FARIDABAD

PROJECT TITLE:-

NEW GATHERING CENTRE GC-30 IN NORTH KUWAIT

DEI.

PIPING & INSTRUMENTATION DIAGRAM
DELUGE WATER SPRAY SYSTEM FOR LP WET CRUDE
SEPARATOR (530-C-101/201/301)

			• •						
PROJECT NO.	DRAWING NO.								
	CONTRACTOR DRG. NO.		KOC DRG. NO.	REV.					
	50489-530-000-PID-1117.001	1 zo							
	SHEET NO. 1 OF 2		SHEET NO.						
EF1902	COMPANY DRG. NO.	REV.							
	SHEET NO.								