



THALAIVAR STEELS LIMITED

Heavy Structural Division

An ISO 9001, ISO 14001 & IS 45001 Certified Company

Sanivada Village, Rajeev Nagar, Visakhapatnam - 530046

E Mail : qc.vsp@sujana.com ; structural.vsp@sujana.com

IS 2062



CM/L- 0006171259

TEST CERTIFICATE

To, MATRIX GRATING PVT LTD A/C of TATA BUSINESS HUB LIMITED GAT NO. 447/B BORGAON KAVATE MAHANKAL, Sangli ,Maharashtra -416419	TC No	TSL/26-27-00019
	Date	25-Apr-2026
	Invoice No	STVSP26-27/0054
	Vehicle No	MH16DP5524
	Cust PO No	Multi

We certify that the material described below fully conforms to IS 2062-2011. chemical composition and mechanical properties of the product,as tested in accordance with the scheme of testing and inspection contained in the BIS certification Marks licence no **CM/L 0006171259** are as indicated below against each order

(PLEASE REFER TO IS 2062-2011 FOR DETAILS OF SPECIFICATION REQUIREMENTS)

Batch No	Inv_Qty	Section Name	Grade	Color Code	Brand / Make
S_20260422/1	2.93	ISA 200X200X16	E 350 A	Yellow	SUJANA
S_20260422/3	24.40	ISA 200X200X20	E 350 A	Yellow	SUJANA

Test Results

Chemical Properties

Section Name	Batch No	C%	Si%	Mn%	P%	S%	V%	CE%	Grade
	Spec	0.200	0.450	1.550	0.045	0.045	0.080	0.470	E 350 A
ISA 200X200X16	S_20260422/1	0.190	0.252	1.376	0.034	0.023	0.037	0.430	E 350 A
		0.177	0.257	1.363	0.031	0.021	0.036	0.420	E 350 A
ISA 200X200X20	S_20260422/3	0.189	0.284	1.363	0.033	0.024	0.039	0.440	E 350 A
		0.179	0.292	1.336	0.029	0.023	0.039	0.430	E 350 A

Mechanical Properties

Section Name	Batch No	TS (mpa)	YS (nm2)	EL %	Impact (Joules)	Bend Test (2t)	Grade
	Spec	490.00	350.00	22.00		Found Ok	E 350 A
ISA 200X200X16	S_20260422/1	570.00	412.00	27.00	0.00	Found Ok	E 350 A
		566.00	404.00	28.00	0.00	Found Ok	E 350 A
ISA 200X200X20	S_20260422/3	562.00	401.00	24.50	0.00	Found Ok	E 350 A
		579.00	406.00	24.00	0.00	Found Ok	E 350 A

Remarks :

For Thalaivar Steels Limited

Prepared by

QC In-Charge