

# Universal transceiver control interface – TCI

Version 1.0

## Introduction

This document describes TCI interface, what can you do with it and how can you do that. This document may be of interest to programmers, who will implement this interface in their software and devices.

TCI – Transceiver Control Interface is the network interface for control, data transfer and synchronization between a transceiver/receiver, logger, digital software, skimmer, other software and external power amplifier, band filters, antenna switch, radio station controller and other devices.

TCI was created as an advanced alternative to old-fashioned COM-port interface and audio cables. It utilizes full duplex web-socket protocol, which works above TCP connection providing data exchange between server and client, and cross-platform capabilities. Transceiver works as a server, all other software and devices as clients. Server and clients may work inside the same PC (SDR-software-server, logger etc. – clients) and/or in separate physical devices, connected via local network (classical transceiver, power amplifier, antenna switch, BPF-filters etc.).

TCI interface has main commands to control a transceiver (CAT-system analogue), receives CW macroses from clients and transmits them on the air, passes transceiver's IQ stream to clients, receives spots from skimmers and Internet clusters, receives/transmits audio signal for digital mode operation\*.

\* Will be added in the new TCI release.

TCI uses an extensible architecture; thus, it can be enriched with new functionality, preserving efficiency of old functions. You can add a certain functionality to the TCI interface, which corresponds to specific needs of any software developer or hardware manufacturer (of receivers, transceivers, power amplifiers, antenna switches etc.). TCI has a server/client identifier; thus, clients can detect an assigned name for a transceiver/receiver (server), this function will help other manufacturers to preserve names of their devices in implemented TCI.

We created TCI interface to unify data exchange between different devices and various software. Modern transceivers and software should be connected via the unified interface – TCI.

## **MIT license to use demo-software of the TCI client**

Copyright (c) 2017 Expert Electronics, Taganrog

Permission is hereby granted, free of charge, to any person obtaining a copy of this software (the "Software"), to deal in the Software without restriction, including without limitation the rights to use, copy, modify, merge, publish, distribute, sublicense, and/or sell copies of the Software, and to permit persons to whom the Software is furnished to do so, subject to the following conditions:

The above copyright notice and this permission notice shall be included in all copies or substantial portions of the Software.

THE SOFTWARE IS PROVIDED "AS IS", WITHOUT WARRANTY OF ANY KIND, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO THE WARRANTIES OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE AND NONINFRINGEMENT. IN NO EVENT SHALL THE AUTHORS OR COPYRIGHT HOLDERS BE LIABLE FOR ANY CLAIM, DAMAGES OR OTHER LIABILITY, WHETHER IN AN ACTION OF CONTRACT, TORT OR OTHERWISE, ARISING FROM, OUT OF OR IN CONNECTION WITH THE SOFTWARE OR THE USE OR OTHER DEALINGS IN THE SOFTWARE.

## **License to use TCI interface**

Copyright (c) 2017 Expert Electronics, Taganrog

Permission is hereby granted, free of charge, to any person using TCI interface (the "Interface") and associated documentation files, to deal in the Interface without restriction, including without limitation the rights to use, copy, modify, merge, publish, distribute, sublicense, and/or sell copies of software with Interface, and to permit persons to whom the software with Interface is furnished to do so.

THIS INTERFACE IS PROVIDED "AS IS", WITHOUT WARRANTY OF ANY KIND, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO THE WARRANTIES OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE AND NONINFRINGEMENT. IN NO EVENT SHALL THE AUTHORS OR COPYRIGHT HOLDERS BE LIABLE FOR ANY CLAIM, DAMAGES OR OTHER LIABILITY, WHETHER IN AN ACTION OF CONTRACT, TORT OR OTHERWISE, ARISING FROM, OUT OF OR IN CONNECTION WITH THE INTERFACE OR THE USE OR OTHER DEALINGS IN THE INTERFACE.

## Description

Any command is the ASCII line, which contains name of the command and list of arguments corresponding to this command. There are some reserved characters, which cannot be part of the command name and its arguments.

List of reserved characters: «>», «,>», «>».

Command structure:

1. Name of the command;
2. Separating character between command name and arguments «>»;
3. Separating character between arguments «,>»;
4. End of the command character «>».

If there are no arguments in the command, then after the name of the command should go end of the command character «>». If the command is incorrect, it is ignored. Letter case (capitalization) is irrelevant.

ExpertSDR2 software works as a server, which can have several clients connected simultaneously, they will be synced between each other via server. When client is connected to the ExpertSDR2, it receives ExpertSDR2 status: firstly, it receives *Read only* commands, then different parameters like frequency, modulations, etc.

When any parameter is changed in the ExpertSDR2 (server), it informs each connected client, so clients do not have to send continuous requests to a server, any change will be reported to every client. If a client will change its state, server will set it for itself and send it to every other client, so server works as a synchronizer. All clients connected to a server will be automatically synced. This way of operation allows to minimize network load, by lessening the traffic.

TCI protocol offers CW operation with line commands.

There are two types of commands:

1. Macros;
2. Message.

Macros – this is a list of characters, which has no rules, but abides to “change of speed” and “abbreviation transfer” commands.

Message – special command, which consists of three parts:

1. Text before callsign;
2. Callsign;
3. Text after callsign.

When transmitting the message, you can transmit the rest of your callsign after transmitting the message with only part of callsign, also you can change transmitting speed in the middle of the message and use abbreviations.

If you need to insert some abbreviation inside the text, it will look like:

ANY TEXT |SK| OTHER TEXT

All characters, which are put between vertical brackets, will be transmitted together.

If you need to decrease transmitting speed, use this character «<», to increase speed use «>». Speed change step 5 wpm, e.g.

ANY TEXT>TEXT+5WPM<TEXT-5WPM>>>TEXT+15WPM

Text commands may contain reserved characters, that is why they should be replaced with the other characters, which will be converted back on the server end:

1. Character «:» should be replaced with «^»;
2. Character «,» should be replaced with «~»;
3. Character «;» should be replaced with «\*».

Command to send macros looks like:

`cw_macros:arg1,arg2;`

`arg1` – periodic number of the software transceiver;

`arg2` – text to be sent before the callsign;

To send this line «+5wpmTU -5wpmRA6LH +10wpm599 004 SK» the command will be:

`cw_macros:0,>TU <RA6LH >>599 004 |SK/;`

Command to send CW message with opportunity to send callsign twice or to enter full callsign in the middle of transmission:

`cw_msg:arg1,arg2,arg3,arg4;`

`arg1` - periodic number of the software transceiver;

`arg2` - text before callsign;

`arg3` - callsign;

`arg4` - text after callsign;

Example:

To transmit «TU RA6LH 599 004» command will be:

`cw_msg:0,TU,RA6LH,599 004;`

If you need to repeat the callsign «TU RA6LH RA6LH 599 004», command will be:

`cw_msg:0,TU,RA6LH$2,599 004;`

If there is no text before callsign «RA6LH RA6LH 599 004», instead of text use special character “\_”:

`cw_msg:0,_,RA6LH$2,599 004;`

If while sending the message you don't know full callsign and you'll need to add it (send it again), probably not once, command will be: `cw_msg:arg1;`

Example:

`cw_msg:0,_,RA6$2,599 004;`

`cw_msg:RA6L;`

`cw_msg:RA6LH;`

If callsign “addition” was late, it came through after callsign transmission was finished, then this command is ignored.

Also, TCI supports order of transmitted CW messages, if you’ll enter several `cw_msg` commands one-by-one, they will be transmitted one-by-one, in this case callsign addition will be applied to currently sent callsign.

Commands is divided on three types:

- Read only;
- Read/Write;
- Write only.

List of commands:

<b>VFO_LIMITS</b>	Receiver’s frequency tuning limits	
Set		Arguments:  <i>arg1</i> — bottom frequency limit, Hz.  <i>arg2</i> — top frequency limit, Hz.
Read	<i>To be sent after connection;</i>	
Answer	<i>VFO_LIMITS:arg1,arg2;</i>	
Type	<i>Read only</i>	
Example	<i>VFO_LIMITS:10000,30000000;</i>	

<b>IF_LIMITS</b>	IF filter frequency limits (in ESDR2 only for VFOA)	
Set		Arguments:  <i>arg1</i> — bottom frequency limit, Hz.  <i>arg2</i> — top frequency limit, Hz.
Read	<i>To be sent after connection;</i>	
Answer	<i>IF_LIMITS:arg1,arg2;</i>	
Type	<i>Read only</i>	
Example	<i>IF_LIMITS:-48000,48000;</i> <i>IF_LIMITS:-96000,96000;</i>	

<b>TRX_COUNT</b>	Number of receivers (transceivers) in the radio	
Set		Arguments:  <i>arg1</i> — number of receivers/transceivers (physical or software).
Read	<i>To be sent after connection;</i>	
Answer	<i>TRX_COUNT:arg1;</i>	
Type	<i>Read only</i>	
Example	<i>TRX_COUNT:2;</i> <i>TRX_COUNT:8;</i>	

<b>CHANNEL_COUNT</b>	Number of additional receiver channels (slices) in one receiver (A/B/C)	
Set		Arguments:  <i>arg1</i> — number of receiver channels (slices).
Read	<i>To be sent after connection;</i>	
Answer	<i>CHANNEL_COUNT:arg1;</i>	
Type	<i>Read only</i>	
Example	<i>CHANNEL_COUNT:2;</i> <i>CHANNEL_COUNT:3;</i>	

<b>DEVICE</b>	Name of the device	
Set		Arguments:  <i>arg1</i> — name of the device.
Read	<i>To be sent after connection;</i>	
Answer	<i>DEVICE:arg1;</i>	
Type	<i>Read only</i>	
Example	<i>DEVICE:SunSDR2;</i> <i>DEVICE:ColibriDDC;</i>	

<b>RECEIVE_ONLY</b>	Determine device as a receiver or transceiver	
Set		Arguments:  <i>arg1</i> — number of receive channels.
Read	<i>To be sent after connection;</i>	
Answer	<i>RECEIVE_ONLY:arg1;</i>	
Type	<i>Read only</i>	
Example	<i>RECEIVE_ONLY:true;</i> <i>RECEIVE_ONLY:false;</i>	

<b>MODULATIONS_LIST</b>	List of supported mode types	
Set		Arguments:  Mode type to be sent as a name.
Read	<i>To be sent after connection;</i>	
Answer	<i>MODULATIONS_LIST:arg1, arg2, ... ,argN;</i>	
Type	<i>Read only</i>	
Example	<i>MODULATIONS_LIST:AM,LSB,USB,FM;</i> <i>RECEIVE_ONLY:AM,SAM,LSB,USB,CW,NFM,WFM;</i>	

<b>TX_ENABLE</b>	Permission to use transmitter	
Set		Arguments:  <i>arg1</i> — periodic number of receiver/transmitter.  <i>arg2</i> — transmission permitted (true)/transmission prohibited (false).
Read	<i>To be sent while operating device</i>	
Answer	<i>TX_ENABLE:arg1, arg2;</i>	
Type	<i>Read only</i>	
Example	<i>TX_ENABLE:0,true;</i>	

<b>READY</b>	To be sent after initialization commands while connecting	
Set		
Read	<i>To be sent after connection;</i>	
Answer	<i>READY;</i>	
Type	<i>Read only</i>	
Example		

<b>TX_FOOTSWITCH</b>	PTT footswitch signal	
Set	<i>TX_FOOTCWATCH:arg1,arg2;</i>	Arguments:  <i>arg1</i> — periodic number of receiver.  <i>arg2</i> — footswitch state (pressed (true), not pressed (false))
Type	<i>Read only</i>	
Example	<i>TX_FOOTCWATCH:0,true;</i> <i>TX_FOOTCWATCH:0,false;</i>	

<b>START</b>	Start ExpertSDR2	
Set	<i>START;</i>	Arguments:
Type	<i>Read / Write</i>	
Example	<i>START;</i>	

<b>STOP</b>	Stop ExpertSDR2	
Set	<i>STOP;</i>	Arguments:
Type	<i>Read / Write</i>	
Example	<i>STOP;</i>	

<b>DDS</b>	Tuning of the RX's center frequency (center of the panorama)	
Set	<i>DDS:arg1,arg2;</i>	Arguments:  <i>arg1</i> — receiver's periodic number.  <i>arg2, arg5</i> — tuning frequency, Hz.
Read	<i>DDS:arg1;</i>	
Answer	<i>DDS:arg1,arg2;</i>	
Type	<i>Read / Write</i>	
Example	<i>DDS:0,7200050;</i> <i>DDS:1;</i>	

<b>IF</b>	IF filter tuning in panorama bandwidth	
Set	<i>IF:arg1,arg2,arg3;</i>	Arguments:  <i>arg1</i> — receiver's periodic number.  <i>arg2</i> — channel's periodic number (A / B).  <i>Arg3</i> — new tuned frequency in respect to DDS (center of the panorama), Hz.
Read	<i>IF:arg1,arg2;</i>	
Answer	<i>IF:arg1,arg2,arg3;</i>	
Type	<i>Read / Write</i>	
Example	<i>IF:0,0,-12000;</i> <i>IF:0,0,23000;</i> <i>IF:1,0;</i>	

<b>RIT_ENABLE</b>	Enable RIT	
Set	<a href="#">RIT_ENABLE:arg1,arg2;</a>	Arguments:  <i>arg1</i> — receiver's periodic number.  <i>arg2</i> — enable indicator.
Read	<a href="#">RIT_ENABLE:arg1;</a>	
Answer	<a href="#">RIT_ENABLE:arg1,arg2;</a>	
Type	<a href="#">Read / Write</a>	
Example	<a href="#">RIT_ENABLE:0,true;</a>  <a href="#">RIT_ENABLE:0,false;</a>  <a href="#">RIT_ENABLE:1;</a>	

<b>MODULATION</b>	Set mode type	
Set	<a href="#">MODULATION:arg1,arg2;</a>	Arguments:  <i>arg1</i> — receiver's periodic number.  <i>arg2</i> — mode type (line).  List of supported mode types:  <a href="#">AM / SAM / DSB / LSB / USB / CW / NFM / WFM / SPEC / DIGL / DIGU / DRM</a>
Read	<a href="#">MODULATION:arg1;</a>	
Answer	<a href="#">MODULATION:arg1,arg2;</a>	
Type	<a href="#">Read / Write</a>	
Example	<a href="#">MODULATION:0,LSB;</a>  <a href="#">MODULATION:0,CW;</a>  <a href="#">MODULATION:1;</a>	

After switching the frequency band, the ExpertSDR2 restores saved settings for the newly selected band, which includes mode and RX filter bandwidth etc. That is why when you change the band, it's required to wait until you (client software) receive **MODULATION** and **RX\_FILTER\_BAND** commands from ExpertSDR2, in case they were changed, if your client software hadn't received these commands while the protection interval 200 ms then send **MODULATION** and **RX\_FILTER\_BAND** commands.

If mode and RX filter bandwidth haven't changed in the ExpertSDR2, it will not send **MODULATION** and **RX\_FILTER\_BAND** commands.

<b>RX_ENABLE</b>	Enable software receivers	
Set	<a href="#">RX_ENABLE:arg1,arg2;</a>	Arguments:  <i>arg1</i> — receiver's periodic number.  <i>arg2</i> — enable indicator.
Read	<a href="#">RX_ENABLE:arg1;</a>	
Answer	<a href="#">RX_ENABLE:arg1,arg2;</a>	
Type	<a href="#">Read / Write</a>	
Example	<a href="#">RX_ENABLE:1,true;</a>  <a href="#">RX_ENABLE:2,false;</a>  <a href="#">RX_ENABLE:1;</a>	



<b>XIT_ENABLE</b>	Enable XIT	
Set	<i>XIT_ENABLE:arg1,arg2;</i>	Arguments:  <i>arg1</i> — receiver's periodic number.  <i>arg2</i> — enable indicator.
Read	<i>XIT_ENABLE:arg1;</i>	
Answer	<i>XIT_ENABLE:arg1,arg2;</i>	
Type	<i>Read / Write</i>	
Example	<i>XIT_ENABLE:0,true;</i>  <i>XIT_ENABLE:0,false;</i>  <i>XIT_ENABLE:1;</i>	

<b>SPLIT_ENABLE</b>	Enable SPLIT mode	
Set	<i>SPLIT_ENABLE:arg1,arg2;</i>	Arguments:  <i>arg1</i> — receiver's periodic number.  <i>arg2</i> — enable indicator.
Read	<i>SPLIT_ENABLE:arg1;</i>	
Answer	<i>SPLIT_ENABLE:arg1,arg2;</i>	
Type	<i>Read / Write</i>	
Example	<i>SPLIT_ENABLE:0,true;</i>  <i>SPLIT_ENABLE:0,false;</i>  <i>SPLIT_ENABLE:1;</i>	

<b>RIT_OFFSET</b>	Tune RIT offset	
Set	<i>RIT_OFFSET:arg1,arg2;</i>	Arguments:  <i>arg1</i> — receiver's periodic number.  <i>arg2</i> — offset frequency, Hz.
Read	<i>RIT_OFFSET:arg1;</i>	
Answer	<i>RIT_OFFSET:arg1,arg2;</i>	
Type	<i>Read / Write</i>	
Example	<i>RIT_OFFSET:0,500;</i>  <i>RIT_OFFSET:0,-200;</i>  <i>RIT_OFFSET:1;</i>	

<b>XIT_OFFSET</b>	Tune XIT offset	
Set	<i>XIT_OFFSET:arg1,arg2;</i>	Arguments:  <i>arg1</i> — receiver's periodic number.  <i>arg2</i> — offset frequency, Hz.
Read	<i>XIT_OFFSET:arg1;</i>	
Answer	<i>XIT_OFFSET:arg1,arg2;</i>	
Type	<i>Read / Write</i>	
Example	<i>XIT_OFFSET:0,500;</i>  <i>XIT_OFFSET:0,-200;</i>  <i>XIT_OFFSET:1;</i>	

<b>RX_CHANNEL</b>	Enable additional receive channels	
Set	<code>RX_CHANNEL:arg1,arg2,arg3;</code>	Arguments:  <i>arg1</i> — receiver's periodic number.  <i>arg2</i> — channel's periodic number.  <i>arg3</i> — enable indicator.
Read	<code>RX_CHANNEL:arg1,arg2;</code>	
Answer	<code>RX_CHANNEL:arg1,arg2,arg3;</code>	
Type	<i>Read / Write</i>	
Example	<code>RX_CHANNEL:0,1,true;</code>  <code>RX_CHANNEL:0,1,false;</code>  <code>RX_CHANNEL:1, 1;</code>	

<b>RX_FILTER_BAND</b>	Adjust IF filter width	
Set	<code>RX_FILTER_BAND:arg1,arg2,arg3;</code>	Arguments:  <i>arg1</i> — receiver's periodic number.  <i>arg1</i> — bottom frequency limit, Hz.  <i>arg2</i> — top frequency limit, Hz.
Read	<code>RX_FILTER_BAND:arg1,arg2;</code>	
Answer	<code>RX_FILTER_BAND:arg1,arg2,arg3;</code>	
Type	<i>Read / Write</i>	
Example	<code>RX_FILTER_BAND:0,30,2700;</code>  <code>RX_FILTER_BAND:0,-2900,-70;</code>  <code>RX_FILTER_BAND:1;</code>	

After switching the frequency band, the ExpertSDR2 restores saved settings for the newly selected band, which includes mode and RX filter bandwidth etc. That is why when you change the band, it's required to wait until you (client software) receive **MODULATION** and **RX\_FILTER\_BAND** commands from ExpertSDR2, in case they were changed, if your client software hadn't received these commands while the protection interval 200 ms then send **MODULATION** and **RX\_FILTER\_BAND** commands.

If mode and RX filter bandwidth haven't changed in the ExpertSDR2, it will not send **MODULATION** and **RX\_FILTER\_BAND** commands.

<b>RX_SMETER</b>	Signal level (S-Meter) in filter bandwidth	
Set	<code>RX_SMETER:arg1,arg2,arg3;</code>	Arguments:  <i>arg1</i> — receiver's periodic number.  <i>arg2</i> — channel's periodic number.  <i>arg3</i> — signal level.
Read	<code>RX_SMETER:arg1,arg2;</code>	
Answer	<code>RX_SMETER:arg1,arg2,arg3;</code>	
Type	<i>Read / Write</i>	
Example	<code>RX_SMETER:0,0,-72;</code>  <code>RX_SMETER:0,1,-63;</code>  <code>RX_SMETER:1,0;</code>	

<b>CW_MACROS_SPEED</b>	Set CW speed for macros	
Set	<i>CW_MACROS_SPEED:arg1;</i>	Arguments:  <i>arg1</i> — CW speed, WPM.
Read	<i>CW_MACROS_SPEED;</i>	
Answer	<i>CW_MACROS_SPEED:arg1;</i>	
Type	<i>Read / Write</i>	
Example	<i>CW_MACROS_SPEED:30;</i>  <i>CW_MACROS_SPEED:42;</i>  <i>CW_MACROS_SPEED;</i>	

<b>CW_MACROS_DELAY</b>	Set delay between “turn to TX” and “start of macros transmission”	
Set	<i>CW_MACROS_DELAY:arg1;</i>	Arguments:  <i>arg1</i> — delay before start of transmission, ms.
Read	<i>CW_MACROS_DELAY;</i>	
Answer	<i>CW_MACROS_DELAY:arg1;</i>	
Type	<i>Read / Write</i>	
Example	<i>CW_MACROS_DELAY:100;</i>  <i>CW_MACROS_DELAY:150;</i>  <i>CW_MACROS_DELAY;</i>	

<b>TRX</b>	Switch between RX/TX modes	
Set	<i>TRX:arg1,arg2, arg3;</i>	Arguments:  <i>arg1</i> — receiver’s periodic number.  <i>arg2</i> — enable indicator.  <i>arg3</i> — source of the signal (unnecessary) (mic – mic signal, vac – signal from VAC)
Read	<i>TRX:arg1;</i>	
Answer	<i>TRX:arg1,arg2;</i>	
Type	<i>Read / Write</i>	
Example	<i>TRX:0,true;</i>  <i>TRX:0,true,mic;</i>  <i>TRX:0,true,vac;</i>  <i>TRX:0,false;</i>  <i>TRX:1;</i>	

For common use, the TRX command might have two arguments, in this case server will automatically determine the source of the input signal for transmission. When you select DIGL/DIGU modes the transceiver will automatically enable VAC and use the signal from it. In all other cases will be used signal from the mic. If you need to manually determine the source of the signal, you should use the third argument: mic – mic signal, vac – signal from VAC.

<b>IQ_START</b>	Start IQ signal output	
Set	<i>IQ_START:arg1;</i>	Arguments:  <i>arg1</i> — receiver’s periodic number.
Type	<i>Read / Write</i>	
Example	<i>IQ_START:0;</i>	

<b>IQ_STOP</b>	Stop IQ signal output	
Set	<i>IQ_STOP:arg1;</i>	Arguments:  <i>arg1</i> — receiver's periodic number.
Type	<i>Read / Write</i>	
Example	<i>IQ_STOP:0;</i>	

<b>IQ_SAMPLERATE</b>	Set IQ signal sample rate	
Set	<i>IQ_SAMPLERATE:arg1;</i>	Arguments:  <i>arg1</i> — sample rate, Hz.
Read		
Answer		
Type	<i>Read / Write</i>	Supported sample rates:  <b>48 / 96 / 192</b> kHz
Example	<i>IQ_SAMPLERATE:48000;</i>	
	<i>IQ_SAMPLERATE:96000;</i>	
	<i>IQ_SAMPLERATE:192000;</i>	

SPOT	Send spot to ExpertSDR2 to display	
Set	<i>SPOT:arg1,arg2,arg3,arg4;arg5</i>	Arguments:  <i>arg1</i> — callsign.  <i>Arg2</i> — mode.  <i>Arg3</i> — frequency, Hz.  <i>Arg4</i> — color ARGB.  <i>Arg5</i> — additional text.
Read		
Answer		
Type	<i>Write only</i>	
Example	<i>SPOT:RN6LHF,CW,7100000,16711680,ANY_TEXT;</i>	
Color is coded with 32-bit characterless number <i>0x00FF0000</i> -> <i>16711680</i>		

<b>SPOT_DELETE</b>	Delete spot	
Set	<i>SPOT:arg1;</i>	Arguments:  <i>arg1</i> — callsign.
Read		
Answer		
Type	<i>Write only</i>	
Example	<i>SPOT_DELETE:IT8TY;</i>	

Reception of IQ signal happens via binary websocket connection, packet structure looks like this:

```
typedef struct
{
    quint32 receiver;    //!< receiver's periodic number
    quint32 sampleRate; //!< sample rate
    quint32 format;      //!< always equals 4 (float 32 bit)
    quint32 codec;       //!< compression algorithm (not implemented yet), always 0
    quint32 crc;         //!< check sum (not implemented yet), always 0
    quint32 length;      //!< length of data field
    quint32 type;        //!< type of data stream
    quint32 reserv[9];   //!< reserved
    float  data[4096];   //!< data field
}DataStream;
```

Type of data stream is determined with the following numeration:

```
typedef enum
{
    IqStream = 0,    //!< Receiver's IQ signal stream
    RxAudioStream,   //!< Receiver's audio stream (not implemented yet)
    TxAudioStream,   //!< Transceiver's audio stream (not implemented yet)
    TxChrono,        //!< Stream of temporary markers to transmit audio signal (not implemented yet)
}StreamType;
```

### List of software with TCI support:

[- SDC](#)

[- LogHX](#)

### Conclusion

TCI interface will gradually develop, in time it will be added with new commands and functionality. Follow the updates of TCI interface.