



MGM's College Of Engineering, Nanded

Department of IT

Semister I Academic Year 2024-25

Report of Cleanliness in Fire Estingusher

Fire Extinguisher Type	Inspection Status	Maintenance Actions	Responsible Personnel
ABC Powder Extinguisher	Compliant	None required	Jane Smith
CO2 Extinguisher	Non-Compliant	Refill pressure, replace seal	Mark Lee
Water Extinguisher	Compliant	None required	Sarah Kim
Foam Extinguisher	Needs Maintenance	Clean exterior, check pressure, refill	Michael Brown
ABC Powder Extinguisher	Compliant	None required	John Doe

Head of Dept.