

OFFICE OF THE DISTRICT FIRE OFFICER,
HUBLICITY FIRE STATION HUBLI 580024

C.N.11/ADV/CC/DFO/HUBLI CITY/2022

Date: 13/10/2022

To,

President

Rastra santa Gunadharanandhi Maharaj
Residential Primary & Higher Primary School
Varur Village,
Hubballi Taluk, Dharwad District, 581207

Sir,

Sub : Issue of 'Fire Safety recommendation/Advice' to Rastra santa Gunadharandhi Maharaj residential Primary & Higher Primary School Varur Village, Hubballi Taluk Dharwad District -581207"

Ref :1) Applicant request letter dated 12/10/2022

><<<*<*<<<

With reference to the subject above cited, the premises of Rastra santa Gunadharandhi Maharaj Residential Primary & Higher Primary School Varur Village Hubballi Taluk Dharwad District" was inspected by the me on 12/10/2022 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

ANNEXURE-1

(Up to 14.99 mtrs in height)

Group B Education Building

NBC-2016, part-4, table 7 (11) 3.1.3 Group B Educational Building Sub division B 1. & B2.
(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory)

A. Details of the building / premises :-

01	Name and Address of the Applicant.	:	President Rastra santa Gunadharanandhi Maharaj Residential Primary & Higher Primary School. Varur Village, Hubballi Taluk, Dharwad District, 581207
02	Name and Address of the premises.	:	Rastra santa Gunadharanandhi Maharaj Residential Primary & Higher Primary School. Varur Village, Hubballi Taluk, Dharwad District, 581207

			<p>generator.</p> <p>C. One CO₂ type fire extinguisher, of 4.5 kgs capacity should be provided near each electrical panel board & electrical room.</p> <p>D. One ABC type fire extinguisher of 06 kgs capacity should be available within 15 mtrs. radius</p>
08.	Public address system	-----	<p>Not required as the risk is low.</p> <p>Recommended to provided electric siren.</p>
09.	First aid Hose reel hose.	-----	<p>One Hose Reel Hose near the staircase (One hose reel hose system for every 1000 sq. mtrs) The hose reel hose of min 19 mm size and of 30.00 mtrs length shall be provided to reach the farthest point of each floor and shut off branch having a nozzle of 5mm size. The hose reel hose should be connected at each landing of each building/block/wing/tower.</p>
10.	Automatic sprinkler system.	-----	<p>Not required as there is no basement</p>
11.	Terrace tank over respective tower terrace.	-----	<p>Terrace tank required 5,000 ltrs. Capacity (the water tank should be kept exclusively fire fight purpose)</p>
12.	Pump at the terrace tank level with minimum pressure of 3.5 kg/cm ² . ----	-----	<p>Recommended to provide booster pump of 450 lpm capacity.</p>
13.	Fire control room at ground floor.	-----	<p>Not required as the risk is</p>

18. Fire Siren	<div style="text-align: right;">District Fire Karnataka State Fire & Emergency Fire Station, Hubli</div> <p>A Fire siren is installed in the Premises to inform the inmates in case of a fire emergency and evacuate the area</p>
19.	<p>Fire precautionary measures:-</p> <ul style="list-style-type: none"> A. Explosive and Flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises. B. Accumulation of combustible waste in and around the premises should be avoided. C. The exit ways shall be always kept clear without any obstruction. D. Liquefied petroleum gas should not be stored in the building. E. The doors shall not be kept locked/latched during working hours and shall be free from obstruction. F. During the class hours the class room doors shall not be locked from inside to out side. <p>As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency And the school shall observe the Fire Safety DAY ON April 14th of every year by conducting Fire Safty drills with Co-ordinate with fire service department.</p>

The Karnataka Fire & Emergency Service Department is issued the Fire Safety recommendation in compliance to the undersigned, within 90 days.

- * All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.4 of Fire and Life safety will have to be complied with mandatorily.

From the above details it is clear that the applicant of the above Educational building have been recommended to provide fire precautionary measures as per *National Building Code 2016, part-4, Table 7 (11) 3.13 Group B Educational Buiding Sub division B1 & B2*. After full-filling the above recommendations, a Certificate should be obtained by this office. *if any time any of the conditions are found not complied with, this Certificate shall stand withdrawn/cancelled.*

Hence, on the report submitted by the me this recommendation Certificate is issued low rise School Building Rastra santa Gunadharanandhi Maharaj Residential Primary & Higher Primary School, Varur Village, Hubballi Taluk, Dharwad District, 581207.

This certificate is valid for a period of one year from the date of issue of this letter and is renewable.

Yours faithfully



District Fire Officer,
Karnataka State Fire & Emergency Service
Fire Station, Hubli City
HUBLI-580 024



ಚಲನ್ ಚಾಲ್ತಿ ಅವಧಿ Challan Validity	ಜಿಲ್ಲೆ District	ಇಲಾಖೆ Department	ದಿವಿಷನ್ ಕಛೇರಿ DDO Office	
7 Days	DHARWAD	DEPARTMENT OF KARNATAKA FIRE & EMERGENCY SERVICES	DIVISIONAL FIRE OFFICE, KARNATAKA FIRE EMERGENCY SERVICES, HUBLI ZONE, HUBLI	
ವರ್ಗ Category	ದಿನಾಂಕ Date	ಚಲನ್ ಉಲ್ಲೇಖ ಸಂಖ್ಯೆ Challan Reference Number	ದಿವಿಷನ್ ಕೋಡ್ DDO Code	
Government	13/10/2022	CR1022007000264218	140310	
ಸಂಗ್ರಾಹಕರ ಹೆಸರು Remitter Name	SWASTISHREE DHARMASEN BHATTARAKMAHASWAMIJI		ಮೊಬೈಲ್ ಸಂಖ್ಯೆ Mobile Number	8660552284
ವಿಳಾಸ Address	NAVAGRAHATEERTHA KSHETRA VARUR HUBLI TALUK DHRWAD			
ಉದ್ದೇಶ Purpose	ಲೆಕ್ಕ ಶೀರ್ಷಿಕೆ Head of Account	ಉಪ ಉದ್ದೇಶದ ಹೆಸರು Sub Purpose Name	ಉದ್ದೇಶ ನಿರ್ದಿಷ್ಟ ಐಡಿ Purpose Specific ID	ಮೊತ್ತ Amount
OTHER ITEMS- FIRE DEPARTMENT	0070~60~109~0~02~000	12.FOR ISSUE OF ADVISE ON FIRE PREVENTION AND FIRE FIGHTING FOR NON HIGH RISE BUILDINGS.	NA-	5000
ಸಂದಾಯದ ಬ್ಯಾಂಕ್ Remittance Bank	STATE BANK OF INDIA	ಒಟ್ಟು ಮೊತ್ತ Grand Total	5000	
ಪಾವತಿ ಹಂತ Payment Status	Payment Yet To Be Made At Agency Bank	ಒಟ್ಟು ಮೊತ್ತ ಅಕ್ಷರಗಳಲ್ಲಿ Total Amount in Words	Five Thousand Only	
ಪಾವತಿ ವಿವರಗಳು / Payment Details				
ಪಾವತಿ ವಿಧ Payment Mode	Cash			

5000 x 10

Denomination

① 500 x 10 = 5000/-

STATE BANK OF INDIA
VIDYANAGAR BR - HUBLI (00297)
TRANSFER / CLEARED / CASH
13 OCT 2022
CHECKER
V. N. JOSHI