Master Infrastructure 24-Hour Operations Report

Report Period: Past 24 Hours | Date: 30 September 2026 | Generated: 09:44:29 IST

6	5	1206080.0 kWh	570.2 kW	0
MASTER DEVICES	ACTIVE SYSTEMS	24H DG ENERGY	LIVE LT LOAD	ACTIVE SYSTEM ALERTS

⚡ 1. Diesel Generator (DG Sets) Operations & 24h Summary

3/3 DG Sets Active | 3 Running

DG Unit	Status	Power & 24h Energy	Fuel Level & Battery	Engine Health	Last Sync
DG SET1 ACTIVE	RUNNING	⚡ **Live Power:** 565.799 kW (24h Max: 0 kW) **Cumulative Energy:** 494350 kWh **Run Hours:** 126.13 hrs | **Starts:** 321	**Fuel Level:** 100% **24h Avg Fuel:** 100.0% (Min: N/A%) **Battery Voltage:** 27.4 V	**Coolant Temp:** 76 °C ⚙ **Oil Pressure:** 508 bar	2026-09-30 09:44:18
DG Set 2 ACTIVE	RUNNING	⚡ **Live Power:** 0 kW (24h Max: 0 kW) **Cumulative Energy:** 472480 kWh **Run Hours:** 108.69 hrs | **Starts:** 284	**Fuel Level:** 100% **24h Avg Fuel:** 100.0% (Min: N/A%) **Battery Voltage:** 26.7 V	**Coolant Temp:** Sensor Fault / Offline ⚙ **Oil Pressure:** Sensor Fault / Offline	2026-09-30 09:44:18
DG Set 3 ACTIVE	RUNNING	⚡ **Live Power:** 569.906 kW (24h Max: 0 kW) **Cumulative Energy:** 239250 kWh **Run Hours:** 97.71 hrs | **Starts:** 231	**Fuel Level:** 90% **24h Avg Fuel:** 93.8% (Min: N/A%) **Battery Voltage:** 27.7 V	**Coolant Temp:** 75 °C ⚙ **Oil Pressure:** 392 bar	2026-09-30 09:44:28

2. Low Voltage (LT) Panels Electrical & 24h Load Distribution

3/7 Circuits Energized | Total Load: 570.2 kW

Sub-Panel	State	Live Load (kW)	Voltage (V)	Current (A)	Freq (Hz)	24h Aggregation Metrics
EVM Charger	STANDBY	**N/A kW**	N/A V	N/A A	N/A Hz	**24h Avg Power:** 0.0 kW ⚡ **24h Max Power:** N/A kW (Max V: N/A V)
Electrical Room 1	LIVE ENERGIZED	**570.2405 kW**	416.9198 V	803.3548 A	49.9705 Hz	**24h Avg Power:** 48.5 kW ⚡ **24h Max Power:** 591.5 kW (Max V: 419.2 V)
UPS Room 1	STANDBY	**0.0 kW**	0.0 V	0.0 A	21.9054 Hz	**24h Avg Power:** 35.9 kW ⚡ **24h Max Power:** 605.0 kW (Max V: 424.8 V)
Transformer 1	LIVE ENERGIZED	**0.0 kW**	410.7107 V	0.0 A	50.0355 Hz	**24h Avg Power:** 343.7 kW ⚡ **24h Max Power:** 603.6 kW (Max V: 439.0 V)
Transformer 2	LIVE ENERGIZED	**0.0 kW**	410.1139 V	0.0 A	50.0446 Hz	**24h Avg Power:** 314.7 kW ⚡ **24h Max Power:** 569.3 kW (Max V: 437.8 V)
Transformer 3	STANDBY	**0.0 kW**	0.0 V	0.0 A	0.0 Hz	**24h Avg Power:** 0.0 kW ⚡ **24h Max Power:** 0.0 kW (Max V: 0.0 V)
Fire Fighting Wall	STANDBY	**N/A kW**	N/A V	N/A A	N/A Hz	**24h Avg Power:** 0.0 kW ⚡ **24h Max Power:** N/A kW (Max V: N/A V)

3. Fire Suppression System & 24h Safety Status

Relay: ONLINE | Cylinders: 3/3 OK

Separation Zone	Cylinder Gas Pressure	Digital Input Loop	Sensor Type	Operational Status

Fire Separation Zone 1	PRESSURE NORMAL	CLOSED / NORMAL	Gas Pressure Sensor & Alarm Loop	Operational (24h Monitored)
Fire Separation Zone 2	PRESSURE NORMAL	CLOSED / NORMAL	Gas Pressure Sensor & Alarm Loop	Operational (24h Monitored)
Fire Separation Zone 3	PRESSURE NORMAL	CLOSED / NORMAL	Gas Pressure Sensor & Alarm Loop	Operational (24h Monitored)

4. RO Plant Water Treatment & 24h Quality Report

Status: FILTERING

Parameter	Live Telemetry Reading	24h Average Reading	24h Maximum Peak	Quality Compliance
TDS (Total Dissolved Solids)	**123 ppm**	109.0 ppm	123.0 ppm	Optimal (< 200 ppm)
Permeate Water Flow Rate	**0.0 L/min**	3.4 L/min	-	Normal Flow
RO Membrane Pressure	**5.0 psi**	-	-	Normal Pressure
pH Level	**7.4**	-	-	Balanced (6.5 - 8.5)