Daily 24-Hour Low Voltage (LT) Panels Electrical Report

Date: 30 September 2026 | Generated At: 09:58:46 IST | Status: MASTER ONLINE

7	2	1122.2 kW	50.0 Hz
SUB-PANELS MONITORED	CIRCUITS ENERGIZED	TOTAL LIVE POWER LOAD	GRID FREQUENCY

LT Sub-Panels Electrical 24h Aggregations

Sub-Panel Name	State	Live Power (kW)	Voltage (V)	Current (A)	Frequency	24h Aggregations
EVM Charger	STANDBY	N/A kW	N/A V	N/A A	N/A Hz	**24h Avg Power:** 0.0 kW ⚡ **24h Max Power:** N/A kW (Max V: N/A V)
Electrical Room 1	STANDBY	0.0 kW	0.0 V	0.0 A	23.891 Hz	**24h Avg Power:** 50.5 kW ⚡ **24h Max Power:** 591.5 kW (Max V: 419.2 V)
UPS Room 1	STANDBY	0.0 kW	0.0 V	0.0 A	21.9054 Hz	**24h Avg Power:** 35.9 kW ⚡ **24h Max Power:** 605.0 kW (Max V: 424.8 V)
Transformer 1	LIVE ENERGIZED	552.5668 kW	409.616 V	805.9973 A	50.0246 Hz	**24h Avg Power:** 345.9 kW ⚡ **24h Max Power:** 603.6 kW (Max V: 439.0 V)
Transformer 2	LIVE ENERGIZED	569.6614 kW	408.8033 V	822.1264 A	50.0345 Hz	**24h Avg Power:** 316.7

						kW ⚡ **24h Max Power:** 576.3 kW (Max V: 437.8 V)
Transformer 3	STANDBY	**0.0 kW**	0.0 V	0.0 A	0.0 Hz	**24h Avg Power:** 0.0 kW ⚡ **24h Max Power:** 0.0 kW (Max V: 0.0 V)
Fire Fighting Wall	STANDBY	**N/A kW**	N/A V	N/A A	N/A Hz	**24h Avg Power:** 0.0 kW ⚡ **24h Max Power:** N/A kW (Max V: N/A V)