Master Infrastructure 24-Hour Operations Report

Report Period: Past 24 Hours | Date: 22 October 2026 | Generated: 17:17:20 IST

7	6	150617.0 kWh	514.1 kW	0
MASTER DEVICES	ACTIVE SYSTEMS	24H DG ENERGY	LIVE LT LOAD	ACTIVE SYSTEM ALERTS

⚡ 1. Diesel Generator (DG Sets) Operations & 24h Summary

3/3 DG Sets Active | 3 Running

DG Unit	Status	Power & 24h Energy	Fuel Level & Battery	Engine Health	Last Sync
DG SET1 ACTIVE	OFF	⚡ **Live Power:** 0 kW (24h Max: 0 kW) 🔋 **Cumulative Energy:** 64190 kWh ⏱ **Run Hours:** 160.1 hrs | 🔄 **Starts:** 392	⛽ **Fuel Level:** 86.2% 📊 **24h Avg Fuel:** 98.2% (Min: N/A%) 🔋 **Battery Voltage:** 26.4 V	🌡 **Coolant Temp:** Sensor Fault / Offline ⚙ **Oil Pressure:** Sensor Fault / Offline	2026-10-22 17:17:14
DG Set 2 ACTIVE	OFF	⚡ **Live Power:** 0 kW (24h Max: 0 kW) 🔋 **Cumulative Energy:** 56061 kWh ⏱ **Run Hours:** 130.12 hrs | 🔄 **Starts:** 324	⛽ **Fuel Level:** 84.3% 📊 **24h Avg Fuel:** 97.9% (Min: N/A%) 🔋 **Battery Voltage:** 26.7 V	🌡 **Coolant Temp:** Sensor Fault / Offline ⚙ **Oil Pressure:** Sensor Fault / Offline	2026-10-22 17:17:14
DG Set 3 ACTIVE	OFF	⚡ **Live Power:** 0 kW (24h Max: 0 kW) 🔋 **Cumulative Energy:** 30366 kWh ⏱ **Run Hours:** 114.81 hrs | 🔄 **Starts:** 277	⛽ **Fuel Level:** 100% 📊 **24h Avg Fuel:** 100.0% (Min: N/A%) 🔋 **Battery Voltage:** 26.7 V	🌡 **Coolant Temp:** Sensor Fault / Offline ⚙ **Oil Pressure:** Sensor Fault / Offline	2026-10-22 17:17:14

🔌 2. Low Voltage (LT) Panels Electrical & 24h Load Distribution

4/7 Circuits Energized | Total Load: 514.1 kW

Sub-Panel	State	Live Load (kW)	Voltage (V)	Current (A)	Freq (Hz)	24h Aggregation Metrics
EVM Charger	LIVE ENERGIZED	0.0818 kW	427.6494 V	0.2012 A	50.0443 Hz	📊 **24h Avg Power:** 0.0 kW ⚡ **24h Max Power:** N/A kW (Max V: N/A V)
Electrical Room 1	LIVE ENERGIZED	211.9681 kW	428.0573 V	290.9711 A	50.0337 Hz	📊 **24h Avg Power:** 210.1 kW ⚡ **24h Max Power:** N/A kW (Max V: N/A V)
UPS Room 1	LIVE ENERGIZED	301.2565 kW	427.4865 V	436.8442 A	50.0442 Hz	📊 **24h Avg Power:** 281.1 kW ⚡ **24h Max Power:** N/A kW (Max V: N/A V)
Transformer 1	STANDBY	N/A kW	N/A V	N/A A	N/A Hz	📊 **24h Avg Power:** 0.0 kW ⚡ **24h Max Power:** N/A kW (Max V: N/A V)
						📊 **24h Avg Power:** 0.0 kW

Transformer 2	STANDBY	**N/A kW**	N/A V	N/A A	N/A Hz	⚡ **24h Max Power:** N/A kW (Max V: N/A V)
Transformer 3	STANDBY	**N/A kW**	N/A V	N/A A	N/A Hz	📊 **24h Avg Power:** 0.0 kW ⚡ **24h Max Power:** N/A kW (Max V: N/A V)
Fire Fighting Wall	LIVE ENERGIZED	**0.7511 kW**	429.5099 V	5.6246 A	50.0348 Hz	📊 **24h Avg Power:** 0.8 kW ⚡ **24h Max Power:** N/A kW (Max V: N/A V)

🧯 3A. Main Plant Fire Suppression & 24h Safety Status

Relay: ONLINE | Cylinders: 8/9 CHECK

Separation Zone	Cylinder Gas Pressure	Digital Input Loop	Sensor Type	Operational Status
Main Fire Suppression 1	PRESSURE NORMAL	CLOSED / NORMAL	Gas Pressure Sensor & Alarm Loop	**Operational (24h Monitored)**
Main Fire Suppression 2	PRESSURE NORMAL	CLOSED / NORMAL	Gas Pressure Sensor & Alarm Loop	**Operational (24h Monitored)**
Main Fire Suppression 3	PRESSURE NORMAL	CLOSED / NORMAL	Gas Pressure Sensor & Alarm Loop	**Operational (24h Monitored)**
Main Fire Suppression 4	PRESSURE NORMAL	CLOSED / NORMAL	Gas Pressure Sensor & Alarm Loop	**Operational (24h Monitored)**
Main Fire Suppression 5	PRESSURE NORMAL	CLOSED / NORMAL	Gas Pressure Sensor & Alarm Loop	**Operational (24h Monitored)**
Main Fire Suppression 6	PRESSURE NORMAL	CLOSED / NORMAL	Gas Pressure Sensor & Alarm Loop	**Operational (24h Monitored)**
Main Fire Suppression 7	PRESSURE NORMAL	CLOSED / NORMAL	Gas Pressure Sensor & Alarm Loop	**Operational (24h Monitored)**
Main Fire Suppression 8	PRESSURE NORMAL	CLOSED / NORMAL	Gas Pressure Sensor & Alarm Loop	**Operational (24h Monitored)**
Main Fire Suppression 9	PRESSURE LOW	CLOSED / NORMAL	Gas Pressure Sensor & Alarm Loop	**Operational (24h Monitored)**

🧯 3B. Fire Suppression UPS Room 2 — 10 Panel Zones

Status: STANDBY | Cylinders: 4/10 OK

Panel Zone	Location / Description	Cylinder Gas Pressure	Sensor Type	Operational Status
Fire Suppression 1	UPS Room 2 — Gas Cylinder 1	LOW PRESSURE	Pressure Switch Sensor	**Attention Required**
Fire Suppression 2	UPS Room 2 — Gas Cylinder 2	LOW PRESSURE	Pressure Switch Sensor	**Attention Required**
Fire Suppression 3	UPS Room 2 — Gas Cylinder 3	LOW PRESSURE	Pressure Switch Sensor	**Attention Required**
Fire Suppression 4	UPS Room 2 — Gas Cylinder 4	LOW PRESSURE	Pressure Switch Sensor	**Attention Required**
Fire Suppression 5	UPS Room 2 — Gas Cylinder 5	LOW PRESSURE	Pressure Switch Sensor	**Attention Required**
Fire Suppression	UPS Room 2 — Gas Cylinder	LOW PRESSURE	Pressure Switch	**Attention**

6	6		Sensor	**Required**
Fire Suppression 7	UPS Room 2 — Gas Cylinder 7	HIGH PRESSURE (OK)	Pressure Switch Sensor	**Normal**
Fire Suppression 8	UPS Room 2 — Gas Cylinder 8	HIGH PRESSURE (OK)	Pressure Switch Sensor	**Normal**
Fire Suppression 9	UPS Room 2 — Gas Cylinder 9	HIGH PRESSURE (OK)	Pressure Switch Sensor	**Normal**
Fire Suppression 10	UPS Room 2 — Gas Cylinder 10	HIGH PRESSURE (OK)	Pressure Switch Sensor	**Normal**

4. RO Plant Water Treatment & 24h Quality Report

Status: FILTERING

Parameter	Live Telemetry Reading	24h Average Reading	24h Maximum Peak	Quality Compliance
TDS (Total Dissolved Solids)	**N/A ppm**	N/A ppm	N/A ppm	**Optimal (< 200 ppm)**
Permeate Water Flow Rate	**0.0 L/min**	0.0 L/min	-	**Normal Flow**
RO Membrane Pressure	**5.0 psi**	-	-	**Normal Pressure**
pH Level	**7.4**	-	-	**Balanced (6.5 - 8.5)**