Daily 24-Hour Diesel Generator (DG Set) Operations Report

Date: **14 October 2026** | Generated At: **03:01:39 IST**

3	3	3	0.0 kWh	0
TOTAL DG SETS	ACTIVE / ONLINE	CURRENTLY RUNNING	24H ENERGY GENERATED	ACTIVE ALARMS


DG Sets Detailed 24h Operational Breakdown

DG SET	STATE	POWER & ENERGY	FUEL & BATTERY	ENGINE HEALTH	LAST SYNC
DG SET1 ONLINE	RUNNING	Live Power: **0.0 kW** 24h Peak: **0.0 kW** 24h Energy: **0 kWh** Meter: **583,450 kWh**	Fuel Level: **87.4 %** 24h Avg / Min: **87.1 % / 86.2 %** Battery: **26.4 V**	Coolant: Sensor Offline Oil Pressure: Sensor Offline Engine RPM: Sensor Offline Run Hours: **146.7 hrs** Starts: **369**	14 Oct 2026 03:01:33
DG Set 2 ONLINE	RUNNING	Live Power: **0.0 kW** 24h Peak: **0.0 kW** 24h Energy: **0 kWh** Meter: **524,600 kWh**	Fuel Level: **82.1 %** 24h Avg / Min: **82.2 % / 81.7 %** Battery: **26.7 V**	Coolant: Sensor Offline Oil Pressure: Sensor Offline Engine RPM: Sensor Offline Run Hours: **121.4 hrs** Starts: **311**	14 Oct 2026 03:01:28
DG Set 3 ONLINE	RUNNING	Live Power: **0.0 kW** 24h Peak: **0.0 kW** 24h Energy: **0 kWh** Meter: **287,400 kWh**	Fuel Level: **100.0 %** 24h Avg / Min: **100.0 % / 100.0 %** Battery: **26.7 V**	Coolant: Sensor Offline Oil Pressure: Sensor Offline Engine RPM: Sensor Offline Run Hours: **110.3 hrs** Starts: **266**	14 Oct 2026 03:01:38

24-Hour Time Series Trends


Power Output (kW · 30-min average)

DG SET1 avg 0 · min 0 · max 0 kW **DG Set 2** avg 0 · min 0 · max 0 kW **DG Set 3** avg 0 · min 0 · max 0 kW




Fuel Level (% · 30-min average)

DG SET1 avg 87.1 · min 86.2 · max 87.7 % **DG Set 2** avg 82.2 · min 81.7 · max 82.7 %
DG Set 3 avg 100 · min 100 · max 100 %



Battery Voltage (V · 30-min average)

DG SET1 avg 26.4 · min 26.4 · max 26.5 V **DG Set 2** avg 26.7 · min 26.6 · max 26.7 V
DG Set 3 avg 26.7 · min 26.7 · max 26.7 V



Coolant Temperature (°C · 30-min average)

DG SET1 avg 41.4 · min 41.4 · max 41.4 °C **DG Set 2** avg 39.2 · min 39.2 · max 39.2 °C
DG Set 3 avg 36.5 · min 36.5 · max 36.5 °C

