AquaGuard Water Quality Assessment Report

Station: **Report Test Station** (REP-01) | Source: **DRINKING_WATER** | Location: 41.0000, -74.0000

Reporting Window: 2026-10-31 16:26 to 2026-11-02 16:26 UTC | Generated: 2026-11-01 16:26:44 UTC

1. Monitoring Telemetry Summary

Metric	Value	Metric	Value
Total Samples Collected	1	Total Alerts Triggered	1
Simulated Samples	0 (0.0%)	Critical Severity Alerts	0
Station Status	ACTIVE	Water Source Classification	DRINKING_WATER

2. Water Quality Parameter Statistics

Parameter	Unit	Min	Max	Average	Samples
pH	pH	7.20	7.20	7.20	1
Turbidity	NTU	0.80	0.80	0.80	1
Temperature	°C	18.50	18.50	18.50	1
Dissolved Oxygen	mg/L	8.50	8.50	8.50	1
Total Dissolved Solids	ppm	180.00	180.00	180.00	1
Electrical Conductivity	µS/cm	270.00	270.00	270.00	1
Ammonia	mg/L	N/A	N/A	N/A	0
Nitrate	mg/L	N/A	N/A	N/A	0
Residual Chlorine	mg/L	N/A	N/A	N/A	0

3. Alert & Incident Record

Time (UTC)	Severity	Parameter	Observed	Threshold	Status
11-01 16:26	WARNING	ph	8.90 pH	8.50 pH	ACTIVE

IMPORTANT SCIENTIFIC & REGULATORY NOTICE: *This report is generated by AquaGuard IoT Automated Water Quality Monitoring System based on online physicochemical sensor telemetry (pH, Turbidity, DO, TDS, EC). Sensor measurements provide rapid, continuous operational screening but* ***DO NOT*** *constitute certification of microbiological potability, absence of pathogenic organisms (e.g. E. coli, coliforms, Giardia, Cryptosporidium), heavy metals (lead, arsenic, mercury), or hazardous organic compounds. Comprehensive drinking water certification requires standardized laboratory analytical procedures conducted by an accredited water testing laboratory.*