

INDEPENDENT ENGINEERING AUDIT & GENERATION VERIFICATION

Bureau Veritas Renewable Advisory Services · Accredited ISO/IEC 17020 Inspection Body

AUDIT REPORT REF:	BV-REC-2026-Q1-9921	AUDIT PERIOD:	Q1 2026 (Jan 1 - Mar 31)
AUDITED FACILITY:	Mojave Desert Solar One	RESOURCE TYPE:	Solar Photovoltaic
NAMEPLATE CAPACITY:	50.0 MW (Peak)	GRID INTERCONNECTION:	GRID-CA-MDS-890
TOTAL VERIFIED MWH:	7,850.5 MWh	AUDIT RESULT:	ACCREDITED & ISSUED

Executive Engineering Summary & Forensic Attestation

Bureau Veritas Clean Energy Advisory has completed the independent technical generation audit for Mojave Desert Solar One. The evaluation reviewed SCADA revenue meter logs, utility billing settlement statements, inverter availability matrices, and hourly solar irradiance index datasets. The total net generation of 7,850.5 MWh conforms with the physical thermodynamic limits of the 50 MW nameplate installation (Capacity Factor: 22.4%). No evidence of inverter tampering or reverse grid feeding was identified during physical field calibration.

OFFICIAL_METER_REPORT_SOLAR_MOJAVE_2026 - Third Party Attestation Digest