

Hostel G & Hostel H Water Quality Analysis Report

Sample Date: 09/11/2024 @ 03:00p.m

Sl.No.	Parameter	Unit	Hostel G (Malhar)	Hostel H (Des)	Acceptable limits	Permissible limits in the absence of an alternate source	Remarks
1.	pH	pH unit	7.62	7.77	6.5-8.8	No Relaxation	
2.	TDS	mg/L	69	67	500	2000	
3.	EC	µS/cm	135.6	136.5	-	-	
4.	Turbidity	NTU	0.12	0.27	1	5	