1 Input Parameters

Module	Tension Member Design - Bolted to End Gusset		
Axial (kN)*	76.0		
Length (mm) *	1250.0		
Section Profile*	Angles		
Section Size*	Ref List of Input Section		
Section Material	E 250 (Fe 410 W)A		
Ultimate Strength, F_u (MPa)	410		
Yield Strength, F_y (MPa)	250		
Bolt Details - Input and Design Preference			
Diameter (mm)	[8]		
Property Class	[4.6]		
Type	Bearing Bolt		
Hole Type	Standard		
Detailing - Des	ign Preference		
Edge Preparation Method	Sheared or hand flame cut		
Are the Members Exposed to Corrosive Influences?	False		
Plate Details - Input and Design Preference			
Thickness (mm)	[8, 10, 12, 14, 16, 18, 20, 22, 25, 28, 32, 36, 40, 45,		
Tincaness (mm)	50, 56, 63, 75, 80, 90, 100, 110, 120]		
Material	E 250 (Fe 410 W)A		

1.1 List of Input Section

a a. *	140 40 71	
Section Size*	$'40 \times 40 \times 5'$	
Decement Size	10 X 10 X 0	

1.2 List of Input Section

Section Size*	'40 x 40 x 5'

2 Design Checks

Design Status Fail

2.1 Selected Member Data

	Section	n Size*	('40 >	x 40 x 5', 'Angles')
	Material		E 250 (Fe 410 W)A	
	Mass, $m (kg/m)$		2.99	
	Area, A (cm ²)		381.0	
	A (mm)	40.0	$I_v(\mathrm{cm}^4)$	2.33
	B (mm)	40.0	r_z (cm)	1.21
C:/Users/parth/Downloads/Osc	t (mm)	15.0 les/images/eq	r_{y} (cm)	1.21
o., osers, par en, bownroads, os	$R_1 \text{ (mm)}$	5.5	r_u (cm)	1.52
	$R_2 \text{ (mm)}$	0.0	r_v (cm)	0.78
	$C_y \text{ (mm)}$	11.7	$Z_z \text{ (cm}^3)$	1.97
	$C_z \text{ (mm)}$	11.7	$Z_y \text{ (cm}^3)$	1.97
	$I_z \text{ (cm}^4)$	5.58	$Z_{pz} (\mathrm{cm}^3)$	3.55
	$I_y(\mathrm{cm}^4)$	5.58	$Z_{py} (\mathrm{cm}^3)$	3.57
	$I_u \text{ (cm}^4)$	8.83	Radius of	7.8
			gyration, r (cm)	

2.2 Spacing Check

Check	Required	Provided	Remarks
Min. Diameter (mm)		d = 8	
Hole Diameter (mm)		$d_0 = 8$	
Minimum Bolts (nos)		$r_l = 1$	

Check	Required	Provided	Remarks
	$p/g_{\min} = 2.5d$		
	$=2.5\times8.0$		
Min. Gauge	= 20.0	0.0	
Distance (mm)			
	[Ref. IS 800:2007, Cl.10.2.2]		
	$e_{\min} = 1.5d_0$		
	$=1.5\times8$		
Min. Edge	= 12.0	15	
Distance (mm)			
	[Ref. IS 800:2007, Cl.10.2.4.2]		
	$depth = 2 e + (r_l - 1) g$		
Spacing Check	$= 2 \times 15 + (1 - 1) \times 20$	29.5	Fail
	= 30		

2.3 Member Check

Check	Required	Provided	Remarks
		$T_{ m dg} = rac{A_g f_y}{\gamma_{m0}}$	
Tension Yielding Capacity (kN)		$= \frac{381.0 \times 250}{1.1 \times 10^3}$ $= 86.59$	
		[Ref. IS 800:2007, Cl.6.2] $\frac{KL}{r} = \frac{1 \times 1250.0}{7.8}$	
Slenderness	$\frac{KL}{r} \le 400$	= 160.26	Pass
		[Ref. IS 800:2007, Cl.7.1.2]	