

# UROX.S36306 - Smoke Detectors for Fire Alarm Systems

## Smoke Detectors for Fire Alarm Systems

See General Information for Smoke Detectors for Fire Alarm Systems

MTECH FIRE DETECTION SYSTEMS LTD  
KIBBUTZ HASOLELIM  
17905 D.N HAMOVIL, ISRAEL

S36306

Investigated to ANSI/UL 268 (editions prior to the 7th ed.)

Products Suitable for Ducts, D(I) and D(ST) are investigated to ANSI/UL 268A

Heat Detector, Model(s) MA-340, MB-240

Detector		Compatibility		Velocity Range (fpm)		Date of Manufacture	Time of Manufacture	Firmware Version
				Min	Max		Firmware Version	Firmware Update
MB-220, MA-320(a)	OAP	P	D2	0	300	-	-	-

Base Model	Related Detector	Control Unit Compatibility Restrictions
MA-300	MA-320, MA-340	B2
MB-300	MB-220, MB-240	B2

B2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

D2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

OAP - Open Area Protection

P - Photoelectric

**Date of Manufacture** identifies the manufacturing start date of all product models that will use the specific Time of Manufacture Firmware Version. The date of manufacture is noncoded and in the format YEAR (in 4 digits), MONTH (in letters), DAY (in 2 digits).

**Time of Manufacture Firmware Version** identifies a numerical and/or alphabetic series designation that is product and date-code specific and will only identify the Firmware Version at the time the product was manufactured. The numeric and/or alphabetic sequence is defined by the manufacturer.

**Firmware Version Update** is a numerical and/or alphabetic sequential identification that is product and date-code specific and sequentially identifies the Firmware Version Update from the previous version of firmware. The numerical and/or alphabetic sequence is defined by the manufacturer.

(a) - Detector base model MA-300 is compatible with heat detector head MA-330

Last Updated on 2020-07-16

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"