



YOGI VEMANA UNIVERSITY
Vemanapuram, Kadapa - 516 005 (A.P., INDIA)

No. YVU/ED/KDP/PE/AE (Elect.,) / C.P. Brown Library/ Electrical Items/V/eh
Quotation /2025-26, Dt.10.02.2026.

To,

The Eligible Suppliers / Authorized Electrical Material Dealers,

Sub: Yogi Vemana University, Kadapa- Engineering Department - "Supply & Transportation of Electrical Items to C.P. Brown Memorial Library, Kadapa"- Calling of Quotations - Reg.

-000-

Eligible electrical material suppliers are requested to submit their sealed quotations for the following items, as per the required specifications:


Sl.No	Description of Item	Qty	Unit	Rate	Amount
1.	Supply and Transportation of Decolam Board of size 12"x15"	2.00	Nos.		
2.	Supply and Transportation of No.8 Screws of 35/38mm	1.00	No.		
3.	Supply of 1.0 Sq mm ISI marked FRLS/FRLS-II/HFTR/ZHFR PVC Insulated flexible copper cables 1100V grade as per IS: 694/1990 & IS:17048/2018 specification for copper cable.	50.00	Mts		
4.	Supply of 6A, 1 Way flush type Switch & 6A, 3 pin flush type Socket with shutter 16A, flush type Switch Socket combined (2 in one), Step type Electronic Regulator, Socket size of wattage 100/120W, ISI marked. Makes: GM G Home/Gold Medal Olive/Million Zoom/Great white Omega/Koncept / Vimalopel/Anchor/ Vihan/CPL/Havells Reo/Elleys.				
a.	6A, 1 Way flush type Switch	12.00	Nos.		
b.	6A, 3 pin flush type Socket with shutter	2.00	Nos.		
c.	16A, flush type Switch Socket combined (2 in one).	3.00	Nos.		
d.	Step type Electronic Regulator, Socket size of wattage 100/120W.	2.00	Nos.		
e.	Batten Holders	2.00	Nos.		
5.	Supply and fixing of 20-24W, not less than 1100mm length LED batten light with extruded aluminum housing and polycarbonate cover, input voltage AC 220-260 Volts, with high power LEDs, having System Efficacy of 100 lumens/watt, PF>0.9, Surge protection: 2KV, THD<15%, with Inbuilt driver and frosted cover CCT 3000K-5700K, minimum CRI>70, etc., complete with earth connection and not less than two years warranty. a) LUMINAIRE MAKE: Phillips/GE-Venture /Crompton/Wipro /Baja/ / Havells/Halonix/Jaquar/HPL/GM/GreenLites/G old/Medal/Eveready/Rhino/Panasonic/Ecolink/C apart.b) LED MAKE: PHILIPS LUMILEDS / CREE / NICHIA/OSRAM/SAMSUNG/Everlight.	5.00	Nos.		

Sl.No	Description of Item	Qty	Unit	Rate	Amount
6.	Supply of 8" (200mm), Light duty exhaust fan with double ball bearing and wire guard etc complete. Makes: Crompton/Almounard/Havells Turbo Force/Halonix Krypton	1.00	No.		
7.	Supply, Transportation and fixing of storage/Pressure type Vertical/Horizontal 230/250V single phase 2000watts ISI mark 5 Star rated water heater with Glass/SS tank and ABS plastic body of 3 Ltrs capacity to withstand up to 6.5 bar of water pressure including all standard accessories and dead weight pressure reducing valve on outlet side, including cost of 2 Nos nylon/PVC/Metallic hose pipe, testing and all labour charges etc., complete. Makes: Prevailing models of Crompton/Jaquar /Venus /Racold/AO Smith /Havells/ Warmex / GM/ Goldmedal.	2.00	Nos.		
8.	Supply of TW Separators/Guttles	4.00	Nos.		
9.	Supply of PVC/Cotton Tape Rolls (8 Mtrs)	10.00	Nos.		
10.	Supply of Fan Condensers (Tibcon)	10.00	Nos.		
11.	GST				
12.	Total:				

Terms & Conditions

1. Rates must be quoted per item, inclusive of transportation, loading/unloading & all taxes.
2. Materials must conform to the specifications mentioned above.
3. Supply must be completed within 7 days from the date of Purchase Order.
4. Payment will be made after material verification and certification by the Engineering Department.
5. Supplier will be responsible for safe delivery & replacement of defective/damaged items.
6. The University reserves the right to accept or reject any quotation without assigning reasons.

The sealed quotation, superscribed as "Quotation for Supply of Electrical Items - C.P. Brown Memorial Library, YVU" should reach the Registrar, Yogi Vemana University, Vemana Puram, Kadapa-516 005 on or before. 18.02.2026 @ 11:00 A.M.


I/c REGISTRAR

REGISTRAR
YOGI VEMANA UNIVERSITY
KADAPA-516005.

Copy to the Director, IT & Networking Cell, YVU, Kadapa with a request to place the call letter in the University Web site.
Copy to Notice Board.
Copy to file.