

2021 Virginia Construction Code

CHAPTER 22 STEEL

SECTION 2201 GENERAL

2201.1 Scope.

The provisions of this chapter govern the quality, design, fabrication and erection of steel construction.

2021 Virginia Construction Code

CHAPTER 22 STEEL

SECTION 2202

IDENTIFICATION OF STEEL FOR STRUCTURAL PURPOSES

2202.1 General.

Identification of *structural steel elements* shall be in accordance with [AISC 360](#). Identification of coldformed steel members shall be in accordance with [AISI S100](#). Identification of cold-formed steel *light-frame construction* shall also comply with the requirements contained in [AISI S240](#) or [AISI S220](#), as applicable. Other steel furnished for structural load-carrying purposes shall be properly identified for conformity to the ordered grade in accordance with the specified ASTM standard or other specification and the provisions of this chapter. Where the steel grade is not readily identifiable from marking and test records, the steel shall be tested to verify conformity to such standards.

2021 Virginia Construction Code

CHAPTER 22 STEEL

SECTION 2203

PROTECTION OF STEEL FOR STRUCTURAL PURPOSES

2203.1 General.

Painting of *structural steel elements* shall be in accordance with [AISC 360](#). Painting of open-web steel joists and joist girders shall be in accordance with [SJI 100](#) and [SJI 200](#). Individual structural members and assembled panels of *cold-formed steel construction* shall be protected against corrosion in accordance with the requirements contained in [AISI S100](#). Protection of cold-formed steel *light-frame construction* shall be in accordance with [AISI S240](#) or [AISI S220](#), as applicable.

2021 Virginia Construction Code

CHAPTER 22 STEEL

SECTION 2204 CONNECTIONS

2204.1 Welding.

The details of design, workmanship and technique for welding and qualification of welding personnel shall be in accordance with the specifications listed in [Sections 2205, 2206, 2207, 2208, 2210 and 2211](#). For *special inspection* of welding, see [Section 1705.2](#).

2204.2 Bolting.

The design, installation and inspection of bolts shall be in accordance with the requirements of [Sections 2205, 2206, 2207, 2210 and 2211](#). For *special inspection* of the installation of high-strength bolts, see [Section 1705.2](#).

2204.3 Anchor rods.

Anchor rods shall be set in accordance with the *approved construction documents*. The protrusion of the threaded ends through the connected material shall fully engage the threads of the nuts but shall not be greater than the length of the threads on the bolts.

2021 Virginia Construction Code

CHAPTER 22 STEEL

SECTION 2205 STRUCTURAL STEEL

2205.1 General.

The design, fabrication and erection of *structural steel elements* in buildings, structures and portions thereof shall be in accordance with [AISC 360](#).

2205.2 Seismic design.

Where required, the seismic design, fabrication and erection of buildings, structures and portions thereof shall be in accordance with [Section 2205.2.1](#) or [2205.2.2](#), as applicable.

2205.2.1 Structural steel seismic force-resisting systems.

The design, detailing, fabrication and erection of structural steel *seismic force-resisting systems* shall be in accordance with the provisions of [Section 2205.2.1.1](#) or [2205.2.1.2](#), as applicable.

2205.2.1.1 Seismic Design Category B or C.

Structures assigned to *Seismic Design Category B* or *C* shall be of any construction permitted in [Section 2205](#). Where a response modification coefficient, *R*, in accordance with [ASCE 7](#), Table 12.2-1, is used for the design of structures assigned to *Seismic Design Category B* or *C*, the structures shall be designed and detailed in accordance with the requirements of [AISC 341](#). [Beam-to-column moment connections in special moment frames and intermediate moment frames shall be prequalified in accordance with AISC 341, Section K1, qualified by testing in accordance with AISC 341, Section K2, or shall be prequalified in accordance with AISC 358.](#)

Exception: The response modification coefficient, *R*, designated for “Steel systems not specifically detailed for seismic resistance, excluding cantilever column systems” in [ASCE 7](#), Table 12.2-1, shall be permitted for systems designed and detailed in accordance with [AISC 360](#), and need not be designed and detailed in accordance with [AISC 341](#).

2205.2.1.2 Seismic Design Category D, E or F.

Structures assigned to *Seismic Design Category D*, *E* or *F* shall be designed and detailed in accordance with [AISC 341](#), except as permitted in [ASCE 7](#), Table 15.4-1. [Beam-to-column moment connections in special moment frames and intermediate moment frames shall be prequalified in accordance with AISC 341, Section K1, qualified by testing in accordance with AISC 341, Section K2, or shall be prequalified in accordance with AISC 358.](#)

2205.2.2 Structural steel elements.

The design, detailing, fabrication and erection of *structural steel elements* in *seismic force-resisting systems* other than those covered in [Section 2205.2.1](#), including struts, *collectors*, chords and foundation elements, shall be in accordance with [AISC 341](#) where either of the following applies:

1. The structure is assigned to *Seismic Design Category D*, *E* or *F*, except as permitted in [ASCE 7](#), Table 15.4-1.
2. A response modification coefficient, *R*, greater than 3 in accordance with [ASCE 7](#), Table 12.2-1, is used for the design of the structure assigned to *Seismic Design Category B* or *C*.

2021 Virginia Construction Code

CHAPTER 22 STEEL

SECTION 2206

COMPOSITE STRUCTURAL STEEL AND CONCRETE STRUCTURES

2206.1 General.

Systems of *structural steel elements* acting compositely with reinforced concrete shall be designed in accordance with [AISC 360](#) and [ACI 318](#), excluding [ACI 318](#) Chapter 14.

2206.2 Seismic design.

Where required, the seismic design, fabrication and erection of composite steel and concrete systems shall be in accordance with [Section 2206.2.1](#).

2206.2.1 Seismic requirements for composite structural steel and concrete construction.

Where a response modification coefficient, R , in accordance with [ASCE 7](#), Table 12.2-1, is used for the design of systems of structural steel acting compositely with reinforced concrete, the structures shall be designed and detailed in accordance with the requirements of [AISC 341](#).

2021 Virginia Construction Code

CHAPTER 22 STEEL

SECTION 2207 STEEL JOISTS

2207.1 General.

The design, manufacture and use of openweb *steel joists* and joist girders shall be in accordance with either [SJI 100](#) or [SJI 200](#), as applicable.

2207.1.1 Seismic design.

Where required, the seismic design of buildings shall be in accordance with the additional provisions of [Section 2205.2](#) or [2211.1.1](#).

2207.2 Design.

The *registered design professional* shall indicate on the *construction documents* the *steel joist* and *steel joist girder* designations from the specifications listed in [Section 2207.1](#); and shall indicate the requirements for joist and joist girder design, layout, end supports, anchorage, bridging design that differs from the SJI specifications listed in [Section 2207.1](#), bridging termination connections and bearing connection design to resist uplift and lateral loads. These documents shall indicate special requirements as follows:

1. Special loads including:
 - 1.1. Concentrated loads.
 - 1.2. Nonuniform loads.
 - 1.3. Net uplift loads.
 - 1.4. Axial loads.
 - 1.5. End moments.
 - 1.6. Connection forces.
2. Special considerations including:
 - 2.1. Profiles for joist and joist girder configurations that differ from those defined by the SJI specifications listed in [Section 2207.1](#).
 - 2.2. Oversized or other nonstandard web openings.
 - 2.3. Extended ends.
3. Live and total load deflection criteria for joists and joist girder configurations that differ from those defined by the SJI specifications listed in [Section 2207.1](#).

2207.3 Calculations.

The *steel joist* and joist girder manufacturer shall design the *steel joists* and *steel joist girders* in accordance with the SJI specifications listed in [Section 2207.1](#) to support the load requirements of [Section 2207.2](#). The *registered design professional* shall be permitted to require submission of the *steel joist* and joist girder calculations as prepared by a *registered design professional* responsible for the product design. Where requested by the *registered design professional*, the *steel joist* manufacturer shall submit design calculations with a cover letter bearing the seal and signature of the joist manufacturer's *registered design professional*. In addition to the design calculations submitted under seal and signature, the following shall be included:

1. Bridging design that differs from the SJI specifications listed in [Section 2207.1](#), such as cantilevered conditions and net uplift.
2. Connection design for:
 - 2.1. Connections that differ from the SJI specifications listed in [Section 2207.1](#), such as flush-framed or framed connections.
 - 2.2. Field splices.
 - 2.3. Joist headers.

2207.4 Steel joist drawings.

Steel joist placement plans shall be provided to show the *steel joist* products as specified on the *approved construction documents* and are to be utilized for field installation in accordance with specific project requirements as stated in [Section 2207.2](#). *Steel joist* placement plans shall include, at a minimum, the following:

1. Listing of applicable loads as stated in [Section 2207.2](#) and used in the design of the *steel joists* and joist girders as specified in the *approved construction documents*.
2. Profiles for joist and joist girder configurations that differ from those defined by the SJI specifications listed in [Section 2207.1](#).

Copyright © 2024 International Code Council, Inc., or its licensors (ALL RIGHTS RESERVED).

Accessed by Venkatesh Shanmugam on 11/14/2024 pursuant to License Agreement with ICC. No further reproduction or distribution authorized. Any Unauthorized reproduction or distribution is a violation of the federal copyright, and subject to civil and criminal penalties thereunder.

3. Connection requirements for:
 - 3.1. Joist supports.
 - 3.2. Joist girder supports.
 - 3.3. Field splices.
 - 3.4. Bridging attachments.
4. Live and total *load* deflection criteria for joists and joist girder configurations that differ from those defined by the SJI specifications listed in [Section 2207.1](#).
5. Size, location and connections for bridging.
6. Joist headers.

Steel joist placement plans do not require the seal and signature of the joist manufacturer's *registered design professional*.

2207.5 Certification.

At completion of manufacture, the *steel joist* manufacturer shall submit a *certificate of compliance* to the owner or the owner's authorized agent for submittal to the *building official* as specified in [Section 1704.5](#) stating that work was performed in accordance with *approved construction documents* and with SJI specifications listed in [Section 2207.1](#).

2021 Virginia Construction Code

CHAPTER 22 STEEL

SECTION 2208 STEEL CABLE STRUCTURES

2208.1 General.

The design, fabrication and erection including related connections, and protective coatings of steel cables for buildings shall be in accordance with [ASCE 19](#).

2021 Virginia Construction Code

CHAPTER 22 STEEL

SECTION 2209 STEEL STORAGE RACKS

2209.1 Steel storage racks.

The design, testing and utilization of *steel storage racks* made of cold-formed or hot-rolled steel structural members shall be in accordance with [RMI ANSI/MH 16.1](#). Where required by [ASCE 7](#), the seismic design of *steel storage racks* shall be in accordance with Section 15.5.3 of [ASCE 7](#).

2209.2 Steel cantilevered storage racks.

The design, testing and utilization of *steel cantilevered storage racks* made of cold-formed or hot-rolled steel structural members shall be in accordance with [RMI ANSI/MH 16.3](#). Where required by [ASCE 7](#), the seismic design of *steel cantilevered storage racks* shall be in accordance with Section 15.5.3 of [ASCE 7](#).

2209.3 Certification.

For rack storage structures that are 8 feet (2438 mm) in height or greater to the top *load* level and assigned to *Seismic Design Category D, E, or F* at completion of the *storage rack* installation, a *certificate of compliance* shall be submitted to the *owner* or the *owner's* authorized agent stating that the work was performed in accordance with approved construction documents.

2021 Virginia Construction Code

CHAPTER 22 STEEL

SECTION 2210 COLD-FORMED STEEL

2210.1 General.

The design of cold-formed carbon and low-alloy steel structural members shall be in accordance with [AISI S100](#). The design of cold-formed stainless-steel structural members shall be in accordance with [ASCE 8](#). Cold-formed steel *light-frame construction* shall comply with [Section 2211](#). Where required, the seismic design of cold-formed steel structures shall be in accordance with the additional provisions of [Section 2210.2](#).

2210.1.1 Steel decks.

The design and construction of cold-formed steel decks shall be in accordance with this section.

2210.1.1.1 Noncomposite steel floor decks.

Noncomposite steel floor decks shall be permitted to be designed and constructed in accordance with [ANSI/SDI-NC1.0](#).

2210.1.1.2 Steel roof deck.

Steel *roof decks* shall be permitted to be designed and constructed in accordance with [ANSI/SDI-RD1.0](#).

2210.1.1.3 Composite slabs on steel decks.

Composite slabs of concrete and steel deck shall be permitted to be designed and constructed in accordance with [SDI-C](#).

2210.2 Seismic requirements for cold-formed steel structures.

Where a response modification coefficient, R , in accordance with [ASCE 7](#), Table 12.2-1, is used for the design of cold-formed steel structures, the structures shall be designed and detailed in accordance with the requirements of [AISI S100](#), [ASCE 8](#), or, for cold-formed steel special-bolted moment frames, [AISI S400](#).

2021 Virginia Construction Code

CHAPTER 22 STEEL

SECTION 2211 COLD-FORMED STEEL LIGHT-FRAME CONSTRUCTION

2211.1 Structural framing.

For cold-formed steel *light-frame construction*, the design and installation of the following structural framing systems, including their members and connections, shall be in accordance with [AISI S240](#), and [Sections 2211.1.1](#) through [2211.1.3](#), as applicable:

1. Floor and roof systems.
2. Structural walls.
3. Shear walls, strap-braced walls and diaphragms that resist in-plane lateral loads.
4. Trusses.

2211.1.1 Seismic requirements for cold-formed steel structural systems.

The design of cold-formed steel *light-frame construction* to resist seismic forces shall be in accordance with the provisions of [Section 2211.1.1.1](#) or [2211.1.1.2](#), as applicable.

2211.1.1.1 Seismic Design Categories B and C.

Where a response modification coefficient, R , in accordance with [ASCE 7](#), Table 12.2-1 is used for the design of cold-formed steel *light-frame construction* assigned to *Seismic Design Category* B or C, the *seismic force-resisting system* shall be designed and detailed in accordance with the requirements of [AISI S400](#).

Exception: The response modification coefficient, R , designated for “Steel systems not specifically detailed for seismic resistance, excluding cantilever column systems” in [ASCE 7](#), Table 12.2-1, shall be permitted for systems designed and detailed in accordance with [AISI S240](#) and need not be designed and detailed in accordance with [AISI S400](#).

2211.1.1.2 Seismic Design Categories D through F.

In cold-formed steel *light-frame construction* assigned to *Seismic Design Category* D, E or F, the *seismic force-resisting system* shall be designed and detailed in accordance with [AISI S400](#).

2211.1.2 Prescriptive framing.

Detached one- and two-family *dwelling*s and *townhouses*, less than or equal to three *stories above grade plane*, shall be permitted to be constructed in accordance with [AISI S230](#) subject to the limitations therein.

2211.1.3 Truss design.

Cold-formed steel trusses shall comply with the additional provisions of [Sections 2211.1.3.1](#) through [2211.1.3.3](#).

2211.1.3.1 Truss design drawings.

The truss design drawings shall conform to the requirements of Section I1 of [AISI S202](#) and shall be provided with the shipment of trusses delivered to the job site. The truss design drawings shall include the details of permanent *individual truss member* restraint/bracing in accordance with Section I1.6 of [AISI S202](#) where these methods are utilized to provide restraint/bracing.

2211.1.3.2 Trusses spanning 60 feet or greater.

The owner or the owner's authorized agent shall contract with a *registered design professional* for the design of the temporary installation restraint/bracing and the permanent *individual truss member* restraint/bracing for trusses with clear spans 60 feet (18 288 mm) or greater. *Special inspection* of trusses over 60 feet (18 288 mm) in length shall be in accordance with [Section 1705.2](#).

2211.1.3.3 Truss quality assurance.

Trusses not part of a manufacturing process that provides requirements for quality control done under the supervision of a third-party quality control agency in accordance with [AISI S240](#) Chapter D shall be fabricated in compliance with [Sections 1704.2.5](#) and [1705.2](#), as applicable.

2211.2 Nonstructural members.

For cold-formed steel *light-frame construction*, the design and installation of nonstructural members and connections shall be in accordance with [AISI S220](#).