

2021 Virginia Construction Code

CHAPTER 12 INTERIOR ENVIRONMENT

SECTION 1203 TEMPERATURE CONTROL

1203.1 Equipment and systems.

Interior spaces intended for human occupancy shall be provided with active or passive space heating systems capable of maintaining an indoor temperature of not less than 68°F (20°C) at a point 3 feet (914 mm) above the floor on the design heating day.

Exceptions: Space heating systems are not required for:

1. Interior spaces where the primary purpose of the space is not associated with human comfort.
2. Group F, H, S or U occupancies.