

# 2021 Virginia Construction Code

## CHAPTER 11 ACCESSIBILITY

### SECTION 1102 COMPLIANCE

#### 1102.1 Design.

Buildings and facilities shall be designed and constructed to be *accessible* in accordance with this code and [ICC A117.1](#).

**Exception:** Wall-mounted visible alarm notification appliances in Group I-3 occupancies shall be permitted to be a maximum of 120 inches (3048 mm) above the floor or ground, measured to the bottom of the appliance. Such appliances shall otherwise comply with all applicable requirements.