

POWER SYSTEMS · MICROGRIDS · FAULT ANALYSIS

DETECTION OF FAULT IN A DG INTEGRATED POWER SYSTEM

**Modeling, Simulation and Fault Analysis of a 13-
Bus
Microgrid using MATLAB / Simulink**

A PROJECT BY

Yuvraj Mishra

TOOLS

**MATLAB R2018a · Simulink · Simscape
Electrical**

YEAR

2026

github.com/Venom893/DG-Fault-Detection

ABSTRACT

This project presents the modelling and detection of fault in a DG Integrated power system using MATLAB/Simulink. A microgrid is a localized power system consisting of distributed energy resources such as renewable energy sources, battery energy storage systems, diesel generators, transformers, transmission lines, and various electrical loads. With the increasing integration of renewable energy and nonlinear loads, protection and Detection of Fault in a DG Integrated Power Systems have become an important challenge in modern power systems.

In this work, a 13-bus microgrid model has been developed in MATLAB/Simulink to study the behaviour of the system under different fault conditions. The proposed model includes components such as a bulk power system, transmission lines, transformers, linear and nonlinear loads, Battery Energy Storage System (BESS), diesel generator, arc furnace model, and Total Harmonic Distortion (THD) analysis block. Different types of faults such as single line-to-ground (AG) fault and three-phase-to-ground (ABC-G) fault were simulated and analysed.

The simulation results show the variation in voltage, current, and harmonic distortion during normal and faulty operating conditions. The study also demonstrates the impact of nonlinear loads and faults on system stability and power quality. The fault analysis helps in understanding system behaviour, improving protection coordination, and enhancing the reliability and safety of microgrid operation.

The developed model successfully demonstrates the importance of fault detection and analysis in microgrids and can be further extended for advanced protection schemes, renewable integration studies, and intelligent fault detection techniques using artificial intelligence and machine learning.

CONTENTS

Certificate	ii
Approval Sheet	iii
Declaration	iv
Acknowledgments	v
Abstract	vi
List of Figures	viii
Chapter 1 Introduction	1
1.1 Introduction	1
1.2 Background	2
1.3 Literature Survey	3
1.4 Research Gap	5
1.5 Problem Formulation	6
1.6 Contribution	7
1.7 Thesis Organization	7
Chapter 2 Fault Detection in a DG Integrated Power System	9
2.1 Introduction	9
2.2 Model Description (with MATLAB/Simulink Diagram)	10
2.3 Methodology Used	13
2.4 Results and Discussion	14
2.5 Conclusion	16
Chapter 3 Fault Analysis and Performance Evaluation of DG Integrated Power System	17
3.1 Introduction	17
3.2 Fault Simulation in DG Integrated Power System	17
3.3 Voltage Analysis During Fault Condition	20
3.4 Current Analysis During Fault Condition	22
3.5 Performance Evaluation of DG Integrated Power System	23
3.6 Discussion of Results	27
3.7 Conclusion	28
Chapter 4 Conclusion and Future Scope	29
4.1 Conclusion	29
4.2 Future Scope	30
References	31
Plagiarism Report	33

List of Figures

Figure No.	Title of Figure	Page No.
Figure 2.1	MATLAB/Simulink Model of DG Integrated 13-Bus Power System	12
Figure 3.1(a)	Three-Phase Current under Normal Operating Condition	19
Figure 3.1(b)	Three-Phase Current under Normal Operating Condition	19
Figure 3.2	Three-Phase Voltage Waveform during ABG Fault Condition	21
Figure 3.3	Three-Phase Current Waveform during ABG Fault Condition	23
Figure 3.4(a)	Three-Phase Current under Normal Operating Condition	25
Figure 3.4(b)	Three-Phase Current under ABG Fault Condition	25
Figure 3.4(c)	Three-Phase Voltage under Normal Operating Condition	25
Figure 3.4(d)	Three-Phase Voltage under ABG Fault Condition	26

CHAPTER 1

INTRODUCTION

1.1 Introduction

The continuous growth in electricity demand and the expansion of modern industries have increased the need for reliable and efficient power systems. Conventional centralized generation systems often experience problems such as transmission losses, voltage fluctuations, overloading, and interruptions during fault conditions. To improve the performance and reliability of electrical networks, Distributed Generation (DG) integrated systems and microgrids are becoming widely used in modern power applications [1].

Distributed Generation refers to small-scale power sources installed close to the consumer side of the network. These generating units may include solar photovoltaic systems, wind energy systems, diesel generators, fuel cells, and battery energy storage systems. The integration of DG units into electrical networks helps reduce transmission losses, improves voltage regulation, and provides better reliability during varying load conditions [2], [3].

Researchers have proposed different control and protection methods to improve the performance of DG integrated systems. Various adaptive control strategies and power-sharing techniques have been developed for inverter-based distributed generators to maintain stable operation and improve current distribution within interconnected microgrids [4], [5]. In addition, fault detection techniques based on signal analysis and monitoring methods have been introduced to identify abnormal operating conditions in distribution systems more effectively [6].

The operation and control of interconnected AC–DC microgrids have also gained significant research attention in recent years. Several studies focused on improving power flow management, synchronization, and stability enhancement in hybrid microgrid systems operating under changing load conditions [7], [8]. Researchers have further analyzed the influence of line impedance and inverter control on current sharing performance in distributed power networks [9], [10].

With the increasing use of renewable energy resources, proper energy management and coordinated control have become essential in DG integrated systems. Studies on active distribution networks and islanded microgrids highlighted the importance of maintaining stable voltage and frequency conditions for reliable system operation [11], [12]. Power management techniques for systems containing multiple DG units have also improved operational flexibility and load-sharing capability within interconnected networks [13].

Modern DG integrated systems also depend heavily on converter technologies for integrating renewable energy sources into the power grid. Proper converter control improves system

stability, enhances power quality, and ensures efficient transfer of electrical power between distributed energy resources and connected loads [14], [15].

Despite these advantages, DG integrated power systems remain vulnerable to electrical faults and abnormal operating conditions. Faults such as line-to-ground faults, line-to-line faults, and unsymmetrical faults may disturb the balance of the system, resulting in voltage variation, excessive current flow, equipment stress, and instability within the network. Therefore, proper fault detection and analysis are necessary for maintaining reliable and safe operation of distributed electrical systems.

In this project, a DG integrated 13-bus power system has been developed using the MATLAB/Simulink platform to study system behaviour during normal and fault conditions. The work mainly focuses on the analysis of ABG fault conditions by observing variations in voltage, current, and system stability during the disturbance period. The developed model helps in understanding the response of interconnected distributed power systems under abnormal operating conditions and highlights the importance of effective fault monitoring and protection techniques in modern smart grid applications.

1.2 Background

The demand for electrical energy has increased continuously due to rapid industrial growth, urbanization, and technological advancement. Modern power systems are expected to provide uninterrupted, stable, and high-quality electricity to consumers under all operating conditions. Conventional centralized generation systems, however, face several limitations such as transmission losses, voltage instability, environmental concerns, and difficulty in supplying reliable power during disturbances. These challenges have encouraged the development of Distributed Generation (DG) and microgrid-based power systems.

Distributed Generation refers to small-scale power generation sources installed close to the load centres instead of relying entirely on large centralized power plants. These generation sources may include diesel generators, photovoltaic systems, wind turbines, battery storage systems, and other renewable energy resources. DG integrated systems improve power reliability, reduce transmission losses, enhance voltage regulation, and provide operational flexibility within modern electrical networks.

With the increasing penetration of distributed energy resources, hybrid microgrids and interconnected DG systems have become important areas of research in recent years. Researchers have proposed various control and power management techniques to improve the operation of such systems. Zolfaghari et al. [6] discussed power flow control in interconnected AC–DC hybrid microgrids using modified unified interphase power controllers, while Taher and Zolfaghari [9] focused on robust control techniques for improving current sharing among inverter-based distributed generators. These studies show that proper control and coordination are necessary for stable operation of distributed power systems.

Despite the advantages offered by DG integrated networks, fault occurrence remains one of the major technical concerns in modern power systems. Electrical faults can occur due to insulation failure, short circuits, equipment malfunction, environmental conditions, or

sudden load disturbances. Fault conditions may produce excessive current, voltage imbalance, and instability within the network, affecting both generation and load components. Among different fault categories, unsymmetrical faults occur more frequently in practical distribution systems. These faults disturb the balance of the three-phase system and influence voltage profile, current magnitude, and power transfer capability. Therefore, effective fault detection and analysis are necessary to maintain the safety, reliability, and continuous operation of distributed electrical networks.

Several researchers have worked on fault detection methods for power systems. Salehi et al. [1] proposed a high impedance fault detection method using morphological gradient edge detection techniques for distribution systems. Their work highlighted the importance of fast and accurate fault identification for preventing system damage and improving operational safety.

In the present project, a DG integrated 13-bus power system is developed using MATLAB/Simulink to study the impact of fault conditions on system operation. The model includes interconnected buses, distributed generation units, transformers, transmission lines, loads, and monitoring blocks designed to represent a practical distributed electrical network. To examine the response of the system during abnormal conditions, an ABG fault is introduced into the network by connecting Phase A and Phase B with ground during simulation. The simulation results help observe variations in voltage, current, and power flow under fault conditions and provide a better understanding of system stability during disturbances. The study of fault conditions in DG integrated systems is important for developing reliable protection strategies and improving the performance of future smart grids and hybrid microgrid networks.

1.3 Literature Survey

The development of distributed generation systems and hybrid microgrids has increased the importance of reliable fault detection, power management, and system stability in modern electrical networks. Several researchers have worked on different control and protection techniques for improving the performance of distributed power systems under normal as well as abnormal operating conditions.

Salehi et al. [1] presented a high impedance fault detection method using a morphological gradient edge detector for distribution systems. The proposed technique processed voltage signals to identify fault conditions and distinguish them from normal switching events. The study showed that the method provided fast and accurate fault identification in distribution networks.

Zolfaghari and Gharehpetian [2] proposed an optimal control strategy for interconnected microgrids with controllable loads. Their work mainly focused on improving voltage regulation, frequency support, and power quality in networked microgrids. The simulation results demonstrated better power exchange performance between AC and DC microgrids.

In another work, Zolfaghari et al. [3] developed a model reference adaptive control method for islanded hybrid microgrids containing flexible loads and storage systems. The study investigated the operation of interconnected AC and DC subsystems and showed that

adaptive control techniques can improve stability and power management during islanded operation.

A robust DC link control method based on a Quasi-Luenberger observer was proposed by Zolfaghari et al. [4] for hybrid microgrids. The research mainly addressed power exchange control between interconnected microgrids and reduced the effect of disturbances on system stability. The proposed controller improved the reliability of hybrid microgrid operation.

Zolfaghari et al. [5] also introduced a new power management scheme for parallel-connected photovoltaic systems in microgrids. Their work focused on improving current sharing and load distribution among distributed generation units using adaptive fuzzy control techniques. The proposed method improved power sharing accuracy and system efficiency under varying operating conditions.

In another study, Zolfaghari et al. [6] discussed power flow control in interconnected AC–DC microgrids using a modified unified interphase power controller (UIPC). The work emphasized stable power exchange and control of hybrid microgrid systems. Simulation results indicated improved power management and reduced DC link fluctuations.

A repetitive control-based technique for current sharing among boost converters in DC microgrids was presented by Zolfaghari et al. [7]. The study analysed the effect of line impedance variations on current sharing and proposed a control method to minimize circulating current between converters. The results confirmed improved current distribution within the DC microgrid.

Taher et al. [8] proposed a robust control approach for synchronization of microgrids with utility systems. The method used robust control theory to reduce frequency oscillations and improve synchronization stability under uncertain operating conditions. The study demonstrated reliable synchronization performance during grid connection.

Another important contribution was made by Taher and Zolfaghari [9], who developed a robust controller for improving current sharing among inverter-based distributed generators in microgrid networks. Their work considered the effect of line impedance on circulating current and proposed an H_∞ loop-shaping control strategy for enhancing system stability and load sharing performance.

More recently, Zolfaghari et al. [10] introduced a robust nonlinear control strategy for isolated hybrid microgrids using a unified interphase power controller. The study focused on bidirectional power exchange between AC and DC subsystems and proposed an adaptive control technique for improving stability and operational reliability of isolated hybrid microgrids.

[11] S. Chowdhury, S. P. Chowdhury, and P. Crossley explained the importance of microgrids and active distribution networks in improving the reliability and efficiency of modern power systems. Their work highlighted the role of distributed generation in reducing transmission losses and supporting stable power supply during network disturbances.

[12] J. A. Peças Lopes, C. L. Moreira, and A. G. Madureira discussed control strategies for islanded microgrid operation. The study focused on maintaining voltage and frequency stability when the microgrid operates independently from the main utility grid.

[13] F. Katiraei and M. R. Iravani proposed power management techniques for microgrids containing multiple distributed generation units. Their research emphasized effective load sharing, coordinated control, and improved operational stability under varying load conditions.

[14] A. Tuladhar, H. Jin, T. Unger, and K. Mauch studied the control of parallel inverters in distributed AC power systems while considering transmission line impedance effects. The proposed method improved current sharing accuracy and enhanced the performance of interconnected DG systems.

[15] R. Teodorescu, M. Liserre, and P. Rodríguez presented advanced grid converter technologies for photovoltaic and wind power systems. Their work highlighted the significance of converter control techniques in integrating renewable energy sources into DG integrated power networks efficiently.

From the above literature, it is observed that considerable research has been carried out in the areas of hybrid microgrids, distributed generation, power management, and control strategies. However, fault analysis in DG integrated power systems under unsymmetrical fault conditions still requires further investigation, especially for interconnected bus systems operating under disturbance conditions. Therefore, this project focuses on the detection and analysis of ABG fault conditions in a DG integrated 13-bus power system using MATLAB/Simulink to study system stability and fault response characteristics.

1.4 Research Gap

Microgrids have emerged as an important solution for modern power systems due to their ability to integrate renewable energy resources, improve reliability, and support localized power generation. However, the increasing penetration of inverter-based distributed generation, nonlinear loads, and energy storage systems has introduced several challenges in fault detection and protection coordination. Conventional protection methods used in traditional power systems are not fully suitable for microgrids because fault current levels in microgrids are comparatively low, variable, and bidirectional in nature.

From the reviewed literature, it is observed that many researchers have focused on intelligent protection schemes, artificial intelligence-based fault detection methods, and adaptive relay coordination techniques. Although these approaches improve fault detection accuracy, several practical issues still remain unresolved in microgrid systems. Most existing studies mainly focus on either renewable integration or protection techniques separately, while limited research has been carried out on analysing the combined impact of faults, nonlinear loads, harmonic distortion, and distributed energy resources within a single integrated microgrid model. In many research works, the effect of harmonics generated by nonlinear industrial loads such as arc furnaces has not been studied in detail during fault conditions. Similarly, the influence of Battery Energy Storage Systems (BESS) and inverter-based sources on system stability and fault current behaviour requires further investigation.

Existing protection schemes also face difficulties in detecting symmetrical and unsymmetrical faults accurately during transitions between grid-connected and islanded operating modes.

Another important gap identified from the literature is the limited availability of simulation models that combine bulk power systems, distributed generation, storage systems, linear and nonlinear loads, THD analysis, and multiple fault conditions within a unified MATLAB/Simulink environment. Many studies focus only on specific components or simplified microgrid structures, which may not accurately represent practical operating conditions of real power systems.

Therefore, there is a need for a detailed simulation-based study that can analyse different fault conditions, harmonic disturbances, and system behaviour in a realistic microgrid environment. The present work attempts to address these gaps by developing a 13-bus MATLAB/Simulink-based microgrid model incorporating transmission lines, transformers, BESS, diesel generator, nonlinear loads, THD analysis, and fault simulation blocks. The study performs detailed analysis of AG fault and ABC-G fault conditions to evaluate voltage variation, fault current behaviour, harmonic distortion, and overall system stability under different operating scenarios.

This research contributes toward improving the understanding of microgrid fault behaviour and highlights the importance of effective protection and power quality analysis in modern smart grid systems. The developed model can also serve as a foundation for future studies related to intelligent fault detection, adaptive protection coordination, renewable energy integration, and advanced microgrid control techniques.

1.5 Problem Formulation

Microgrids are becoming an important part of modern electrical power systems because they support renewable energy integration, improve reliability, and provide continuous power supply during grid disturbances. However, the operation and protection of microgrids are more complicated than conventional power systems due to the presence of distributed generation sources, battery storage systems, nonlinear loads, and bidirectional power flow. In a microgrid, different types of faults such as single line-to-ground fault, line-to-line fault, and three-phase fault may occur because of short circuits, equipment failure, insulation breakdown, or switching disturbances. These faults can affect the voltage, current, stability, and power quality of the system. During fault conditions, abnormal current flows through the network and may damage electrical equipment if the fault is not detected and isolated properly.

Traditional protection methods used in conventional grids are not always suitable for microgrids because inverter-based renewable energy sources produce lower fault current compared to synchronous generators. As a result, protective devices may fail to operate correctly during some fault conditions. In addition, nonlinear loads such as arc furnace systems generate harmonics in the network, which further affects system performance and increases Total Harmonic Distortion (THD).

Another major challenge is maintaining system stability during both normal and faulty conditions. Since the microgrid can operate in grid-connected mode as well as islanded mode, fault behaviour changes depending on operating conditions. Therefore, proper fault analysis is necessary to study the behaviour of the microgrid and improve protection coordination.

In this project, a MATLAB/Simulink-based microgrid model has been developed to analyse different fault conditions and study system response. The model includes components such as buses, transmission lines, transformers, BESS, diesel generator, linear and nonlinear loads, THD analysis block, and fault block. Different fault conditions like AG fault and ABC-G fault are simulated to observe voltage variation, current behaviour, harmonic distortion, and overall system performance.

The main problem addressed in this work is to analyse the effect of faults on a microgrid system and study how faults influence system stability, protection performance, and power quality under different operating conditions.

1.6 Contribution

The major contributions of this project are as follows:

1. Developed a hybrid microgrid simulation model using MATLAB/Simulink for efficient power management and system analysis.
2. Integrated a Battery Energy Storage System (BESS) with a diesel generator to improve energy balancing and ensure uninterrupted power supply during varying load conditions.
3. Implemented voltage and frequency regulation mechanisms using an excitation system to maintain system stability.
4. Simulated industrial nonlinear load conditions using an arc furnace model to analyse the reliability and performance of the microgrid.
5. Designed a control mechanism for monitoring power flow, load demand, charging, and discharging operations of the Battery Energy Storage System.
6. Analysed the performance of the microgrid under different operating conditions, including peak load demand and power fluctuations.
7. Demonstrated the importance of hybrid generation systems and energy storage technologies in improving power quality, reliability, and energy efficiency.
8. Provided a scalable and flexible microgrid model that can be further extended with renewable energy sources such as solar and wind power systems.

1.7 Thesis Organization

The report has been divided into different chapters to present the complete development and analysis of the hybrid microgrid system in a systematic manner.

The first chapter introduces the basic concept of microgrids and explains the need for reliable and efficient power systems in modern applications. It also discusses the background of the study, existing research works, research gaps, objectives, problem statement, and the overall contribution of the project.

The second chapter focuses on the design and modelling of the proposed hybrid microgrid system developed in the MATLAB/Simulink environment. This chapter explains the major components used in the system, such as the diesel generator, Battery Energy Storage System (BESS), excitation system, transformers, transmission lines, and control units. The architecture and configuration of the complete system are also described.

The third chapter presents the operational methodology and performance analysis of the microgrid. It explains how power is generated, stored, distributed, and controlled within the system under different load conditions. Simulation results related to voltage regulation, power balancing, frequency stability, and load management are discussed in detail to evaluate the effectiveness of the proposed system.

The final chapter summarizes the important findings and outcomes obtained from the project work. It also highlights the advantages of hybrid microgrid systems and suggests possible future improvements, including renewable energy integration, advanced control techniques, and smart grid applications.

The report concludes with references and supporting materials used during the development of the project.

CHAPTER 2

Detection of Fault in a DG Integrated Power System

2.1 Introduction

Modern electrical power systems are continuously evolving with the integration of Distributed Generation (DG) units and intelligent control techniques. Conventional centralized power generation systems often face challenges such as transmission losses, voltage instability, and difficulty in supplying uninterrupted power during abnormal conditions. To overcome these limitations, DG integrated power systems and microgrids are increasingly being adopted in industrial, commercial, and residential applications. A DG integrated power system consists of small-scale generation sources connected near the load side of the network. These generation sources may include diesel generators, solar photovoltaic systems, wind energy systems, battery storage units, and other renewable energy resources. The integration of distributed generators improves system reliability, enhances voltage profile, reduces transmission losses, and supports continuous power supply during disturbances.

Despite these advantages, the occurrence of faults remains one of the major concerns in power system operation. Faults may occur due to insulation failure, short circuits, equipment malfunction, lightning, or sudden changes in load conditions. When a fault takes place, large fault currents flow through the network, causing voltage imbalance, overheating of equipment, instability, and possible interruption of power supply. Therefore, proper fault detection and analysis are essential for maintaining the stability and safety of the system.

The present work focuses on the detection and analysis of faults in a DG integrated power system developed using MATLAB/Simulink. The proposed model consists of a 13-bus interconnected network containing distributed generation units, transformers, transmission lines, loads, measurement blocks, and protection elements. The simulation model is designed to study the behaviour of the system under both normal and abnormal operating conditions.

To examine the fault response of the network, a fault block is introduced in the system. In this project, an ABG fault is implemented, where Phase A and Phase B are simultaneously connected to ground. This type of fault belongs to the category of unsymmetrical faults and produces unequal voltage and current distribution across the network. The effect of the fault can be observed through variations in current magnitude, bus voltage, and power flow throughout the system. The developed MATLAB/Simulink model also includes monitoring and control blocks that continuously observe system parameters during simulation. These monitoring units help identify the fault condition and evaluate its impact on the DG integrated network. The simulation results provide useful information regarding system behaviour, stability, and protection requirements under fault conditions.

The main objective of this chapter is to explain the structure and operation of the proposed DG integrated 13-bus power system and to analyse the impact of ABG fault conditions on system performance. The study contributes toward understanding fault behaviour in distributed power networks and highlights the importance of efficient fault detection techniques in modern electrical systems.

To study the behaviour of the system during disturbances, a fault block is incorporated into the model. The project mainly focuses on the analysis of an ABG fault, where Phase A and Phase B simultaneously come in contact with the ground. This type of fault is categorized as an unsymmetrical fault because the electrical quantities in all three phases become unequal during the fault period. The occurrence of the ABG fault affects bus voltages, line currents, and power flow across the network.

The MATLAB/Simulink environment provides an efficient platform for modelling and analysing such complex electrical systems. Using simulation tools, the response of the DG integrated network can be observed under different operating conditions without affecting an actual power system. Parameters such as voltage profile, current magnitude, and fault response characteristics can be monitored continuously during simulation.

The proposed work aims to investigate the impact of ABG fault conditions on the performance and stability of the DG integrated power system. The analysis helps in understanding fault behaviour, evaluating protection requirements, and improving the reliability of distributed electrical networks. The study also highlights the importance of fault monitoring and protection techniques in the development of modern smart grid and microgrid systems.

2.2 Model Description

The proposed model represents a DG integrated power system designed and simulated in the MATLAB/Simulink environment for studying fault detection and system behaviours under abnormal operating conditions. The developed network consists of a 13-bus interconnected system containing distributed generation units, transformers, transmission lines, loads, monitoring blocks, and fault analysis components. The model is created to analyse how the system reacts during unsymmetrical fault conditions and to evaluate the stability of the network during disturbances.

The overall system is arranged in the form of multiple buses connected through transmission lines and transformers to establish power transfer between different sections of the network. Distributed generation sources are integrated into the system to provide electrical power support and improve reliability during varying load conditions. The DG units help maintain continuous power supply and support voltage stability within the network.

The MATLAB/Simulink model includes several major components that work together to simulate practical power system operation. Transmission lines are used for transferring electrical energy between buses, while transformers regulate voltage levels for proper power distribution. Loads connected at different buses represent power consumption within the network. Measurement and control blocks are incorporated to continuously monitor system parameters such as voltage, current, and power flow during simulation.

A fault block is integrated into the network for performing fault analysis. In this project, an ABG fault is applied in the system, where Phase A and Phase B simultaneously come into contact with the ground. This type of fault creates an imbalance in the system and causes variations in voltage and current throughout the network. The fault condition is introduced intentionally to observe the response of the DG integrated system under abnormal situations. During normal operation, electrical power flows smoothly through the buses, transmission lines, and loads while maintaining stable operating conditions. However, when the ABG fault occurs, fault current increases rapidly and voltage imbalance appears across the affected buses. The monitoring blocks record these changes, which helps in analysing the behaviours of the system during the fault period. The proposed model also contains protection and switching elements that help isolate the faulted section from the healthy part of the network. This improves system safety and reduces the possibility of equipment damage during disturbances. The inclusion of distributed generation sources further supports the system by maintaining partial power supply and improving operational reliability during fault conditions.

The developed 13-bus DG integrated power system provides a flexible platform for studying fault behaviour, voltage stability, current variation, and protection requirements in modern electrical networks. The simulation results obtained from the model are useful for understanding the impact of unsymmetrical faults and for developing efficient fault detection and protection techniques for future smart grid applications.




Figure 2.1: MATLAB/Simulink model of the proposed DG integrated 13-bus power system developed for studying ABG fault conditions, voltage variation, and system performance under disturbed operating conditions.

The developed model consists of a DG integrated 13-bus power network designed in MATLAB/Simulink for studying the impact of fault conditions on system performance. The model includes distributed generation units, transmission lines, transformers, interconnected buses, loads, measurement blocks, and fault analysis components connected to represent a practical distributed electrical system. Monitoring blocks are used to observe voltage and current variations during simulation, while the fault block is implemented to create ABG fault conditions within the network. The system is designed to study power flow, waveform variation, fault current, voltage disturbance, and overall network stability under both normal and abnormal operating conditions.

2.3 Methodology Used

The work carried out in this project mainly focuses on developing and analysing a DG integrated power system under fault conditions using the MATLAB/Simulink platform. The methodology adopted for the study includes system modelling, fault implementation, monitoring of electrical parameters, and analysis of system response during abnormal conditions.

Initially, a 13-bus interconnected power system was designed in MATLAB/Simulink to represent a practical distributed power network. Different buses were connected through transmission lines and transformers to establish proper power transfer throughout the system. Loads were connected at suitable buses to simulate power consumption under normal operating conditions.

After developing the basic network structure, Distributed Generation (DG) units were integrated into the system. These DG units were added to improve voltage support and maintain continuous power supply within the network. Proper connection and synchronization of the DG units with the bus system were performed before carrying out fault analysis.

Once the normal operating model was completed, different measurement and monitoring blocks were connected to observe system parameters such as voltage, current, and power flow at various buses. These measurement blocks helped in studying the variation of electrical quantities during both healthy and fault conditions. To analyse abnormal system behaviours, a fault block was introduced into the network. In this project, an ABG fault condition was created by short-circuiting Phase A and Phase B with ground at a selected point in the system. The fault was applied for a specific duration during simulation in order to examine the response of the DG integrated network.

After introducing the fault, the system behaviours were continuously monitored using scope and measurement blocks available in MATLAB/Simulink. Variations in bus voltage, line current, and power flow were observed carefully during the fault period. The effect of the fault on overall system stability and DG performance was also analysed.

The collected simulation results were then compared under normal and faulty operating conditions to understand the impact of the ABG fault on the 13-bus power network. Based on the observed responses, conclusions were drawn regarding fault detection, system stability, and protection requirements in DG integrated power systems.

The overall methodology followed in this project can be summarized in the following steps:

- Development of a 13-bus DG integrated power system in MATLAB/Simulink
- Integration of distributed generation units into the network
- Connection of loads, transformers, and transmission lines
- Installation of measurement and monitoring blocks
- Implementation of ABG fault using a fault block
- Observation of voltage and current variations during fault conditions
- Analysis of system response and stability under disturbance
- Evaluation of fault impact on the DG integrated network

The adopted methodology helped in understanding the behaviours of the system during unsymmetrical fault conditions and provided useful insights into fault detection and power system protection.

Furthermore, the methodology adopted in this project provides a systematic approach for studying fault behaviours in modern distributed power systems. The simulation model developed in MATLAB/Simulink helps in understanding the interaction between distributed generation units and the power network during unsymmetrical fault conditions. The obtained results can also be useful for improving fault detection techniques, designing effective protection schemes, and enhancing the reliability and stability of DG integrated power systems. This methodology may further serve as a reference for future research related to microgrid protection, renewable energy integration, and advanced fault analysis studies.

2.4 Results and Discussion

The developed DG integrated 13-bus power system was simulated successfully in the MATLAB/Simulink environment to study the behaviour of the network during normal and fault conditions. The simulation mainly focused on analysing the impact of an ABG fault on voltage profile, current variation, and overall system stability.

Under normal operating conditions, the power system showed stable performance with proper power flow across all buses. The distributed generation unit supplied electrical power smoothly to the connected loads through the transmission network. Voltage magnitude at different buses remained within acceptable operating limits, and the current flow through the transmission lines was balanced. The interconnected network operated continuously without any abnormal disturbance before the fault was introduced.

To examine the system response during disturbance, an ABG fault was applied in the network using the fault block available in MATLAB/Simulink. The fault was created by connecting Phase A and Phase B simultaneously to the ground for a short duration. As soon as the fault occurred, noticeable variations were observed in different electrical parameters of the system.

One of the major observations during simulation was the sudden rise in fault current at the affected section of the network. The current waveform became highly distorted during the fault interval, indicating the presence of abnormal operating conditions. At the same time, bus voltages near the fault location experienced a sharp drop because of the imbalance created in the system.

The simulation results also showed that the fault affected the power transfer capability of the network. Due to the occurrence of the ABG fault, power flow through some transmission lines became unstable for a temporary period. The disturbance propagated across nearby buses and influenced the performance of connected loads as well as the distributed generation unit.

The DG source continued supplying power during the fault condition, but fluctuations in voltage and current were observed throughout the system. This behaviour indicates that unsymmetrical faults can significantly affect the operational stability of DG integrated networks if proper protection mechanisms are not provided.

Another important observation from the simulation was the response of the monitoring and protection components. The measurement blocks successfully detected abnormal changes in electrical parameters during the fault period. These observations demonstrate the importance of continuous monitoring in identifying disturbances and improving system protection.

The waveform analysis obtained from scopes and monitoring blocks clearly indicated the difference between healthy and faulty operating conditions. During healthy operation, the voltage and current signals remained stable and balanced, whereas fault conditions produced irregular waveforms and disturbances in the network.

The overall simulation study confirmed that the ABG fault creates significant stress on the DG integrated power system and can reduce system stability if faults are not detected and isolated quickly. The results obtained from this work can be useful for designing better protection strategies and improving fault management techniques in modern distributed power systems.

2.4.1 Important Observations from Simulation

- Stable voltage and current were observed during normal operating conditions.
- Fault current increased rapidly after the occurrence of the ABG fault.
- Voltage dip occurred at buses located near the faulted section.
- Power flow became temporarily disturbed during the fault period.
- Current and voltage waveforms showed imbalance under fault conditions.
- Monitoring blocks successfully detected abnormal system behaviours.
- The DG integrated system remained operational but experienced temporary instability during the fault.

2.4.2 Discussion

The simulation results indicate that fault analysis is essential for improving the reliability and protection of DG integrated power systems. Unsymmetrical faults such as ABG faults can create severe disturbances within the network and affect both generation and load performance. Therefore, proper fault detection and fast isolation techniques are necessary to prevent equipment damage and maintain uninterrupted power supply.

The MATLAB/Simulink model developed in this project provides a practical approach for studying fault behaviour in distributed electrical networks. The analysis performed in this

work can further be extended for developing intelligent fault detection schemes and advanced protection systems for future smart grid applications.

2.5 Conclusion

This chapter presented the modelling and analysis of a DG integrated 13-bus power system developed in the MATLAB/Simulink environment for studying fault conditions. The system was designed by integrating distributed generation units, transmission lines, transformers, loads, and monitoring components to simulate the behaviour of a practical electrical network.

An ABG fault condition was introduced in the system to analyse the effect of unsymmetrical faults on overall network performance. During simulation, noticeable disturbances were observed in voltage profile, current waveform, and power flow throughout the affected section of the system. The fault caused imbalance in electrical parameters and temporarily affected the stability of the network.

The simulation results demonstrated that the occurrence of faults can significantly influence the operation of DG integrated power systems if proper monitoring and protection techniques are not applied. The monitoring blocks used in the model successfully detected abnormal variations in system parameters during the fault period, which helped in understanding the behaviour of the network under disturbed conditions. The study also showed that distributed generation units improve system reliability by supporting power supply during disturbances, although fault conditions still create temporary instability in the network. Proper fault detection and isolation are therefore necessary for maintaining safe and continuous operation of the system.

Overall, the developed MATLAB/Simulink model provided a useful platform for analysing fault behaviour in DG integrated power systems. The work carried out in this chapter can further be extended for advanced fault detection methods, intelligent protection systems, and smart grid applications in future power networks.

CHAPTER 3

Fault Analysis and Performance Evaluation of DG Integrated Power System

3.1 Introduction

The reliable operation of a power system largely depends on its ability to withstand disturbances and maintain stability during abnormal conditions. In DG integrated power systems, fault conditions can create serious disturbances in voltage, current, and power flow, which may affect the performance of connected loads as well as generating units. Therefore, proper fault analysis becomes necessary for understanding system behaviours and improving protection mechanisms in modern distributed networks.

This chapter mainly focuses on the analysis of fault conditions in the developed 13-bus DG integrated power system using MATLAB/Simulink. The performance of the system is examined under both normal and faulty operating conditions by observing different electrical parameters such as voltage, current, and power flow across the network.

To study the fault response of the system, an ABG fault condition was introduced using the fault block integrated within the simulation model. The fault was created by connecting Phase A and Phase B simultaneously to ground for a specific duration during simulation. Since the fault is unsymmetrical in nature, it produces imbalance in the three-phase system and affects the stability of the network. The simulation results obtained from the model help in analysing the effect of the fault on different buses, transmission lines, and distributed generation units connected within the system. Variations in current magnitude, voltage profile, and waveform characteristics are observed carefully to understand the behaviours of the network during the fault period.

This chapter also discusses how the DG integrated system responds during disturbance conditions and how monitoring blocks help identify abnormal operating situations. The waveform analysis carried out in this study provides useful information regarding fault impact, system reliability, and the need for efficient protection techniques in distributed power systems. The main objective of this chapter is to evaluate the performance of the developed DG integrated network during ABG fault conditions and study the stability of the system under disturbance. The analysis performed in this chapter can further help in developing improved fault detection and protection methods for future smart grid and microgrid applications.

3.2 Fault Simulation in DG Integrated Power System

The fault simulation was carried out in the developed 13-bus DG integrated power system using the MATLAB/Simulink environment. The main purpose of the simulation was to study the behaviour of the network during abnormal operating conditions and observe the effect of fault disturbances on different electrical parameters of the system.

The proposed model consists of interconnected buses, distributed generation units, transformers, transmission lines, loads, and monitoring blocks arranged to represent a practical distributed power network. Under normal operating conditions, the DG source supplies power to the connected loads while maintaining stable voltage and current throughout the system.

To analyse the fault response, a fault block was connected within the network at a selected location in the system. In this project, an ABG fault was introduced by connecting Phase A and Phase B simultaneously to the ground during simulation. The fault was applied for a short time interval in order to observe the transient behaviour of the power system under disturbance conditions. When the fault was initiated, the balance of the three-phase system was disturbed immediately. Large fault current started flowing through the affected section of the network, and voltage magnitude at nearby buses decreased significantly. Because the fault involved two phases and ground, the system experienced unsymmetrical operating conditions, which resulted in uneven distribution of current and voltage across the network.

The distributed generation unit continued supplying power during the disturbance; however, fluctuations were observed in system parameters during the fault duration. The monitoring blocks connected to different buses recorded the changes in voltage and current waveforms, which helped in analysing the fault behaviours more effectively.

The simulation also demonstrated the effect of the fault on transmission lines and connected loads. Temporary instability in power transfer was observed during the fault period, especially near the fault location. After removal of the fault, the system gradually returned toward stable operating conditions. The complete fault analysis was performed using waveform observation through scope blocks available in MATLAB/Simulink. The obtained waveforms clearly showed the difference between healthy operating conditions and faulty conditions within the DG integrated network.

3.2.1 Observations During Fault Simulation

- Sudden rise in fault current was observed after the occurrence of the ABG fault.
- Voltage dip occurred at buses connected near the faulted section.
- Current and voltage waveforms became unbalanced during the disturbance.
- Temporary instability in power flow was noticed during the fault interval.
- The DG source continued operating but experienced fluctuations in output parameters.
- Monitoring blocks successfully detected abnormal operating conditions in the system.




Figure 3.1(a): Three-Phase Current under Normal Operating Condition

The figure shows the balanced three-phase current waveform obtained during normal operating conditions of the DG integrated power system, indicating smooth current flow and stable system behaviour.




Figure 3.1(b): Three-Phase Voltage under Normal Operating Condition

The figure illustrates the three-phase voltage waveform under normal operating conditions, where the voltage remains comparatively stable with minor distortions due to line impedance and load fluctuations.

3.3 Voltage Analysis During Fault Condition

Voltage stability is one of the most important factors in maintaining the reliable operation of a power system. During normal operating conditions, the voltage at different buses of the DG integrated network remained nearly stable and balanced. The distributed generation source supplied sufficient power to the connected loads, and the voltage profile across the 13-bus system stayed within acceptable operating limits.

To examine the effect of disturbances on the system, an ABG fault was introduced in the network during simulation. The fault created an imbalance in the three-phase system by connecting Phase A and Phase B with ground for a short duration. As soon as the fault occurred, noticeable changes in bus voltages were observed throughout the system.

The buses located near the fault point experienced a sudden drop in voltage magnitude during the fault interval. This voltage dip occurred because of the large fault current flowing through the faulted section of the network. Compared to normal operating conditions, the voltage waveform became distorted and unbalanced due to the unsymmetrical nature of the ABG fault.

The simulation results also indicated that the effect of the disturbance gradually reduced for buses located farther from the fault location. However, temporary fluctuations were still observed in different parts of the network because all buses were electrically interconnected through transmission lines and transformers.

The voltage waveform obtained from the MATLAB/Simulink scope clearly showed the transition between healthy and faulty operating conditions. Before the fault occurrence, the waveform remained smooth and balanced. During the fault period, the voltage magnitude decreased sharply and waveform irregularities appeared in the affected phases. After the fault was cleared, the voltage gradually recovered toward normal operating conditions.

The distributed generation unit helped support the network during the disturbance by maintaining partial voltage stability within the system. Even though temporary imbalance was observed, the DG integrated system continued operating throughout the simulation period.

The analysis of voltage response during fault conditions is important because excessive voltage variation can affect connected loads, reduce power quality, and damage sensitive electrical equipment. Therefore, proper monitoring and fast fault isolation are necessary to maintain stable voltage conditions in distributed power systems.

3.3.1 Observations from Voltage Analysis

- Stable voltage profile was observed during healthy operating conditions.
- Significant voltage dip occurred immediately after the ABG fault was introduced.
- Voltage imbalance was more severe near the faulted bus section.
- Waveform distortion appeared during the fault interval.
- Voltage gradually recovered after fault clearance.
- The DG source provided partial voltage support during the disturbance.




Figure 3.2: Three-Phase Voltage under Fault Condition

The waveform illustrates the variation in bus voltage before, during, and after the occurrence of the ABG fault in the DG integrated 13-bus power system.

3.4 Current Analysis During Fault Condition

Current analysis plays an important role in understanding the severity and impact of faults in a power system. Under normal operating conditions, the current flowing through the transmission lines and buses of the DG integrated network remained balanced and within the permissible operating range. The distributed generation source supplied power smoothly to the connected loads, resulting in stable current flow throughout the system.

During the simulation process, an ABG fault was introduced in the network to examine the response of the system under abnormal conditions. The fault caused Phase A and Phase B to come in contact with the ground, which immediately disturbed the balance of the three-phase system. As soon as the fault occurred, a sudden increase in current magnitude was observed in the affected section of the network. The fault current became significantly higher than the normal operating current because the fault created a low-resistance path within the system. The increase in current was most noticeable near the fault location, while comparatively smaller disturbances were observed at buses farther from the faulted section.

The current waveforms obtained from the MATLAB/Simulink scopes clearly showed abnormal variations during the fault period. Before the occurrence of the fault, the three-phase currents were nearly balanced and followed a stable waveform pattern. However, once the ABG fault was introduced, the current waveform became distorted and irregular because of the unsymmetrical nature of the fault. The simulation also showed that the distributed generation unit continued supplying current to the network during the disturbance period. Although the DG source supported system operation, fluctuations in current flow were still observed due to the sudden fault condition. These fluctuations affected the stability of power transfer within the interconnected buses and transmission lines.

Another important observation from the analysis was that the fault current reduced gradually after the fault was cleared from the system. The waveform slowly returned toward normal operating conditions once the disturbance was removed. This recovery behaviour indicated that the system was capable of regaining stability after temporary disturbances.

The current analysis carried out in this study helps in understanding the effect of unsymmetrical faults on distributed power systems. Excessive fault current can damage transformers, transmission lines, generators, and other connected electrical equipment if proper protection mechanisms are not implemented. Therefore, accurate fault detection and quick isolation are essential for improving the safety and reliability of DG integrated networks.

3.4.1 Observations from Current Analysis

- Balanced current flow was observed during normal operating conditions.
- Fault current increased rapidly after the occurrence of the ABG fault.
- Current waveform became distorted during the fault interval.
- Maximum current disturbance was observed near the fault location.
- The DG source continued supplying power during the fault condition.
- Current magnitude gradually returned to normal after fault clearance.
- Temporary instability in power transfer was observed during the disturbance.




Figure 3.3: Three-phase current waveform observed during the ABG fault condition showing sudden current imbalance and disturbance in the DG integrated power system

3.5 Performance Evaluation of DG Integrated Power System

The performance of the developed DG integrated 13-bus power system was evaluated under both normal and fault operating conditions using MATLAB/Simulink simulation. The analysis mainly focused on observing the stability of the system, behaviour of electrical parameters, and the ability of the distributed generation source to support the network during disturbances.

Under normal operating conditions, the system showed stable performance with balanced voltage and current distribution across all buses. Power transfer between different sections of the network remained smooth, and the connected loads received continuous electrical supply without any major disturbance. The distributed generation unit effectively supported the network by maintaining stable operating conditions throughout the simulation period.

When the ABG fault was introduced into the system, temporary disturbances were observed in different parts of the network. The occurrence of the fault affected voltage stability, increased fault current, and disturbed the normal flow of power through the transmission lines. Despite these disturbances, the DG integrated system continued operating during the fault interval, which demonstrated the reliability of distributed generation support in modern power networks. The simulation results indicated that the buses located closer to the fault

experienced larger voltage drops and current fluctuations compared to buses located farther away. This behaviour showed that the severity of the disturbance depends on the location of the fault within the network. The transmission lines connected near the faulted section also experienced temporary stress because of the sudden rise in current flow.

Another important observation during performance evaluation was the response of the monitoring blocks integrated into the system. These blocks successfully detected abnormal changes in electrical parameters during the fault period. The monitoring process helped identify the occurrence of the fault and provided useful information regarding system behaviour under disturbed conditions. The distributed generation unit played a significant role in improving system reliability during the disturbance. Even though fluctuations were observed during the fault interval, the DG source continued supplying power to the connected network, which helped reduce the impact of the fault on overall system operation.

The simulation study also highlighted the importance of proper fault detection and protection mechanisms in DG integrated power systems. Without effective protection, excessive fault current and voltage instability may damage electrical equipment and reduce system reliability. Therefore, fast detection and isolation of faults are necessary for maintaining stable operation of distributed power networks.

Overall, the performance evaluation confirmed that the developed DG integrated 13-bus system was capable of operating under both healthy and fault conditions while maintaining partial system stability. The analysis carried out in this project provides a better understanding of fault behaviour and can be useful for improving future protection and monitoring techniques in distributed electrical systems.

3.5.1 Important Findings from Performance Evaluation

- The system operated normally under healthy operating conditions.
- Distributed generation improved power reliability during disturbances.
- The ABG fault caused temporary instability in voltage and current.
- Buses near the fault location experienced more severe disturbances.
- Monitoring blocks successfully detected abnormal operating conditions.
- The system gradually recovered after fault removal.
- Proper fault protection is necessary for safe and reliable operation of DG integrated networks.




Figure 3.4(a): Three-Phase Current under Normal Operating Condition




Figure 3.4(b): Three-Phase Current under ABG Fault Condition




Figure 3.4(c): Three-Phase Voltage under Normal Operating Condition




Figure 3.4(d): Three-Phase Voltage under ABG Fault Condition

The above waveforms present a comparison between the normal operating condition and the ABG fault condition in the DG integrated 13-bus power system. Under normal conditions, the three-phase voltage and current waveforms remain comparatively balanced and follow a near-sinusoidal pattern, indicating stable system operation and proper coordination between generation and load demand.

After the occurrence of the ABG fault, noticeable disturbances appear in both voltage and current waveforms. The fault condition causes imbalance among the three phases, resulting in waveform distortion, sudden fluctuation in current magnitude, and reduction in voltage level during the disturbance interval. The changes are more prominent in the affected phases because the fault directly involves Phase A and Phase B with ground. The current waveform under fault condition shows an abnormal rise in magnitude due to the sudden increase in fault current flowing through the network. Similarly, the voltage waveform experiences instability and irregular variations because of the unsymmetrical nature of the disturbance. These variations indicate the effect of the fault on system stability and power transfer capability. The comparison between normal and fault conditions clearly demonstrates how electrical disturbances influence the operation of the DG integrated network. The obtained results also show that the distributed generation source continues supporting the system during the fault period, although temporary instability is observed within the network.

Overall, the simulation outputs verify that the developed MATLAB/Simulink model successfully represents both healthy and disturbed operating conditions of a practical

distributed power system and can effectively be used for fault analysis and performance evaluation studies.

3.6 Discussion of Results

The simulation study carried out on the DG integrated 13-bus power system provided a clear understanding of how fault conditions influence the stability and performance of a distributed electrical network. From the obtained waveforms and simulation outputs, it was observed that the system behaved normally during healthy operating conditions, whereas noticeable disturbances appeared immediately after the introduction of the ABG fault.

One of the major observations from the analysis was the sudden imbalance created in the network when Phase A and Phase B were connected to ground. The fault disturbed the normal three-phase operation and produced irregular variations in both voltage and current throughout the affected section of the system. The buses located close to the fault experienced larger disturbances compared to buses situated farther away, which indicates that fault location has a direct impact on system behaviour. During the fault interval, the voltage profile of the network dropped considerably near the faulted bus. At the same time, the current magnitude increased sharply because of the low-resistance path created during the fault condition. These changes affected the overall power transfer capability of the network and caused temporary instability within the system.

Another important observation was related to the performance of the distributed generation source during the disturbance. Even after the occurrence of the fault, the DG unit continued supplying power to the system, although fluctuations were visible in the output parameters. This shows that distributed generation improves system reliability and supports the network during abnormal operating situations. However, the simulation also demonstrated that DG integration alone cannot completely eliminate the effect of faults unless proper protection mechanisms are implemented.

The monitoring and measurement blocks connected within the MATLAB/Simulink model responded effectively during the disturbance period. The abnormal changes in current and voltage waveforms were clearly detected through the scope outputs, making it easier to identify the occurrence of the fault and analyse its impact on the network. This highlights the importance of continuous monitoring in modern distributed power systems. The waveform analysis also revealed a clear difference between normal and faulty operating conditions. Under healthy conditions, the voltage and current signals remained balanced and stable. In contrast, the ABG fault produced distorted and unbalanced waveforms, which confirmed the unsymmetrical nature of the disturbance.

From the overall simulation results, it can be understood that fault conditions significantly influence the operational stability of DG integrated systems. If faults are not detected and isolated quickly, they may reduce power quality, damage connected equipment, and interrupt power supply to consumers. Therefore, advanced protection and fault detection techniques are necessary for improving the safety and reliability of future distributed electrical networks.

The analysis performed in this project also demonstrates how MATLAB/Simulink can be used effectively for studying fault behaviour in power systems without requiring a physical

setup. The developed model provides a practical platform for understanding system response during disturbances and can further be extended for research related to smart grids, microgrids, and intelligent fault protection systems.

3.7 Conclusion

This chapter presented the fault analysis and performance evaluation of the developed DG integrated 13-bus power system using MATLAB/Simulink. The behaviour of the system was studied under both normal and fault conditions to understand the impact of disturbances on overall network operation.

An ABG fault was introduced into the system to examine the response of voltage, current, and power flow during abnormal operating conditions. The simulation results showed that the occurrence of the fault created imbalance in the network and caused noticeable variations in electrical parameters. A sudden increase in fault current and a temporary drop in bus voltage were observed during the fault interval, which affected the stability of the interconnected system.

The waveform analysis obtained from the MATLAB/Simulink model clearly demonstrated the difference between healthy and faulty operating conditions. During normal operation, the voltage and current waveforms remained balanced and stable, whereas distorted and unbalanced waveforms appeared after the fault was introduced. The buses located near the faulted section experienced comparatively larger disturbances than other parts of the network.

The study also showed that the distributed generation unit continued supporting the system during the disturbance period, which helped maintain partial system stability and improve reliability. However, the results indicated that fault conditions can still create significant operational stress in DG integrated systems if proper protection mechanisms are not available. Another important outcome of this work was the successful monitoring of system behaviour using measurement and scope blocks integrated within the simulation model. These monitoring units effectively detected abnormal variations in electrical parameters and provided useful information for analysing fault conditions within the network.

Overall, the simulation results confirmed that fault analysis is essential for improving the protection, reliability, and stability of distributed power systems. The developed DG integrated model provides a practical approach for studying unsymmetrical fault behaviour and can further be extended for advanced fault detection, intelligent protection schemes, and smart grid applications in future electrical power networks.

CHAPTER 4

Conclusion and Future Scope

4.1 Conclusion

This project presented the development of a DG integrated 13-bus power system for studying fault conditions using the MATLAB/Simulink environment. The complete network was designed by connecting distributed generation units, buses, transformers, transmission lines, loads, and protection components in order to represent a practical distributed power structure.

The main objective of the work was to observe the effect of an ABG fault on the overall operation of the interconnected system. For this purpose, a fault block was introduced into the network, where Phase A and Phase B were connected to ground during simulation. The generated results clearly indicated that the fault produced disturbances in voltage profile, current flow, and power transfer across different sections of the system.

During healthy operating conditions, the system maintained proper coordination between generation and load demand. However, once the fault was applied, sudden fluctuations appeared in electrical quantities, particularly near the affected buses. The rise in fault current and reduction in voltage level showed the seriousness of unsymmetrical faults in distributed electrical networks.

The simulation outputs also demonstrated that the distributed generation source continued supplying power even during the disturbance period, which helped maintain partial continuity of supply within the network. At the same time, the study revealed that fault conditions can still create operational stress and instability if fast protection mechanisms are not available.

The monitoring blocks connected within the MATLAB/Simulink model successfully captured abnormal variations during the disturbance interval. The obtained waveforms provided a clear understanding of how the interconnected system responded before, during, and after the fault occurrence.

Another important outcome of this project was the practical understanding gained regarding fault occurrence in DG integrated systems. The work helped in understanding how disturbances influence interconnected buses, transmission paths, and generating units in a distributed network.

Overall, the project achieved its intended goal of studying fault conditions in a DG integrated power system and understanding the impact of ABG faults on network operation. The developed simulation model can further serve as a useful reference for future studies related to distributed generation, fault protection, and modern smart power systems.

4.2 Future Scope

The present work can be further improved in several areas to make the system more efficient, intelligent, and suitable for advanced power system applications. Since distributed power networks are continuously evolving, there is significant scope for extending this project in future research and practical implementation.

Some possible future enhancements are listed below:

- Integration of renewable energy sources such as solar and wind energy into the existing DG network.
- Implementation of intelligent fault identification methods using Artificial Intelligence and Machine Learning techniques.
- Development of automatic fault isolation systems for reducing disturbance duration.
- Use of advanced relays and adaptive protection schemes for faster system response.
- Comparative study of different fault types including LG, LL, LLG, and three-phase faults.
- Real-time hardware implementation of the proposed model for practical verification.
- Addition of IoT-based monitoring systems for remote supervision and control.
- Improvement of voltage regulation and power quality using advanced control methods.
- Expansion of the system for smart grid and microgrid applications with bidirectional power flow capability.

The future improvements mentioned above can help create a more reliable and intelligent distributed power system capable of handling complex disturbances with better stability and protection performance.

Reference

- [1] M. Salehi, M. Zolfaghari, and J. M. Maritz, "A Simple Approach to Detect High Impedance Fault Using Morphological Gradient Edge Detector," *IEEE Access*, vol. 12, pp. 11024–11034, Jan. 2024.
- [2] M. Zolfaghari and G. B. Gharehpetian, "Affine Projection-like Optimal Control of UIPC in Networked Microgrids with Controllable Loads," *IET Control Theory & Applications*, vol. 17, no. 8, pp. 1002–1014, 2023.
- [3] M. Zolfaghari, G. B. Gharehpetian, F. Blaabjerg, and A. Anvari-Moghaddam, "Model Reference Adaptive Control of UIPC in Islanded Hybrid Microgrids with Flexible Loads and Storages," in *Proceedings of the IEEE International Conference on Environment and Electrical Engineering (EEEIC)*, 2021, pp. 1–5.
- [4] M. Zolfaghari, G. B. Gharehpetian, and A. Anvari-Moghaddam, "Quasi-Luenberger Observer-Based Robust DC Link Control of UIPC for Flexible Power Exchange Control in Hybrid Microgrids," *IEEE Systems Journal*, vol. 15, no. 2, pp. 2845–2854, 2021.
- [5] M. Zolfaghari, S. H. Hosseini, S. H. Fathi, M. Abedi, and G. B. Gharehpetian, "A New Power Management Scheme for Parallel-Connected PV Systems in Microgrids," *IEEE Transactions on Sustainable Energy*, vol. 9, no. 4, pp. 1605–1615, Oct. 2018.
- [6] M. Zolfaghari, M. Abedi, and G. B. Gharehpetian, "Power Flow Control of Interconnected AC–DC Microgrids in Grid-Connected Hybrid Microgrids Using Modified UIPC," *IEEE Transactions on Smart Grid*, vol. 10, no. 6, pp. 6298–6307, Nov. 2019.
- [7] M. Zolfaghari, G. B. Gharehpetian, and M. Abedi, "A Repetitive Control-based Approach for Power Sharing Among Boost Converters in DC Microgrids," *Journal of Operation and Automation in Power Engineering*, vol. 7, no. 2, pp. 168–175, Oct. 2019.
- [8] S. A. Taher, M. Zolfaghari, C. Cho, M. Abedi, and M. Shahidehpour, "A New Approach for Soft Synchronization of Microgrid Using Robust Control Theory," *IEEE Transactions on Power Delivery*, vol. 32, no. 1, pp. 473–482, 2016.
- [9] S. A. Taher and M. Zolfaghari, "Designing Robust Controller to Improve Current-Sharing for Parallel-Connected Inverter-Based DGs Considering Line Impedance Impact in Microgrid Networks," *International Journal of Electrical Power & Energy Systems*, vol. 63, pp. 625–644, 2014.
- [10] M. Zolfaghari, G. B. Gharehpetian, F. Blaabjerg, and A. Anvari-Moghaddam, "A New Robust Nonlinear Control Strategy for UIPC in Isolated Hybrid Microgrids," *International Journal of Electrical Power & Energy Systems*, vol. 155, pp. 1–9, 2024.
- [11] S. Chowdhury, S. P. Chowdhury, and P. Crossley, *Microgrids and Active Distribution Networks*, London, U.K.: The Institution of Engineering and Technology, 2009.

[12] J. A. Peças Lopes, C. L. Moreira, and A. G. Madureira, “Defining Control Strategies for Microgrid’s Islanded Operation,” *IEEE Transactions on Power Systems*, vol. 21, no. 2, pp. 916–924, May 2006.

[13] F. Katiraei and M. R. Iravani, “Power Management Strategies for a Microgrid with Multiple Distributed Generation Units,” *IEEE Transactions on Power Systems*, vol. 21, no. 4, pp. 1821–1831, Nov. 2006.

[14] A. Tuladhar, H. Jin, T. Unger, and K. Mauch, “Control of Parallel Inverters in Distributed AC Power Systems with Consideration of Line Impedance Effect,” *IEEE Transactions on Industry Applications*, vol. 36, no. 1, pp. 131–138, Jan. 2000.

[15] R. Teodorescu, M. Liserre, and P. Rodríguez, *Grid Converters for Photovoltaic and Wind Power Systems*, Chichester, U.K.: John Wiley & Sons, 2011.

Plagiarism Report

ORIGINALITY REPORT			
7%	4%	5%	1%
SIMILARITY INDEX	INTERNET SOURCES	PUBLICATIONS	STUDENT PAPERS
PRIMARY SOURCES			
1	Ramesh Bansal. "Power System Protection in Smart Grid Environment", CRC Press, 2019 Publication	1%	
2	Submitted to University of Sunderland Student Paper	1%	
3	Mahdi Zolfaghari, Mehrdad Abedi, Gevork B. Gharehpetian. "Power Flow Control of Interconnected AC-DC Microgrids in Grid-Connected Hybrid Microgrids Using Modified UIPC", IEEE Transactions on Smart Grid, 2019 Publication	<1%	
4	vbn.aau.dk Internet Source	<1%	
5	"[Front matter]", 2017 Smart Grid Conference (SGC), 2017 Publication	<1%	
6	"Advances in Electrical Control and Signal Systems", Springer Science and Business Media LLC, 2020 Publication	<1%	
7	joape.uma.ac.ir Internet Source	<1%	
8	dspace.iiti.ac.in Internet Source	<1%	
9	Submitted to The Scientific & Technological Research Council of Turkey (TUBITAK) Student Paper	<1%	

10	1library.net Internet Source	<1%
11	stax.strath.ac.uk Internet Source	<1%
12	Mahdi Zolfaghari, Venera Nurmanova, Mehdi Bagheri, Gevork B. Gharehpetian. "Adaptive Gain-Regulating-based Control of Parallel-Connected Γ -Z-Source Power Converters in Hybrid Microgrids", 2020 9th International Conference on Renewable Energy Research and Application (ICRERA), 2020 Publication	<1%
13	"Smart Grids and Microgrids", Wiley, 2022 Publication	<1%
14	Changyu Liu, Xiaojun Wang, Zhao Liu, Dahai Zhang, Guomin Luo, Jinghan He. "A data-driven high impedance fault detection framework for distribution network based on improved temporal convolutional network", International Journal of Electrical Power & Energy Systems, 2026 Publication	<1%
15	Submitted to University of Technology, Sydney Student Paper	<1%
16	Submitted to University of South Africa Student Paper	<1%
17	Submitted to University of Liverpool Student Paper	<1%
18	www.ias.ac.ir Internet Source	<1%
19	Salman Amirkhan, Masoud Radmehr, Mohammad Rezanejad, Shahab Khormali. "A	<1%

robust control technique for stable operation
of a DC/AC hybrid microgrid under
parameters and loads variations",
International Journal of Electrical Power &
Energy Systems, 2020

Publication

- | | | |
|-----------------|--|-----|
| 20 | Mahdi Zolfaghari, Seyed Hossein Hosseini, Hamid Fathi, Mehrdad Abedi, Gevork B. Gharehpetian. "A New Power Management Scheme for Parallel-Connected PV systems in Microgrids", IEEE Transactions on Sustainable Energy, 2018 | <1% |
| Publication | | |
| 21 | core.ac.uk | <1% |
| Internet Source | | |
| 22 | repository.charlotte.edu | <1% |
| Internet Source | | |
| 23 | www.csemag.com | <1% |
| Internet Source | | |
| 24 | www.researchgate.net | <1% |
| Internet Source | | |
| 25 | Mahdi Zolfaghari, Gevork B. Gharehpetian. "Isolated UIPC-intertied AC-DC microgrids operation with novel dynamic flexible loads model", Electric Power Systems Research, 2023 | <1% |
| Publication | | |
| 26 | eprints.ums.edu.my | <1% |
| Internet Source | | |
| 27 | journals.usb.ac.ir | <1% |
| Internet Source | | |
| 28 | ualberta.scholaris.ca | <1% |
| Internet Source | | |

29	www.scopus.com Internet Source	<1%
30	Abhay Sanatan Satapathy, Sthitapragyan Mohanty, Asit Mohanty, Reji Kumar Rajamony et al. "Emerging technologies, opportunities and challenges for microgrid stability and control", Energy Reports, 2024 Publication	<1%
31	P.K. Koner, G. Ledwich. "SRAT–Distribution Voltage Sags and Reliability Assessment Tool", IEEE Transactions on Power Delivery, 2004 Publication	<1%
32	Suresh Ukarande, Shailesh R. Nikam, Makarand G. Kulkarni, Nandana A. Prabhu et al. "Technologies for Energy, Agriculture, and Healthcare - 2 International Conference on Technologies for Energy, Agriculture, and Healthcare (ICTEAH 2025)", CRC Press, 2026 Publication	<1%
33	dokumen.pub Internet Source	<1%
34	espace.etsmtl.ca Internet Source	<1%
35	etj.uotechnology.edu.iq Internet Source	<1%
36	iris.unipa.it Internet Source	<1%
37	linknovate.com Internet Source	<1%
38	scholar.archive.org Internet Source	<1%
39	tudr.thapar.edu Internet Source	<1%

40	webx.ubi.pt Internet Source	<1 %
41	www.mdpi.com Internet Source	<1 %
42	Walid M. Nassar, Olimpo Anaya-Lara, Khaled H. Ahmed. "A new adaptive instantaneous average current sharing technique for circulating current minimization among parallel converters in a LV DC-microgrid", International Journal of Electrical Power & Energy Systems, 2022 Publication	<1 %
43	doaj.org Internet Source	<1 %
44	Submitted to University of Sheffield Student Paper	<1 %

Exclude quotes Off

Exclude matches Off

Exclude bibliography On