

Firmware Release Notes

Edge module firmware, releases 4.2 to 4.7

4.7, released 8 July 2026

- Sub second sampling on the main incomer for harmonic capture.
- Reduced buffer flush interval, cutting data loss on network drops from 40 seconds to 4.
- Fixed a rare timestamp drift on modules running over 90 days without a reboot.

4.6, released 2 June 2026

- Over the air update support, removing the need for a site visit for firmware.
- Added phase imbalance calculation at the edge instead of in the cloud.

4.5, released 21 April 2026

- Support for the VT 210 higher range clamp used on incomers above 800 amps.
- Local storage extended to 72 hours of buffered readings.

4.3 and 4.4, February and March 2026

Power quality event capture, watchdog hardening, and a fix for a boot loop seen on nine modules exposed to sustained supply flicker.

Update policy

Firmware is staged across 5 percent of the fleet for seven days before general release. No release has been rolled back since 4.1.