



LEADWAY MARINE SERVICES LIMITED

Specialized in Survey / Servicing of Life Savings Application (LSA) Fire Fighting Equipment (FFE)
Navigational Aid, Inflatable Liferafts, Life Boat/Davit/Winch Inspection, Calibration of Equipments,
Helideck Equipment and Air/Foam Quality Test, Fire Hose Pressure Testing & Exports & Imports.

27

CERTIFICATE OF INSPECTION

SELF CONTAINED BREATHING APPARATUS (SCBA)

DATE	OWNERS	SHIP	REGISTRY PORT	CERT NO.
21/08/2021	ELSHCON NIGERIA LIMITED	ENL SUPERIOR	LAGOS	LMSL/COI 20312052

DESCRIPTION TYPE	DESCRIPTION OF WORKING CODE (PERFORMED/RECOMMENDED)
• EEBD • MEDICAL OXYGEN ✓ BREATHING APPARATUS	1= Breathing Apparatus Refilled 2= Breathing Apparatus Inspected (agent & propellant gas) 3= Breathing apparatus Hydrostatically tested 4= Breathing Apparatus with Mask 5= Breathing Apparatus Mask Repair 6= New Breathing Apparatus 7= Rejected 8= Label Attached

THIS IS TO CERTIFY THAT WE HAVE INSPECTED, RECHARGED AND REPAIRED (WHERE NECESSARY) THE BREATHING APPARATUS (BA), IN ACCORDANCE WITH REQUIREMENT FROM SOLAS, MANUFACTURER AND IMO RESOLUTION STANDARD, THE CHAPTER II -2, SOLAS 1974, PROTOCOL 1988 REGULATIONS 6 & 7. IT CONTENT WAS LEFT IN GOOD WORKING ORDER AND EACH ONE PROVIDED WITH NEW UP TO DATE INSPECTION LABEL AS ENLISTED HERE UNDER. THE EQUIPMENT MUST BE REGULARLY CHECKED, IF USED COMPLETELY OR PARTIALLY MUST BE RECHARGED AND REFILLED.

NO	SERIAL NO	MAKER	WORKING PRESSURE	TEST PRESSURE	LAST HYDRO TEST	WORKING CODE	REMARK
1	000048	YEAN	300 BAR	450 BAR	04/2019	1,2,4,8	OK
2	000361	YEAN	300 BAR	450 BAR	04/2019	1,2,4,8	OK
3	663204	JIANGBO	300 BAR	450 BAR	04/2019	1,2,4,8	OK
4	665955	JIANGBO	300 BAR	450 BAR	04/2019	1,2,4,8	OK

	FACE MASK	BREATHING VALVE	REGULATORY UNIT AND HOSE	BLACK PLAT AND HARNESS	FUNCTION TEST BY TEST EQUIPMENT	CYLINDER SERVICE/CHART REFERENCE INSPECTION (B1) RECHARGED (B1) TESTED (B2)		
1	YES	YES	YES	YES	YES	YES	YES	YES
2	YES	YES	YES	YES	YES	YES	YES	YES
3	YES	YES	YES	YES	YES	YES	YES	YES
4	YES	YES	YES	YES	YES	YES	YES	YES



REMARK: We hereby certify that on the above date, the above equipment was in good working order and it is fit for use in any Emergency

DATE OF SERVICE

21/08/2021

NEXT DUE DATE

20/08/2022


21/08/2021

INSPECTOR

118 Iwofe Road, Off Whimpey Junction, Port Harcourt – Nigeria

Tel: +234-8033094638, 08124999115, Fax: +234-84-230238