



THE LIGHT FIRE SERVICE

Beside Chelsea Filling Station, Trans-Woji, and Port Harcourt Rivers State.
+2348060005514

CERTIFICATE OF FIRE EXTINGUISHERS

This is to certify that the following cylinder/fire extinguishers on board **BOAT NAME: PRINCESS IBISO** inspected and subjected to hydraulic pressure test at **100/200 PSI/BAR** refilled and serviced where necessary and kept in a proper working condition as at today 30TH April 2021.

LIST OF CYLINDER/FIRE EXTINGUISHERS

S/N	MAKE	TEST PRESSURE	WORKING PRESSURE	EXTINGUISHER TYPE	SIZE	SERVICES DATE	NEST DUE DATE	REMARKS
1.	Angus 00366	27 BAR	12 BAR	DCP	6kg	30 th April. 2021	Sept 29 th 2021	OK
2.	Angus 26379	27 BAR	12 BAR	DCP	6kg	30 th April. 2021	Sept 29 th 2021	OK
3.	Angus 001022	27 BAR	12 BAR	DCP	6kg	30 th April. 2021	Sept 29 th 2021	OK
4.	Angus 15288	27 BAR	12 BAR	DCP	6kg	30 th April. 2021	Sept 29 th 2021	OK
5.	Angus NIL	27 BAR	12 BAR	DCP	6kg	30 th April. 2021	Sept 29 th 2021	OK

CERTIFIED BY
THE LIGHT FIRE SERVICE



USCG

Approved By Federal Fire Service
PPS/COF/No. A 0000092

SIGN:.....

