

Specialized in Survey / Servicing of Life Savings Application (LSA) Fire Fighting Equipment (FFE) Navigational Aid, Inflatable Liferafts, Life Boat/Davit/Winch Inspection, Calibration of Equipments, Helideck Equipment and Air/Foam Quality Test, Fire Hose Pressure Testing & Exports & Imports.

## CERTIFICATE OF INSPECTION EMERGENCY ESCAPE RREATHING DEVICE (FERD)

DATE	OWNERS	SHIP	REGISTRY PORT	CERT NO.
21/08/2021	ELSHCON NIGERIA LIMITED	ENL SUPERIOR	LAGOS	LMSL/COI 20312052

THIS IS TO CERTIFY THAT WE HAVE INSPECTED, RECHARGED AND REPAIRED (WHERE NECESSARY) ALL THE EEBD, IN ACCORDANCE WITH REQUIREMENT FROM SOLAS, MANUFACTURER AND IMO RESOLUTION STANDARD, THE CHAPTER II -2, SOLAS 1974, PROTOCOL 1988 REGULATIONS 6 & 7. IT CONTENT WAS LEFT IN GOOD WORKING ORDER AND EACH ONE PROVIDED WITH NEW UP TO DATE INSPECTION LABEL AS ENLISTED HERE UNDER. THE EQUIPMENT MUST BE REGULARLY CHECKED, IF USED COMPLETELY OR PARTIALLY MUST BE RECHARGED AND REFILLED.

DESCRIPTION TYPE	AIR BREATHING BOTTLE WORKS DESCRIPTION			
EEBD MEDICAL OXYGEN BREATHING APPARATUS	1= EEED Refilled 2= EEBD Inspected (agent & propellant gas) 3= EEBD Hydrostatically tested 4= EEBD with Mask 5= EEBD Mask Repair	6= New EESD 7= Rejected 8= Label Attached		

S/N	MAKE	SERIAL NO	FILL WEIGHT	TEST PRESSURE	WORKING	REMARK
1	JIANGBO	66533	200 BAR	300 BAR		OK
2	JIANGBO	668144	200 BAR	300 BAR	1,2,8	OK
3	JIANGBO	668230	200 BAK	300 BAR	1,2,8	OX
4	JIANGBO	668062	200 BAR	300 BAR	1,2,8	OK
5	JIANGBO	658192	200 BAR	300 BAR	1,2,8	OK

## PERFORMED ACTIVITIES

- Condition of Back Place, Carrying Harness and Cylinder Strap, Result Good
- Complete Function Test y Ds911/Quastor Test Stand Result: OK
- Testing of the Lung Demand Valve. Result: OK
- The Apparatus is in Conformity with the Test Protocol Result: OK

REMARK: We hereby certify that on the above date, the above equipment was in good working order and it is

fit for use in any Emergency

**DATE OF SERVICE** 

21/08/2021

**NEXT DUE DATE** 

20/08/2022



INSPECTOR