



THE LIGHT FIRE SERVICES

Beside Chelsea filling station, Trans woji, Port Harcourt Rivers-state
+234 8060005514, +234 8056807101

CERTIFICATE OF FIRE EXTINGUISHER

This is to certify that the following cylinder/fire extinguisher on board **PRINCESS IBISO**. Inspected and subjected to hydraulic pressure test at **100/200 PSI/BAR** refilling and services where necessary and kept in a proper working condition as today 15TH NOV 2021.

List of cylinder/fire extinguishers

S/N	MAKE	TEST PRESURE	WORKING PRESURE	EXTINGUISHER TYPE	SIZE	SERVICES DATE	NEXT DUE DATE	REMARK
1.	ANGUS	27BAR	12BAR	DCP	6KG	15 TH NOV 2021	14 TH APRIL 2022	OK
2.	ANGUS	27BAR	12BAR	DCP	6KG	15 TH NOV 2021	14 TH APRIL 2022	OK
3.	ANGUS	27BAR	12BAR	DCP	6KG	15 TH NOV 2021	14 TH APRIL 2022	OK
4.	ANGUS	27BAR	12BAR	DCP	6KG	15 TH NOV 2021	14 TH APRIL 2022	OK

THE LIGHT FIRE SERVICES



USCG

APPROVED BY FEDERAL FIRE SERVICES
PPS/COL/NO.A000092

SIGN.....





THE LIGHT FIRE SERVICES

Beside Chelsea filling station, Trans woji, Port Harcourt Rivers-state
+234 8060005514, +234 8056807101

CERTIFICATE OF FIRE EXTINGUISHER

This is to certify that the following cylinder/fire extinguisher on board
PRINCESS BISGAH. Inspected and subjected to hydraulic pressure test at
100/200 PSI/BAR refilling and services where necessary and kept in a proper
working condition as today 15TH NOV 2021.

List of cylinder/fire extinguishers

S/N	MAKE	TEST PRESURE	WORKING PRESURE	EXTINGUISHER TYPE	SIZE	SERVICES DATE	NEXT DUE DATE	REMARK
1.	ANGUS	27BAR	12BAR	DCP	6KG	15 TH NOV 2021	14 TH APRIL 2022	OK
2.	ANGUS	27BAR	12BAR	DCP	6KG	15 TH NOV 2021	14 TH APRIL 2022	OK
3.	ANGUS	27BAR	12BAR	DCP	6KG	15 TH NOV 2021	14 TH APRIL 2022	OK
4.	ANGUS	27BAR	12BAR	DCP	6KG	15 TH NOV 2021	14 TH APRIL 2022	OK
5.	ANGUS	27BAR	12BAR	DCP	6KG	15 TH NOV 2021	14 TH APRIL 2022	OK

THE LIGHT FIRE SERVICES



USCG

APPROVED BY FEDERAL FIRE SERVICES
PPS/COL/NO.A000092

SIGN.....

