

# FEDERAL MINISTRY OF HEALTH

## PORT HEALTH (QUARANTINE) SERVICES

RIVERS STATE

P.M.B. NO

6213



Date: 31/10//2019

Telephone 08035751763  
08097895855

Ref. No: PH/LAB/19/0151

### WATER ANALYSIS RESULT/CERTIFICATION

- A. Types of Water - Fresh Water Sample  
B. Source of sample - ENL SUPERIOR (BRIDGE)  
C. Aim of Analysis - To Determine Portability

#### RESULT:-

#### 1. PHYSICAL CHARACTERISTICS

- Colour - Colourless  
Taste - Unobjectionable  
Odour - Odourless

#### 2. PHYSIO CHEMICAL CHARATERISTICS

Physico-chemical Parameters	Units	Analytical Method	Result values	W.H.O Guideline Values
Colour	TCU	APHA 2120B	10.6	<15..00
Conductivity	Us/cm	APHA 2510-B	156.07	0-1000
Nitrate (as NO <sup>3</sup> )	Mg/L	APHA 418CDR2010	7.20	0-45
Total Iron (Fe <sup>2+</sup> )	Mg/L	ASTM D1068	0.26	0-0.30
Copper (Cu <sup>2+</sup> )	Mg/L	ASTM D1688	0.07	0-1.00
pH	-	APHA 4500HB	5.73	6.50-8.50
Residual Chlorine	Mg/L	APHA 4500-CLF	<0.01	0-0.30
Chromium (Cr <sup>6+</sup> )	Mg/L	ASTM D1687	ND	0-0.05
Fluoride (F <sup>-</sup> )	Mg/L	APHA 4500-FP	ND	0-45
Chloride (Cl <sup>-</sup> )	Mg/L	APHA 452100-B	48.02	0.250
Total Alkalinity	Mg/L CaCO <sub>3</sub>	APHA 2091-B	22.09	0-250

Bicarbonate ( $\text{HCO}_3^-$ )	Mg/L	APHA 2320-B	47.04	0-250
Lead (Pb)	Mg/L	ASTM D3559	<0.6	<0.5
Sulphate ( $\text{SO}_4^{2-}$ )	Mg/L	ASTM 516DR/2010	23.91	0-70
Manganese ( $\text{Mn}^{2+}$ )	Mg/L	ASTM D358	<0.001	<0.5
Total hardness	Mg/L $\text{CaCO}_3$	APHA 2340-C	20.01	0-200
Calcium hardness	Mg/L	APHA 2340-D	12.02	0-75
Magnesium hardness	Mg/L	APHA 2340-E	8.01	0-50
Total suspended solids	Mg/L	APHA 2540-D	<0.21	0-30
Total dissolved solids	Mg/L	APHA 2540-C	140.00	0-500
Total Acidity	Mg/L $\text{CaCO}_3$	APHA 2044-A	0.91	0-250
Salinity	Mg/L	APHA 45100-B	135.01	0-5000

### 3. MICROBIAL / BACTERIOLOGICAL CHARACTERISTICS

**CULTURE MEDIA USED:** MacConkey Broth, EMB Agar, Sabouraud Agar, Nutrient Agar.

**MACROSCOPY:** Colourless, Odorless, Tasteless, with no deposit on standing

S/N	PARAMETERS	UNIT	ANALYTICAL METHODS	ANALYTICAL RESULT	WHO LIMIT
C	MICROBIOLOGICAL PARAMETERS				
1	TOTAL COLIFORM BACTERIA COUNT AT 37°C	MPN/100ml	APHA 9221B	Absent	0-5
2	TOTAL HETEROPHIC BACTERIA COUNT (THBC) AT 37°C	CFU/100ml	APHA 9221D	1	0-100
3	TOTAL FILAMENTOUS FUNGAL COUNT AT 37°C	CFU/100ml	ASTM D5465-93	Absent	<1

Klebsiella aerogenes, CFU/ml	Absent	0
Legionella, CFU/ml	Absent	0
Salmonella Typhi CFU/ml	Absent	0

#### REMARKS:

All parameters analyzed fall with W.H.O standard for portable water.

Water is therefore good for drinking and other domestic uses.

This analysis is in accordance with International Health Regulations and Nigerian Quarantine Acts. And it valid for six (6) months.

*Handwritten signature and stamp:*  
 N.D. [Signature]  
 ASSISTANT CHIEF  
 SCIENTIFIC OFFICER  
 PORTHELM



# FEDERAL MINISTRY OF HEALTH

## PORT HEALTH (QUARANTINE) SERVICES

RIVERS STATE

P.M.B. NO

6213



Date: 31/10//2019

Telephone 08035751763  
08097895855

Ref. No: PH/LAB/19/0150

### WATER ANALYSIS RESULT/CERTIFICATION

- A. Types of Water - Fresh Water Sample  
B. Source of sample - ENL SUPERIOR (GALLEY)  
C. Aim of Analysis - To Determine Portability

#### RESULT:-

##### 1. PHYSICAL CHARACTERISTICS

- Colour - Colourless  
Taste - Unobjectionable  
Odour - Odourless

##### 2. PHYSIO CHEMICAL CHARATERISTICS

Physico-chemical Parameters	Units	Analytical Method	Result values	W.H.O Guideline Values
Colour	TCU	APHA 2120B	10.6	<15..00
Conductivity	Us/cm	APHA 2510-B	156.07	0-1000
Nitrate (as NO <sup>3</sup> )	Mg/L	APHA 418CDR2010	7.20	0-45
Total Iron (Fe <sup>2+</sup> )	Mg/L	ASTM D1068	0.26	0-0.30
Copper (Cu <sup>2+</sup> )	Mg/L	ASTM D1688	0.07	0-1.00
pH	-	APHA 4500HB	5.73	6.50-8.50
Residual Chlorine	Mg/L	APHA 4500-CLF	<0.01	0-0.30
Chromium (Cr <sup>6+</sup> )	Mg/L	ASTM D1687	ND	0-0.05
Fluoride (F <sup>-</sup> )	Mg/L	APHA 4500-FP	ND	0-45
Chloride (Cl <sup>-</sup> )	Mg/L	APHA 452100-B	48.02	0.250
Total Alkalinity	Mg/L CaCO <sub>3</sub>	APHA 2091-B	22.09	0-250



Bicarbonate ( $\text{HCO}_3^-$ )	Mg/L	APHA 2320-B	47.04	0-250
Lead (Pb)	Mg/L	ASTM D3559	<0.6	<0.5
Sulphate ( $\text{SO}_4^{2-}$ )	Mg/L	ASTM 516DR/2010	23.91	0-70
Manganese ( $\text{Mn}^{2+}$ )	Mg/L	ASTM D358	<0.001	<0.5
Total hardness	Mg/L $\text{CaCO}_3$	APHA 2340-C	20.01	0-200
Calcium hardness	Mg/L	APHA 2340-D	12.02	0-75
Magnesium hardness	Mg/L	APHA 2340-E	8.01	0-50
Total suspended solids	Mg/L	APHA 2540-D	<0.21	0-30
Total dissolved solids	Mg/L	APHA 2540-C	140.00	0-500
Total Acidity	Mg/L $\text{CaCO}_3$	APHA 2044-A	0.91	0-250
Salinity	Mg/L	APHA 45100-B	135.01	0-5000

### 3. MICROBIAL / BACTERIOLOGICAL CHARACTERISTICS

**CULTURE MEDIA USED:** MacConkey Broth, EMB Agar, Sabouraud Agar, Nutrient Agar.

**MACROSCOPY:** Colourless, Odorless, Tasteless, with no deposit on standing

S/N	PARAMETERS	UNIT	ANALYTICAL METHODS	ANALYTICAL RESULT	WHO LIMIT
C	MICROBIOLOGICAL PARAMETERS				
1	TOTAL COLIFORM BACTERIA COUNT AT 37°C	MPN/100ml	APHA 9221B	Absent	0-5
2	TOTAL HETEROPHIC BACTERIA COUNT (THBC) AT 37°C	CFU/100ml	APHA 9221D	1	0-100
3	TOTAL FILAMENTOUS FUNGAL COUNT AT 37°C	CFU/100ml	ASTM D5465-93	Absent	<1

Klebsiella aerogenes, CFU/ml	Absent	0
Legionella, CFU/ml	Absent	0
Salmonella Typhi CFU/ml	Absent	0

#### REMARKS:

All parameters analyzed fall with W.H.O standard for portable water.

Water is therefore good for drinking and other domestic uses.

This analysis is in accordance with International Health Regulations and Nigerian Quarantine Acts. And it valid for six (6) months.

*N. A. N.*