

VIEGO INTEGRATED SERVICES

ENGINEERING & ALLIED TECHNICAL SERVICES

Contact Address:
No.19b Ede Street,
FELAG House, Ogbunabali
Port Harcourt.
Tel:08037098076

14th April, 2023

The Manager,
Elshcon Nig. Ltd
Port Harcourt

Dear Sir,

RE - OVERHAULLING OF YOUR 65 KVA GENERATOR AT ELSHCON BASE ONE TRANS WOJI ROAD, PORT HARCOURT

Having completed the overhauling, we were unable to start up and test run the generator due to the following:

1. The kick starter is faulty
2. The Electric pump is bad

Please note that the above items were not discovered to be bad prior to inspection and quotation because the generator was not in a working condition and therefore could not be started.

Cost of Repairs/Replacement of the following items.

1. The kick starter -

We discovered upon repairs, that the kick starter is not the matching or the exact type for the generator hence there is lack of alignment which subsequently affected the performance and damage on the kick starter. Based on these findings the kick starter repairer suggested,

- A repair at the cost of ₦18,000.00
- Replacement of the kick starter with the matching type at the cost of ₦65,000.00
- Or a swap with the old one at the cost of ₦35,000.00

2. Replacement of the Electric lift pump-

- First grade (Original manufacturer type) ₦185,000.00
- Second grade (TURKEY MADE) ₦68,000.00
- Third grade (CHINA/UNKOWN) ₦30,000.00 - 45,000.00


We do recommend the first or second grade.

We therefore looking forward to your approval and payment based on the choice you make to enable us conclude the repairs immediately.

Thanks for yours patronage.

Yours faithfully,

For: VIEGO INTEGRATED SERVICE


OGOME VIRGINUS
Project Engineer