



AN EXELON COMPANY

**Matthew K. Segers**  
Assistant General Counsel  
  
EP9628  
701 Ninth Street NW  
Washington, DC 20068-0001

Office 202.428.1220  
Fax 202.331.6767  
pepco.com  
mksegers@pepcoholdings.com

July 7, 2025

Mr. Andrew Johnston  
Executive Secretary  
Public Service Commission of Maryland  
William Donald Schaefer Tower  
6 St. Paul Street, 16<sup>th</sup> Floor  
Baltimore, MD 21206-6808

**Re: Case No. 8890 – Pepco Modification of Retail Transmission Rates effective September 1, 2025**

Dear Mr. Johnston:

Enclosed for filing in the above referenced matter please find tariff pages of the Potomac Electric Power Company’s (“Pepco” or “Company”) proposed Standard Offer Service – Rider “SOS”. The retail transmission rates included in Rider “SOS” have been updated to reflect the current Federal Energy Regulatory Commission (FERC) approved wholesale transmission rates, which went into effect June 1, 2025. Pepco requests that the Commission approve the revised transmission rates contained in Rider “SOS” effective with usage on and after September 1, 2025.

The current Pepco Zone FERC-approved wholesale transmission rates for the period June 1, 2025 through May 31, 2026 include the following items:

1. Pepco’s and the Southern Maryland Electric Cooperative’s (SMECO’s) FERC-approved formula rates as delineated in Attachment H-9A and Attachment H-9C of the PJM Open Access Transmission Tariff (“OATT”).
2. Transmission Enhancement Charges (“TECs”) pursuant to Schedule 12 of the PJM OATT.
3. The impact of changes to the PJM OATT pursuant to the Federal Energy Regulatory Commission (“FERC”) Order issued on May 31, 2018 in FERC Docket No. EL05-121-009.

The incorporation of these items into the Company's retail transmission rates is described in greater detail on pages 2 through 6. A residential bill impact estimate is included on page 4, and a description of each of the attachments included in this filing is also included on pages 4 and 5.

## 1. Formula Rate - Pepco and SMECO

On May 12, 2025, the Company posted its annual update of the Company's formula transmission rate on the PJM website and filed informational copies of it with the FERC. The updated Network Integrated Transmission Service (NITS) rate is based on data contained in the 2024 FERC Form 1 for Pepco, which was filed with the FERC on March 30, 2025. As shown in Attachment H-9A of the PJM OATT, the filed wholesale transmission rate for NITS for the Pepco Zone effective June 1, 2025 is approximately \$57,744 per megawatt-year. Accounting for solely the Pepco Zone's share of Pepco Zone Schedule 12 TECs, the wholesale transmission rate for NITS effective June 1, 2024, excluding any amount associated with the SMECO formula rate for NITS, is approximately \$56,544 per megawatt-year.

The increase in the 2025 NITs rate from the 2024 NITs rate is largely driven by significant transmission additions that drove an increase in Investment Return, Income Taxes, and Depreciation and Amortization Expense. Additional drivers include increased total transmission O&M and True-Up component.

Specific details are shown in the chart below.

|                           | <u>2024-2025</u> | <u>PEPCO<br/>2025-2026</u> | <u>Variance</u> |
|---------------------------|------------------|----------------------------|-----------------|
| O&M                       | 61,457,803       | 62,652,929                 | 1,195,126       |
| Depreciate & Amortization | 56,295,434       | 61,165,557                 | 4,870,123       |
| Taxes Other than Income   | 17,688,826       | 18,546,092                 | 857,266         |
| Investment Return         | 127,814,024      | 150,320,930                | 22,506,906      |
| Income Taxes              | 31,825,304       | 38,234,012                 | 6,408,708       |
| Revenue Credits           | (7,367,012)      | (8,251,211)                | (884,199)       |
| True-Up                   | 16,189,598       | 32,246,856                 | 16,057,258      |
| Incentives                | 908,911          | 885,227                    | (23,684)        |
| Increase (Decrease)       | 304,812,888      | 355,800,392                | 50,987,504      |

On January 1, 2017, SMECO became classified as a PJM Transmission Owner and, consequently, its 230kV transmission and associated facilities are now considered a part of the bulk electric system. As a result, it was required to register as a Transmission Owner and to execute PJM's Transmission Owners Agreement (TOA) whereby it transferred its functions as Transmission Operator to PJM. SMECO's transmission system is integrated with the transmission system of Pepco in the Pepco Zone of PJM.<sup>1</sup> As such, it is appropriate to include

---

<sup>1</sup> Further information can be found in FERC Docket No. ER18-963 as well as the testimony of SMECO Witness Slater in Maryland Case No. 9456.

its formula rate for NITS in the calculation of the retail transmission rates for customers in the Pepco Zone.

As shown in SMECO's revision to Attachment H-9C of the PJM Open Access Transmission Tariff filed on November 27, 2024, in FERC Docket No. ER18-963-000, the filed wholesale transmission rate for NITS for SMECO currently in effect is approximately \$2,773 per megawatt-year.

Including the SMECO formula rate for NITS, the Pepco Zone's wholesale transmission rate for NITS effective June 1, 2025 is approximately \$59,317 per megawatt-year. Supporting documentation for this calculation can be found on page 1 of Attachment D.

## 2. Transmission Enhancement Charges

Schedule 12 of the PJM OATT delineates certain charges, referred to as TECs, that are implemented to compensate transmission owners for the annual transmission revenue requirements for "Regional Transmission Enhancements" (as defined in the PJM OATT) that are requested by PJM for reliability or economic purposes. TECs are recovered by PJM through an additional transmission charge in the transmission zones assigned cost responsibility for the related Regional Transmission Enhancement Project ("RTEP"). As part of PJM's RTEP, PJM is required to file annual cost responsibility assignments for transmission projects in accordance with Schedule 12 of the PJM OATT for PJM Board of Managers and FERC approval. The assigned TECs are subsequently delineated in the formula rate update filings made by the responsible transmission owner.

As of July 2, 2025, formula rate updates incorporating Transmission Enhancement projects in Schedule 12 of the PJM Tariff, for which the Pepco Zone has an allocated responsibility, have been filed by the following transmission owners:

| Transmission Owner                                       | FERC Docket |
|--|-------------|
| AEP East Operating Companies (AEP)                       | ER08-1329   |
| Atlantic City Electric Company (Atlantic City)           | ER09-1156   |
| Baltimore Gas and Electric Company (BGE)                 | ER09-1100   |
| Commonwealth Edison Company                              | ER09-1145   |
| Delmarva Power & Light Company (Delmarva Power)          | ER09-1158   |
| Duquesne Light Company                                   | ER09-1167   |
| Mid- Atlantic Interstate Transmission, LLC               | ER21-2072   |
| Northern Indiana Public Service Company                  | ER13-2376   |
| PECO Energy Company                                      | ER17-1519   |
| Potomac Electric Power Company (Pepco)                   | ER09-1159   |
| Potomac-Appalachian Transmission Highline, L.L.C. (PATH) | ER09-1159   |
| PPL Electric Utilities Corporation (PPL Electric)        | ER09-1148   |
| Public Service Electric and Gas Company (PSE&G)          | ER09-1257   |
| South FirstEnergy  | ER21-253    |
| Trans-Allegheny Interstate Line Company (TrAILCo)        | ER17-406    |
| Transource Maryland, LLC                                 | ER17-419    |
| Transource Pennsylvania, LLC                             | ER17-419    |

|   |           |
|---|-----------|
| Virginia Electric Power Company (Dominion)    | ER09-545  |
| NextEra Energy Transmission MidAtlantic, Inc. | ER20-1783 |

The TECs for the Pepco Zone are included in the wholesale transmission rate for NITS for the Pepco Zone, as described in Section 1 above. However, for purposes of calculating retail transmission rates for customers in the Pepco Zone, the wholesale transmission rate for NITS only includes the Schedule 12 TECs that reflects the cost responsibility for Regional Transmission Enhancement projects allocated to the Pepco Zone. This calculation is detailed on page 1 of Attachment D.

The annual revenue requirements as of July 2nd, 2025 for TECs for the other transmission zones listed are shown on pages 1 through 12 of Attachment C. The Pepco Zone's Transmission Enhancement Charge for non-Pepco Zone Regional Transmission Enhancement projects is approximately \$7,105 per megawatt-year.

### **3. FERC Docket No. EL05-121-009 Settlement**

FERC Docket No. EL05-121-009 pertained to the allocation of costs for RTEPs among Transmission Owners (“TOs”) in PJM. A settlement in this docket was reached in April 2018 and was approved by the FERC on May 31, 2018. As a part of the settlement, the cost allocation of RTEPs through the TECs was modified. The modification to the allocation was retroactive to the TECs beginning in 2007 and applies to both current and future TECs.

The modification to the allocation of the TECs is described as a “Billing Line Item” (“BLI”):

**a. Billing Line Item 1108 – Transmission Enhancement**

This BLI is used by PJM to charge for TECs. Changes to the current TECs as a result of the settlement are, on a going forward basis, reflected in this BLI. As discussed above, the Pepco Zone’s responsibility for Pepco Zone RTEP and non-Pepco Zone RTEP are calculated in Attachments C and D of this filing.

**b. Billing Line Item 1115 – Transmission Enhancement Settlement (EL05-121-009)**

This BLI is a billing line item developed to charge or credit the total aggregate difference between historic TECs for the period 2007 – 2015 and the TECs for the same period reflecting the modified allocations. BLI 1115 remains in effect through December 31, 2025. This component is calculated on Attachment E Page 1 of 1.

The following BLI's are no longer in effect:

**c. Billing Line Item 1108 – Transmission Enhancement – Catch Up and Interest**

**d. Billing Line Item 1115 – Transmission Enhancement Settlement (EL05-121-009) – Catch Up and Interest**

#### **4. Residential Bill Impact**

The Company estimates that the net impact (including the impact to the PCA) of its proposed change in transmission retail rates to a Residential SOS customer using 824 kWh per month is \$1.25 per month.

#### **Description of Filing Attachments**

##### **Attachment A**

Attachment A provides proposed tariff pages containing the revised retail transmission rates as well as a redline which shows the additions and deletions to the current tariff pages.

##### **Attachment B**

Attachment B includes a summary of the calculation of the Pepco Zone's Retail Transmission Revenue Requirement by component for the period June 2025 to May 2026. It also provides a summary by rate schedule of Annualized Current Transmission Revenue, Transmission Peak Load Contribution ("TPLC"), Proposed Retail Transmission Revenue, and the proposed increase in Retail Transmission Revenue on a dollar and a percentage basis as allocated to rate schedules utilizing the Pepco Zone's TPLC as of January 1, 2025.

##### **Attachment C**

Attachment C includes the calculation of the Pepco Zone's allocated responsibility for the revenue requirements associated with Regional Transmission Enhancement projects in other PJM transmission zones.

##### **Attachment D**

Attachment D includes the Pepco Zone's transmission service annual revenue requirement, including in that calculation (1) an adjustment to reflect only the Pepco Zone's share of Pepco Zone Schedule 12 TECs and (2) the addition of SMECO's FERC-approved formula rate for NITS.

##### **Attachment E**

Attachment E calculates the impact of the FERC Docket No. EL05-121-009 Settlement on the June 2025 to December 2025 Pepco Zone retail transmission revenue requirement.

##### **Attachment F**

Attachment F calculates the proposed Pepco retail transmission rates using the final June 2025 to May 2026 Pepco Zone retail transmission revenue requirement allocations to Pepco's Maryland rate schedules and associated 2024 billing determinants. The retail transmission rates shown in Attachment F are designed prior to the application of the Commission-approved PCA-related transmission rate adjustment.

##### **Attachment G**

Attachment G calculates the annualized bill impact of the Company's proposed update to its transmission retail rates for Residential SOS customers using 824 kWh per month utilizing current distribution, generation, transmission, and surcharge rates, as well as proposed transmission rates.

Please note that all attachments refer to any underlying PJM source documentation used in their preparation.

Finally, the Company, pursuant to its discussions with the Staff of the Public Service Commission, commits to filing its future transmission retail rate updates on or around July 1<sup>st</sup> of each year.

In consideration of the foregoing, Pepco requests that the Commission approve the revised transmission rates, effective September 1, 2025.

Please contact me if you have any further questions.

Sincerely,

/S/ **Matthew K. Segers**

Matthew K. Segers

Enclosure

cc: All Parties of Record

Attachment A  
Clean and Redlined Pages

Clean Pages

**RATE SCHEDULES  
FOR  
ELECTRIC SERVICE  
IN  
MARYLAND  
POTOMAC ELECTRIC POWER COMPANY**



**RATES AND REGULATORY PRACTICES GROUP**

**TABLE OF CONTENTS  
RATE SCHEDULES**

|  |                  |
|--|------------------|
| RESIDENTIAL SERVICE - SCHEDULE "R" .....   | Page 3 - 3.1     |
| TIME METERED RESIDENTIAL SERVICE - SCHEDULE "R-TM" .....   | Page 4 - 4.1     |
| GENERAL SERVICE - SCHEDULE "GS" .....  | Page 5 - 5.1     |
| TEMPORARY SERVICE - SCHEDULE "T" .....   | Page 6 - 6.1     |
| TIME METERED MEDIUM GENERAL SERVICE - LOW VOLTAGE - TYPE II<br>SCHEDULE "MGT LV II" .....  | Page 7 - 7.2     |
| TIME METERED MEDIUM GENERAL SERVICE - LOW VOLTAGE - TYPE II A<br>SCHEDULE "MGT LV II A" (THIS SCHEDULE HAS BEEN DELETED) .....     | Page 7.3 – 7.5   |
| TIME METERED MEDIUM GENERAL SERVICE - LOW VOLTAGE - TYPE III<br>SCHEDULE "MGT LV III" .....  | Page 7.6 – 7.8   |
| TIME METERED MEDIUM GENERAL SERVICE - PRIMARY SERVICE - TYPE II<br>SCHEDULE "MGT 3A II" .....                                      | Page 8 - 8.2     |
| TIME METERED MEDIUM GENERAL SERVICE - PRIMARY SERVICE - TYPE II A<br>SCHEDULE "MGT 3A II A" (THIS SCHEDULE HAS BEEN DELETED) ..... | Page 8.2 – 8.5   |
| TIME METERED MEDIUM GENERAL SERVICE - PRIMARY SERVICE - TYPE III<br>SCHEDULE "MGT 3A III" .....                                    | Page 8.6 – 8.8   |
| TIME METERED GENERAL SERVICE - LOW VOLTAGE -<br>SCHEDULE "GT LV" .....   | Page 9 - 9.2     |
| TIME METERED GENERAL SERVICE - PRIMARY SERVICE -<br>SCHEDULE "GT 3A" .....   | Page 10 - 10.2   |
| TIME METERED GENERAL SERVICE - HIGH VOLTAGE -<br>SCHEDULE "GT 3B" .....  | Page 11 - 11.2   |
| TIME METERED RAPID TRANSIT SERVICE - SCHEDULE "TM-RT" .....  | Page 12 - 12.1   |
| ELECTRIC VEHICLE SERVICE - SCHEDULE "EV" .....   | Page 13 – 13.1   |
| (THIS SCHEDULE IS CLOSED TO NEW CUSTOMERS)   |                  |
| OUTDOOR LIGHTING SERVICE - SCHEDULE "OL" .....   | Page 14 - 14.1   |
| STREET LIGHTING SERVICE - SCHEDULE "SL" .....  | Page 15 - 15.1   |
| SERVICING STREET LIGHTS SERVED FROM OVERHEAD LINES -<br>SCHEDULE "SSL-OH" .....  | Page 16 - 16.3   |
| SERVICING STREET LIGHTS SERVED FROM UNDERGROUND<br>LINES - SCHEDULE "SSL-UG" .....   | Page 17 - 17.2   |
| SERVICING STREET LIGHTS SERVED FROM OVERHEAD LINES –<br>SCHEDULE "SSL-OH-LED" .....  | Page 17.3 – 17.5 |
| SERVICING STREET LIGHTS SERVED FROM UNDERGROUND LINES –<br>SCHEDULE "SSL-UG-LED" .....   | Page 17.6 – 17.9 |

|  |                                |
|--|--------------------------------|
| TELECOMMUNICATIONS NETWORK SERVICE - SCHEDULE "TN" .....   | <a href="#">Page 18 - 18.1</a> |
| COGENERATION AND SMALL POWER PRODUCTION INTERCONNECTION<br>SERVICE - SCHEDULE "CG-SPP" PURCHASE OF POWER ..... | <a href="#">Page 19 - 19.4</a> |
| STANDBY SERVICE - SCHEDULE "S" .....   | <a href="#">Page 20 - 20.1</a> |
| PLUG-IN VEHICLE CHARGING – SCHEDULE “PIV” .....  | <a href="#">Page 21 - 21.1</a> |
| RESIDENTIAL SERVICE – PLUG-IN VEHICLE CHARGING – SCHEDULE “R-PIV” .....  | <a href="#">Page 22 – 22.1</a> |
| COMMUNITY SOLAR PILOT PROGRAM – SCHEDULE “CS” .....  | <a href="#">Page 23 – 23.6</a> |
| RESIDENTIAL TIME-OF-USE PROGRAM – SCHEDULE “R-TOU-P” .....   | <a href="#">Page 24 – 24.1</a> |
| PUBLIC ELECTRIC VEHICLE CHARGING SERVICE – SCHEDULE “PC-PIV” .....   | <a href="#">Page 25 – 25.1</a> |
| RESERVED FOR FUTURE USE.....   | <a href="#">Page 25.2 – 26</a> |

## RIDERS

|  |                                |
|--|--------------------------------|
| MARKET PRICE SERVICE - RIDER "MPS" .....   | <a href="#">Page 27 - 27.1</a> |
| (THIS RIDER HAS BEEN DELETED)  |                                |
| UNIVERSAL SERVICE CHARGE RECOVERY - RIDER "USC" .....                                    | <a href="#">Page 28</a>        |
| GENERATION PROCUREMENT CREDIT - RIDER "GPC".....   | <a href="#">Page 29 - 29.1</a> |
| (THIS RIDER HAS BEEN DELETED)  |                                |
| EXPERIMENTAL RESIDENTIAL ELECTRIC VEHICLE SERVICE -<br>RIDER "R-EV" .....                | <a href="#">Page 30</a>        |
| EXPERIMENTAL RESIDENTIAL TIME-OF-USE ELECTRIC VEHICLE<br>SERVICE - RIDER "R-TM-EV" ..... | <a href="#">Page 30.2</a>      |
| NET ENERGY METERING "NEM" .....  | <a href="#">Page 31 – 31.3</a> |
| EXPERIMENTAL CONJUNCTIVE BILLING SERVICE – RIDER “CBS” .....                             | <a href="#">Page 32 – 32.1</a> |
| (THIS RIDER HAS BEEN DELETED)  |                                |
| TELECOMMUNICATION NETWORK CHARGE - RIDER "SL-TN" .....                                   | <a href="#">Page 33</a>        |
| POWER FACTOR - RIDER "PF" .....  | <a href="#">Page 34</a>        |
| THERMAL ENERGY STORAGE SERVICE - RIDER "TS" .....  | <a href="#">Page 35</a>        |
| DELIVERY TAX SURCHARGE - RIDER "DT" .....  | <a href="#">Page 36</a>        |
| MONTGOMERY COUNTY SURCHARGE - RIDER "MCS" .....  | <a href="#">Page 37</a>        |
| MARYLAND ENVIRONMENTAL SURCHARGE - RIDER "MES" .....                                     | <a href="#">Page 38</a>        |

|  |                                 |
|--|---------------------------------|
| TEMPORARY TAX COMPLIANCE SURCHARGE - RIDER "TTCS" .....<br>(THIS RIDER HAS BEEN DELETED)           | <a href="#">Page 39</a>         |
| OPTIONAL METER EQUIPMENT RELATED SERVICES - RIDER "OMRS".....                                      | <a href="#">Pages 40 – 40.2</a> |
| EXCESS FACILITIES - RIDER "EF" .....   | <a href="#">Page 41</a>         |
| DIVESTITURE SHARING CREDIT - RIDER "DS".....<br>(THIS RIDER HAS BEEN DELETED)                      | <a href="#">Page 42</a>         |
| STANDARD OFFER SERVICE - RIDER "SOS".....  | <a href="#">Page 43 – 43.7</a>  |
| ADMINISTRATIVE CREDIT – RIDER “AC” .....   | <a href="#">Page 44</a>         |
| SOS PHASE IN CREDIT/DEFERRED COST ADJUSTMENT–RIDER “SOS PIC/DCA”.<br>(THIS RIDER HAS BEEN DELETED) | <a href="#">Page 45 – 45.1</a>  |
| RESERVED DELIVERY CAPACITY SERVICE – RIDER “RDCS”.....   | <a href="#">Page 46 – 46.1</a>  |
| BILL STABILIZATION ADJUSTMENT – RIDER “BSA” .....  | <a href="#">Page 47 – 47.1</a>  |
| EMPOWER MD CHARGE - RIDER “E-MD” .....   | <a href="#">Page 48 – 48.1</a>  |
| RESIDENTIAL DIRECT LOAD CONTROL – RIDER “R-DLC” .....  | <a href="#">Page 49 – 49.1</a>  |
| RGGI RATE CREDIT – RIDER “RRC” .....   | <a href="#">Page 50</a>         |
| MASTER-METERED DIRECT LOAD CONTROL – RIDER “MM-DLC”.....<br>(THIS RIDER HAS BEEN DELETED)          | <a href="#">Page 51 – 51.1</a>  |
| AGGREGATE NET ENERGY METERING – RIDER “ANEM”.....  | <a href="#">Page 52 – 52.4</a>  |
| NON-RESIDENTIAL DIRECT LOAD CONTROL – RIDER “NR-DLC” .....   | <a href="#">Page 53</a>         |
| DEMAND RESOURCE SURCHARGE – RIDER “DRS” .....  | <a href="#">Page 54 – 54.1</a>  |
| DYNAMIC PRICING – PEAK ENERGY SAVINGS CREDIT – RIDER “DP” .....                                    | <a href="#">Page 55 – 55.1</a>  |
| GRID RESILIENCY CHARGE – RIDER “GRC” .....   | <a href="#">Page 56 – 56.1</a>  |
| COMMUNITY NET ENERGY METERING PILOT PROGRAM “RIDER CNM” .....                                      | <a href="#">Page 57 – 57.1</a>  |
| ELECTRIC VEHICLE CHARGING PROGRAM – RIDER “EVCP” .....   | <a href="#">Page 58 – 58.5</a>  |
| GREEN RIDER – RIDER “GREEN” .....  | <a href="#">Page 59</a>         |
| ELECTRIC VEHICLE CHARGING DISTRIBUTION DEMAND CHARGE   |                                 |
| CREDIT – RIDER “EVCDDCC” .....   | <a href="#">Page 60 - 60.1</a>  |
| ECONOMIC RELIEF AND RECOVERY RIDER - RIDER “ERR” .....   | <a href="#">Page 61 - 61.8</a>  |
| MULTI-YEAR PLAN (“MYP”) ADJUSTMENT RIDER – RIDER “MYP” ADJUSTMENT ...                              | <a href="#">Page 62 - 62.1</a>  |
| REVENUE DEFERRAL MECHANISM RIDER – RIDER “RDM”.....  | <a href="#">Page 63 – 63.10</a> |
| SMALL GENERATOR INTERCONNECTION STANDARD.....  | <a href="#">Page 64</a>         |

## Summary Rider

Rates and charges included in the Rate Schedules listed in the summary matrix shall be modified with the terms and conditions consistent with the indicated Riders:

|   | Rider           | Rate Schedule |      |    |   |           |            |           |            |       |       |       |       |    |    |
|---|-----------------|---------------|------|----|---|-----------|------------|-----------|------------|-------|-------|-------|-------|----|----|
|   |                 | R             | R-TM | GS | T | MGT LV II | MGT LV III | MGT 3A II | MGT 3A III | GT LV | GT 3A | GT 3B | TM-RT | EV | OL |
|   | <b>GRT</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| A | <b>USC</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
|   | <b>R-EV</b>     | X             |      |    |   |           |            |           |            |       |       |       |       |    |    |
|   | <b>R-TM-EV</b>  |               | X    |    |   |           |            |           |            |       |       |       |       |    |    |
|   | <b>NEM</b>      | X             | X    | X  |   | X         | X          | X         | X          | X     | X     | X     |       |    |    |
| I | <b>SL-TN</b>    |               |      |    |   |           |            |           |            |       |       |       |       |    |    |
|   | <b>PF</b>       |               |      | X  |   | X         | X          | X         | X          | X     | X     | X     |       |    |    |
|   | <b>TS</b>       |               |      |    |   | X         | X          | X         | X          | X     | X     | X     |       |    |    |
| F | <b>DT</b>       | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| E | <b>MCS</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| E | <b>MES</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
|   | <b>OMRS</b>     | X             | X    | X  |   | X         | X          | X         | X          | X     | X     | X     | X     |    |    |
|   | <b>EF</b>       |               |      |    |   | X         | X          | X         | X          | X     | X     | X     | X     |    |    |
| D | <b>SOS</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| G | <b>PCA*</b>     | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| G | <b>HPS*</b>     |               |      |    |   | X         |            |           | X          | X     | X     | X     |       |    |    |
| G | <b>AC</b>       | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
|   | <b>RDCS</b>     |               |      |    |   | X         | X          | X         | X          | X     | X     | X     | X     |    |    |
| G | <b>BSA</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     |       |    | X  |
| A | <b>E-MD</b>     | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
|   | <b>R-DLC</b>    | X             | X    |    |   |           |            |           |            |       |       |       |       |    |    |
| H | <b>RRC</b>      | X             | X    |    |   |           |            |           |            |       |       |       |       |    |    |
|   | <b>MM-DLC</b>   |               |      |    |   | X         | X          | X         | X          | X     | X     | X     | X     | X  |    |
|   | <b>ANEM</b>     | X             | X    | X  |   | X         | X          | X         | X          | X     | X     | X     |       |    |    |
|   | <b>NR-DLC</b>   |               |      | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| B | <b>DRS</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| A | <b>DP</b>       | X             | X    |    |   |           |            |           |            |       |       |       |       |    |    |
| A | <b>GRC</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
|   | <b>CNM</b>      |               |      |    |   |           |            |           |            |       |       |       |       |    |    |
|   | <b>EVCP</b>     | X             |      | X  |   | X         | X          | X         | X          | X     | X     | X     |       |    |    |
| C | <b>GREEN</b>    |               |      |    |   |           |            |           |            |       |       |       |       |    |    |
|   | <b>EVCDCCC</b>  |               |      |    |   | X         | X          | X         | X          | X     | X     | X     |       |    |    |
|   | <b>ERR</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| I | <b>MYP ADJ.</b> | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
|   | <b>RDM</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |

**Key:**

X – Rider is applicable or available to the Rate Schedule indicated

\* – A component of Rider SOS

A – Rider is reconciled and updated annually during the first quarter of each year

B – Rider is reconciled and updated annually during the second quarter of each year

C – Rider is reconciled and updated biannually during the first and third quarters of each year

D – Rider is updated biannually with SOS – Type II rates updated on a quarterly basis

E – Off-rider rates are tracked on a monthly basis and updated annually

F – Off-rider rate is tracked on a monthly basis and updated upon change in the enacted franchise tax rate

G – Off-rider rates are tracked and updated on a monthly basis

H – Off-rider rates are tracked and updated on a quarterly basis

I – Rider is updated periodically

## Summary Rider

Rates and charges included in the Rate Schedules listed in the summary matrix shall be modified with the terms and conditions consistent with the indicated Riders:

|   | Rider    | SL | SSL-OH | SSL-UG | SSL-OH-LED | SSL-UG-LED | TN | S | PIV | R-PIV | CS | R-TOU-P | PC-PIV |
|---|----------|----|--------|--------|------------|------------|----|---|-----|-------|----|---------|--------|
|   | GRT      | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
| A | USC      |    |        |        |            |            |    |   |     | X     |    | X       |        |
|   | R-EV     |    |        |        |            |            |    |   |     |       |    |         |        |
|   | R-TM-EV  |    |        |        |            |            |    |   |     |       |    |         |        |
|   | NEM      |    |        |        |            |            |    |   | X   |       |    | X       |        |
| I | SL-TN    | X  | X      | X      | X          | X          |    |   |     |       |    |         |        |
|   | PF       |    |        |        |            |            |    |   |     |       |    |         |        |
|   | TS       |    |        |        |            |            |    |   |     |       |    |         |        |
| F | DT       | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
| E | MCS      | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
| E | MES      | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
|   | OMRS     |    |        |        |            |            |    |   |     |       |    | X       |        |
|   | EF       |    |        |        |            |            |    |   |     |       |    |         |        |
| D | SOS      | X  | X      | X      | X          | X          | X  |   |     |       |    | X       |        |
| G | PCA*     | X  | X      | X      | X          | X          | X  |   |     |       |    | X       |        |
| G | HPS*     |    |        |        |            |            |    |   |     |       |    |         |        |
| G | AC       | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
|   | RDCS     |    |        |        |            |            |    |   |     |       |    |         |        |
| G | BSA      |    |        |        |            |            |    |   | X   | X     |    | X       |        |
| A | E-MD     | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
|   | R-DLC    |    |        |        |            |            |    |   |     | X     |    | X       |        |
| H | RRC      |    |        |        |            |            |    |   |     |       |    | X       |        |
|   | MM-DLC   |    |        |        |            |            |    |   |     |       |    |         |        |
|   | ANEM     |    |        |        |            |            |    |   |     |       |    |         |        |
|   | NR-DLC   | X  | X      | X      | X          | X          | X  |   |     |       |    |         |        |
| B | DRS      | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
| A | DP       |    |        |        |            |            |    |   | X   | X     |    | X       |        |
| A | GRC      | X  | X      | X      | X          | X          | X  |   |     |       |    |         |        |
|   | CNM      |    |        |        |            |            |    |   |     |       | X  |         |        |
|   | EVCP     |    |        |        |            |            |    |   |     | X     |    | X       |        |
| C | GREEN    |    |        |        |            |            |    |   | X   | X     |    |         | X      |
|   | EVCDCC   |    |        |        |            |            |    |   |     |       |    |         |        |
|   | ERR      | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       | X      |
| I | MYP ADJ. | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
|   | RDM      | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |

**Key:**

X – Rider is applicable or available to the Rate Schedule indicated

\* – A component of Rider SOS

A – Rider is reconciled and updated annually during the first quarter of each year

B – Rider is reconciled and updated annually during the second quarter of each year

C – Rider is reconciled and updated biannually during the first and third quarters of each year

D – Rider is updated biannually with SOS – Type II rates updated on a quarterly basis

E – Off-rider rates are tracked on a monthly basis and updated annually

F – Off-rider rate is tracked on a monthly basis and updated upon change in the enacted franchise tax rate

G – Off-rider rates are tracked and updated on a monthly basis

H – Off-rider rates are tracked and updated on a quarterly basis

I – Rider is updated periodically

---

Date of Issue: June 24, 2004

Date Effective: July 1, 2004

**MD - PIV****PLUG-IN VEHICLE CHARGING -  
SCHEDULE "PIV"**

**AVAILABILITY** – Available for Distribution and Standard Offer Service for low voltage electric service used for Plug-in Vehicle (“PIV”) battery charging purposes in premises where other electric requirements are furnished under Schedule “R” and “RTM”.

Customers taking service under Rider “NEM” (Net Energy Metering) are eligible for this Schedule “PIV”.

**CHARACTER OF SERVICE**

The service supplied under this schedule normally will be alternating current, sixty hertz, either (i) single phase, three wire, 120/240 volts or 120/208 volts, or (ii) three phase, four wire, 120/208 volts.

Service will be supplied from the regular service connection facilities.

**MONTHLY RATE**

|                                      |  |
|--------------------------------------|--|
| <b>Distribution Service Charge</b>   | <b>Rate Year 1<br/>Effective<br/>April 1, 2024</b> |
| <b>Kilowatt-Hour Charge (Summer)</b> | \$0.08760  |
| <b>Kilowatt-Hour Charge (Winter)</b> | \$0.04328  |

| Generation Service Charge             | Rate Effective<br>November 1, 2024 -<br>January 31, 2025<br>Winter | Rate Effective<br>February 1, 2025 -<br>May 31, 2025<br>Winter | Rate Effective<br>June 1, 2025 -<br>October 31, 2025<br>Summer |
|---------------------------------------|--|--|--|
| <b>SOS Kilowatt-Hour Charge</b>       |  |  |  |
| On-Peak                               | \$0.15995 per kWhr   | \$0.15995 per kWhr   | \$0.16479 per kWhr   |
| Off-Peak                              | \$0.08527 per kWhr   | \$0.08527 per kWhr   | \$0.07666 per kWhr   |
| <b>Administrative Charge</b>          | \$0.00391 per kWhr   | \$0.00589 per kWhr   | \$0.00515 per kWhr   |
| <b>Total SOS Kilowatt Hour Charge</b> |  |  |  |
| On-Peak                               | \$0.16386 per kWhr   | \$0.16584 per kWhr   | \$0.16994 per kWhr   |
| Off-Peak                              | \$0.08918 per kWhr   | \$0.09116 per kWhr   | \$0.08181 per kWhr   |

\*The Administrative Charge rates typically change every February, June and October.

|                                      |   |
|--------------------------------------|---|
| <b>Transmission Service Charge</b>   | <b>Rate Effective<br/>September 1, 2025</b> |
| <b>Kilowatt-Hour Charge (Summer)</b> | \$0.02101                                   |
| <b>Kilowatt-Hour Charge (Winter)</b> | \$0.02101                                   |

**Procurement Cost Adjustment**

See [www.pepco.com](http://www.pepco.com) for currently effective rate

**MD - PIV**

**Generation and Transmission Service Charges** – Customers who do not receive service from an alternative Electric Supplier as defined in the Company's General Terms and Conditions will receive Generation and Transmission Services from the Company under the provisions of Schedule "PIV". Supply Service Charges for Schedule "PIV" will be updated to reflect changes to Rider "SOS" rates.

**Billing Credit** – A monthly billing credit in the amount of \$0.61 per residential customer will be applied to the bill of each customer receiving a consolidated bill from an alternative supplier for services provided both by Pepco and by the alternative supplier.

**BILLING MONTHS**

**Summer** – Billing months of June through October.  
**Winter** – Billing months of November through May.

**RATING PERIODS**

On-peak hours are from 12:00 p.m. to 8 p.m. Monday through Friday excluding holidays falling on weekdays. All other hours are off-peak.

**SUPPLY CAPACITY REQUIREMENT**

Should additional service capacity be required for the "off-peak" service, in excess of that provided for regular service, the customer will pay to the Company an amount equal to the estimated cost of the additional facilities. Such payment must be made prior to the commencement of service under this schedule.

**GROSS RECEIPTS TAX**

A surcharge of 2.0408% is applied to the transmission and distribution components of the customer's bill to recover the amount attributable to the Gross Receipt's Tax.

**GENERAL TERMS AND CONDITION**

This schedule is subject in all respects to the Company's "General Terms and Conditions for Furnishing Electric Service" and the Company's "Electric Service Rules and Regulations."

**APPLICABLE RIDERS**

Net Energy Metering  
Administrative Credit  
Delivery Tax Surcharge  
Montgomery County Surcharge  
Maryland Environmental Surcharge  
Bill Stabilization Adjustment  
Empower MD Charge  
Demand Resource Surcharge  
Dynamic Pricing – Peak Energy Savings Credit  
Green Rider  
Economic Relief and Recovery Rider  
MYP Adjustment Rider  
Revenue Deferral Mechanism Rider

**RESIDENTIAL SERVICE - WITH PLUG-IN  
VEHICLE CHARGING SCHEDULE "R-PIV"**

**AVAILABILITY** – Available for Distribution Service and Standard Offer Service when modified by Rider “SOS” in the Maryland portion of the Company’s service area for low voltage electric service where the use is primarily for residential purposes and for farm operations where the electricity for both farm and residential purposes is delivered through the same meter.

The service supplied under this Schedule is for Plug-in Vehicle (“PIV”) battery charging purposes in addition to the electric requirements for residential purposes and for farm operations as described above. The electricity for PIV battery charging purposes is delivered through the same meter as for both farm and residential purposes.

Not available for residential premises in which five (5) or more rooms are furnished under Schedules “R” and “RTM” for hire.

Not available for seasonal loads metered separately from lighting and other usage in the same occupancy.

Not available for temporary, auxiliary or emergency service.

**CHARACTER OF SERVICE**

The service supplied under this schedule normally will be alternating current, sixty hertz, either (i) single phase, three wire, 120/240 volts or 120/208 volts, or (ii) three phase, four wire, 120/208 volts.

Service will be supplied from the regular service connection facilities.

**MONTHLY RATE**

| Distribution Service Charge   | Rate Year 1<br>Effective<br><b>April 1, 2024</b> |
|-------------------------------|--|
| Customer Charge               | \$ 8.44  |
| Kilowatt-Hour Charge (Summer) | \$0.08760  |
| Kilowatt-Hour Charge (Winter) | \$0.04328  |

| Generation Service Charge      | Rate Effective<br>November 1, 2024 –<br>January 31, 2025<br>Winter | Rate Effective<br>February 1, 2025 –<br>May 31, 2025<br>Winter | Rate Effective<br>June 1, 2025 -<br>October 31, 2025<br>Summer |
|--------------------------------|--|--|--|
| SOS Kilowatt-Hour Charge       |  |  |  |
| On-Peak                        | \$0.21973 per kWhr   | \$0.21973 per kWhr   | \$0.17528 per kWhr   |
| Off-Peak                       | \$0.07135 per kWhr   | \$0.07135 per kWhr   | \$0.07116 per kWhr   |
| Administrative Charge          | \$0.00391 per kWhr   | \$0.00589 per kWhr   | \$0.00515 per kWhr   |
| Total SOS Kilowatt Hour Charge |  |  |  |
| On-Peak                        | \$0.22364 per kWhr   | \$0.22562 per kWhr   | \$0.18043 per kWhr   |
| Off-Peak                       | \$0.07526 per kWhr   | \$0.07724 per kWhr   | \$0.07631 per kWhr   |

\*The Administrative Charge rates typically change every February, June and October.

**MONTHLY RATES (Continued)**

| <b>Transmission Service Charge</b>   | <b>Rate Effective<br/>September 1, 2025</b> |
|--------------------------------------|---|
| <b>Kilowatt-Hour Charge (Summer)</b> | \$0.02101                                   |
| <b>Kilowatt-Hour Charge (Winter)</b> | \$0.02101                                   |

**Procurement Cost Adjustment**See [www.pepco.com](http://www.pepco.com) for currently effective rate

**Generation and Transmission Service Charges** – Customers must receive Generation and Transmission Services from the Company under the provisions of Schedule “R-PIV”. Supply Service Charges for Schedule “R-PIV” will be updated to reflect changes to Rider “SOS” rates.

**BILLING MONTHS**

**Summer** – Billing months of June through October.

**Winter** – Billing months of November through May.

**RATING PERIODS**

On-peak hours are from 12:00 p.m. to 8 p.m. Monday through Friday excluding holidays falling on weekdays. All other hours are off-peak.

**SUPPLY CAPACITY REQUIREMENT**

Should additional service capacity be required for the “off-peak” service, in excess of that provided for regular service, the customer will pay to the Company an amount equal to the estimated cost of the additional facilities. Such payment must be made prior to the commencement of service under this schedule.

**GROSS RECEIPTS TAX**

A surcharge of 2.0408% is applied to the transmission and distribution components of the customer’s bill to recover the amount attributable to the Gross Receipt’s Tax.

**GENERAL TERMS AND CONDITION**

This schedule is subject in all respects to the Company’s “General Terms and Conditions for Furnishing Electric Service” and the Company’s “Electric Service Rules and Regulations.”

**APPLICABLE RIDERS**

Net Energy Metering

Administrative Credit

Delivery Tax Surcharge

Montgomery County Surcharge

Maryland Environmental Surcharge

Bill Stabilization Adjustment

Empower MD Charge

Residential Direct Load Control

Demand Resource Surcharge

Dynamic Pricing – Peak Energy Savings Credit

Universal Service Charge Recovery

Green Rider

Economic Relief and Recovery Rider

MYP Adjustment Rider

Revenue Deferral Mechanism Rider

**MD – SOS****STANDARD OFFER SERVICE  
RIDER “SOS”****RIDER “SOS” – STANDARD OFFER SERVICE**

Available in the Maryland portion of the Company's service area for the provision of Generation and Transmission Services to customers who do not have an alternate supplier for Generation and Transmission Services as defined in the Customer Choice Act, Section 7-510(C)(2).

Standard Offer Service (SOS) is available beginning July 1, 2004 in accordance with the provisions contained in the Maryland Case No. 8908 Settlement Agreements (Phase I and II) approved by the Maryland Public Service Commission in Order Nos. 78400 and 78710 and in the Code of Maryland Regulations (COMAR) 20.52 Electric Standard Offer Service.

**DESCRIPTION OF SOS TYPES****Residential**

Applicable to customers served on Schedules “R”, “R-TM” and “R-TOU-P”.

Customers may leave or return to Rider “SOS” without penalty by the Company, subject to the Company's General Terms and Conditions.

A Customer shall not change Type within the SOS year.

**Type I Non-Residential**

Applicable to customers served on Schedules “GS”, “T”, “SL”, “TN”, “EV”, and “OL”.

Customers may leave or return to Rider “SOS” without penalty by the Company, subject to the Company's General Terms and Conditions.

A Customer shall not change Type within the SOS year.

**Type II Non-Residential**

Applicable to customers served on Schedules “MGT LV II” and “MGT 3A II”.

Customers may leave or return to Rider “SOS” without penalty by the Company, subject to the Company's General Terms and Conditions.

A Customer shall not change Type within the SOS year.

**Hourly-Priced Service (HPS)**

Applicable to customers served on Schedules “MGT LV III”, “MGT 3A III”, “GT LV”, “GT 3A”, “GT 3B” and “TM-RT”.

Customers may leave or return to Rider “SOS” without penalty by the Company, subject to the Company's General Terms and Conditions.

When a customer purchasing from an alternate supplier, other than the Company, returns or is returned to the Company on or after June 1, 2005, the customer will receive HPS.

A Customer shall not change Type within the SOS year.

**MD – SOS****MONTHLY RATE**

Customers receiving Standard Offer Service will pay the Distribution Service Charge, Transmission Service Charge and Generation Service Charge including all applicable riders. The Distribution Service Charges are stated in the Monthly Rates for the Customer's applicable Rate Schedule.

The Standard Offer Service Rate for each Rate Schedule within each SOS Type, including any usage incurred under associated Riders, will include the following components:

1. The seasonally-differentiated and, if applicable, time-of-use differentiated load weighted average of all awarded electric supply prices for specific services in each year.
2. Retail charges designed to recover, on an aggregate basis, FERC-approved transmission charges and any other PJM charges and costs incurred by Pepco.
3. An administrative charge, consisting of incremental, uncollectible and cash working capital cost, an administrative adjustment and a return (included in Generation rates tables below); and;
4. Applicable taxes.

**SOS – Residential (Generation, Transmission including separately calculated GRT, and Procurement Cost Adjustment)**

**Schedule R**

| Generation Service Charge             | 10/01/24 – 01/31/25 | 02/01/25 – 05/31/25 | 06/01/25 – 09/30/25 |
|---------------------------------------|---------------------|---------------------|---------------------|
| <b>SOS Kilowatt-hour Charge</b>       | \$0.10115 per kWhr  | \$0.10115 per kWhr  | \$0.09882 per kWhr  |
| <b>Administrative Charge</b>          | \$0.00391 per kWhr  | \$0.00589 per kWhr  | \$0.00515 per kWhr  |
| <b>Total SOS Kilowatt Hour Charge</b> | \$0.10506 per kWhr  | \$0.10704 per kWhr  | \$0.10397 per kWhr  |

\*The Administrative Charge rates typically change every February, June and October.

| Transmission Service Charge | Summer             | Winter             |
|-----------------------------|--------------------|--------------------|
| Kilowatt-hour Charge        | \$0.02101 per kWhr | \$0.02101 per kWhr |

**Procurement Cost Adjustment**

See [www.pepco.com](http://www.pepco.com) for currently effective rate

**Schedule R-TM**

| Generation Service Charge             | 10/01/24 – 01/31/25 | 02/01/25 – 05/31/25 | 06/01/25 – 09/30/25 |
|---------------------------------------|---------------------|---------------------|---------------------|
| <b>SOS Kilowatt-hour Charge</b>       |                     |                     |                     |
| On Peak                               | \$0.10231 per kWhr  | \$0.10231 per kWhr  | \$0.10243 per kWhr  |
| Intermediate                          | \$0.10221 per kWhr  | \$0.10221 per kWhr  | \$0.09707 per kWhr  |
| Off Peak                              | \$0.10028 per kWhr  | \$0.10028 per kWhr  | \$0.09773 per kWhr  |
| <b>Administrative Charge</b>          | \$0.00391 per kWhr  | \$0.00589 per kWhr  | \$0.00515 per kWhr  |
| <b>Total SOS Kilowatt Hour Charge</b> |                     |                     |                     |
| On Peak                               | \$0.10622 per kWhr  | \$0.10820 per kWhr  | \$0.10758 per kWhr  |
| Intermediate                          | \$0.10612 per kWhr  | \$0.10810 per kWhr  | \$0.10222 per kWhr  |
| Off Peak                              | \$0.10419 per kWhr  | \$0.10617 per kWhr  | \$0.10288 per kWhr  |

\*The Administrative Charge rates typically change every February, June and October.

| Transmission Service Charge | Summer             | Winter             |
|-----------------------------|--------------------|--------------------|
| Kilowatt-hour Charge        | \$0.02092 per kWhr | \$0.02092 per kWhr |

**Procurement Cost Adjustment**

See [www.pepco.com](http://www.pepco.com) for currently effective rate

**MD – SOS****Schedule R-TOU-P**

| Generation Service Charge             | 02/01/25 – 05/31/25 | 06/01/25 – 09/01/25 | 09/01/25 – 09/30/25 |
|---------------------------------------|---------------------|---------------------|---------------------|
| <b>SOS Kilowatt-hour Charge</b>       |                     |                     |                     |
| On Peak                               | \$0.20418 per kWhr  | \$0.28656 per kWhr  | \$0.29398 per kWh   |
| Off Peak                              | \$0.09651 per kWhr  | \$0.07571 per kWhr  | \$0.07571 per kWh   |
| <b>Administrative Charge</b>          | \$0.00589 per kWhr  | \$0.00515 per kWhr  | \$0.00515 per kWh   |
| <b>Total SOS Kilowatt Hour Charge</b> |                     |                     |                     |
| On Peak                               | \$0.21007 per kWhr  | \$0.29171 per kWhr  | \$0.29913 per kWh   |
| Off Peak                              | \$0.10240 per kWhr  | \$0.08086 per kWhr  | \$0.08086 per kWh   |

\*The Administrative Charge rates typically change every February, June and October.

**Transmission Service Charge**

|                                    |  |
|------------------------------------|--|
| <b>Kilowatt-hour Charge</b>        | Included in Generation Service Charge  |
| <b>Procurement Cost Adjustment</b> | See <a href="http://www.pepco.com">www.pepco.com</a> for currently effective rate. |

**Note:** Schedule R-TOU-P billing periods are as follows:

Summer – Billing months are June through September, and On-Peak hours will be between the hours of 2:00 pm and 7:00 pm excluding weekends and holidays. All other hours are off-peak.

Winter - Billing months are October through May, and On-Peak hours will be between the hours of 6:00 am and 9:00 am and the hours of 5:00 pm and 9:00 pm, excluding weekends and holidays. All other hours are off-peak.

**SOS – Type I Non-Residential (Generation, Transmission including separately calculated GRT, and Procurement Cost Adjustment)**

**Schedule GS and EV**

| Generation Service Charge             | 10/01/24 – 01/31/25 | 02/01/25 – 05/31/25 | 06/01/25 – 09/30/25 |
|---------------------------------------|---------------------|---------------------|---------------------|
| <b>SOS Kilowatt-hour Charge</b>       | \$0.10050 per kWhr  | \$0.10050 per kWhr  | \$0.09806 per kWhr  |
| <b>Administrative Charge</b>          | \$0.00326 per kWhr  | \$0.00530 per kWhr  | \$0.00421 per kWhr  |
| <b>Total SOS Kilowatt Hour Charge</b> | \$0.10376 per kWhr  | \$0.10580 per kWhr  | \$0.10227 per kWhr  |

\*The Administrative Charge rates typically change every February, June and October.

| Transmission Service Charge        | Summer  | Winter             |
|------------------------------------|---|--------------------|
| <b>Kilowatt-hour Charge</b>        | \$0.01423 per kWhr  | \$0.01423 per kWhr |
| <b>Procurement Cost Adjustment</b> | See <a href="http://www.pepco.com">www.pepco.com</a> for currently effective rate |                    |

**Schedule T**

| Generation Service Charge             | 10/01/24 – 01/31/25 | 02/01/25 – 05/31/25 | 06/01/25 – 09/30/25 |
|---------------------------------------|---------------------|---------------------|---------------------|
| <b>SOS Kilowatt-hour Charge</b>       | \$0.10050 per kWhr  | \$0.10050 per kWhr  | \$0.09806 per kWhr  |
| <b>Administrative Charge</b>          | \$0.00326 per kWhr  | \$0.00530 per kWhr  | \$0.00421 per kWhr  |
| <b>Total SOS Kilowatt Hour Charge</b> | \$0.10376 per kWhr  | \$0.10580 per kWhr  | \$0.10227 per kWhr  |

\*The Administrative Charge rates typically change every February, June and October.

| Transmission Service Charge        | Summer  | Winter             |
|------------------------------------|---|--------------------|
| <b>Kilowatt-hour Charge</b>        | \$0.01063 per kWhr  | \$0.01063 per kWhr |
| <b>Procurement Cost Adjustment</b> | See <a href="http://www.pepco.com">www.pepco.com</a> for currently effective rate |                    |

**Schedule SL**

| Generation Service Charge             | 10/01/24 – 01/31/25 | 02/01/25 – 05/31/25 | 06/01/25 – 09/30/25 |
|---------------------------------------|---------------------|---------------------|---------------------|
| <b>SOS Kilowatt-hour Charge</b>       | \$0.09791 per kWhr  | \$0.09791 per kWhr  | \$0.09353 per kWhr  |
| <b>Administrative Charge</b>          | \$0.00326 per kWhr  | \$0.00530 per kWhr  | \$0.00421 per kWhr  |
| <b>Total SOS Kilowatt Hour Charge</b> | \$0.10117 per kWhr  | \$0.10321 per kWhr  | \$0.09774 per kWhr  |

\*The Administrative Charge rates typically change every February, June and October.

| Transmission Service Charge        | Summer  | Winter             |
|------------------------------------|---|--------------------|
| <b>Kilowatt-hour Charge</b>        | \$0.00007 per kWhr  | \$0.00007 per kWhr |
| <b>Procurement Cost Adjustment</b> | See <a href="http://www.pepco.com">www.pepco.com</a> for currently effective rate |                    |

**MD – SOS****MONTHLY RATE (continued)****Schedule OL**

| Mercury Vapor (10/01/24 to 01/31/25) |                          |                      |                       |          |
|--------------------------------------|--------------------------|----------------------|-----------------------|----------|
| Generation Rates                     | \$/kWh Rate <sup>1</sup> | kW/lamp <sup>2</sup> | kWh / mo <sup>3</sup> | \$ Lamp  |
| 175 Watt Lamp                        | \$0.10117                | 0.210                | 73.50                 | \$ 7.44  |
| 250 Watt Lamp                        | \$0.10117                | 0.290                | 101.50                | \$ 10.27 |
| 400 Watt Lamp                        | \$0.10117                | 0.445                | 155.75                | \$ 15.76 |

| Mercury Vapor (02/01/25 to 05/31/25) |                          |                      |                       |          |
|--------------------------------------|--------------------------|----------------------|-----------------------|----------|
| Generation Rates                     | \$/kWh Rate <sup>1</sup> | kW/lamp <sup>2</sup> | kWh / mo <sup>3</sup> | \$ Lamp  |
| 175 Watt Lamp                        | \$0.10321                | 0.210                | 73.50                 | \$ 7.59  |
| 250 Watt Lamp                        | \$0.10321                | 0.290                | 101.50                | \$ 10.48 |
| 400 Watt Lamp                        | \$0.10321                | 0.445                | 155.75                | \$ 16.07 |

| Mercury Vapor (06/01/25 to 09/30/25) |                          |                      |                       |          |
|--------------------------------------|--------------------------|----------------------|-----------------------|----------|
| Generation Rates                     | \$/kWh Rate <sup>1</sup> | kW/lamp <sup>2</sup> | kWh / mo <sup>3</sup> | \$ Lamp  |
| 175 Watt Lamp                        | \$0.09774                | 0.210                | 73.50                 | \$ 7.18  |
| 250 Watt Lamp                        | \$0.09774                | 0.290                | 101.50                | \$ 9.92  |
| 400 Watt Lamp                        | \$0.09774                | 0.445                | 155.75                | \$ 15.22 |

| High Pressure Sodium (10/01/24 to 01/31/25) |                          |                      |                       |          |
|---|--------------------------|----------------------|-----------------------|----------|
| Generation Rates                            | \$/kWh Rate <sup>1</sup> | kW/lamp <sup>2</sup> | kWh / mo <sup>3</sup> | \$ Lamp  |
| 100 Watt Lamp                               | \$0.10117                | 0.120                | 42.00                 | \$ 4.25  |
| 150 Watt Lamp                               | \$0.10117                | 0.175                | 61.25                 | \$ 6.20  |
| 250 Watt Lamp                               | \$0.10117                | 0.295                | 103.25                | \$ 10.45 |

| High Pressure Sodium (02/01/25 to 05/31/25) |                          |                      |                       |          |
|---|--------------------------|----------------------|-----------------------|----------|
| Generation Rates                            | \$/kWh Rate <sup>1</sup> | kW/lamp <sup>2</sup> | kWh / mo <sup>3</sup> | \$ Lamp  |
| 100 Watt Lamp                               | \$0.10321                | 0.120                | 42.00                 | \$ 4.33  |
| 150 Watt Lamp                               | \$0.10321                | 0.175                | 61.25                 | \$ 6.32  |
| 250 Watt Lamp                               | \$0.10321                | 0.295                | 103.25                | \$ 10.66 |

| High Pressure Sodium (06/01/25 to 09/30/25) |                          |                      |                       |          |
|---|--------------------------|----------------------|-----------------------|----------|
| Generation Rates                            | \$/kWh Rate <sup>1</sup> | kW/lamp <sup>2</sup> | kWh / mo <sup>3</sup> | \$ Lamp  |
| 100 Watt Lamp                               | \$0.09774                | 0.120                | 42.00                 | \$ 4.11  |
| 150 Watt Lamp                               | \$0.09774                | 0.175                | 61.25                 | \$ 5.99  |
| 250 Watt Lamp                               | \$0.09774                | 0.295                | 103.25                | \$ 10.09 |

<sup>1)</sup>Administrative charge included in \$/kWh rate<sup>2)</sup>kW/lamp includes ballast<sup>3)</sup>kWh/month = 4200 Burning Hours / Year \*kW/lamp/12<sup>4)</sup>Winter rates are available after Tranche 3

| Transmission Service Charge | Summer          | Winter          |
|-----------------------------|-----------------|-----------------|
| 175 Watt                    | \$0.00 per lamp | \$0.00 per lamp |
| 250 Watt                    | \$0.00 per lamp | \$0.00 per lamp |
| 400 Watt                    | \$0.00 per lamp | \$0.00 per lamp |

Procurement Cost Adjustment

See [www.pepco.com](http://www.pepco.com) for currently effective rate

**MD – SOS****MONTHLY RATE (continued)****Schedule TN and Rider SL-TN**

| <b>Generation Service Charge</b>      | <b>10/01/24 – 01/31/25</b> | <b>02/01/25 – 05/31/25</b> | <b>06/01/25 – 09/30/25</b> |
|---------------------------------------|----------------------------|----------------------------|----------------------------|
| <b>SOS Kilowatt-hour Charge</b>       | \$0.09646 per kWhr         | \$0.09646 per kWhr         | \$0.13168 per kWhr         |
| <b>Administrative Charge</b>          | \$0.00326 per kWhr         | \$0.00530 per kWhr         | \$0.00421 per kWhr         |
| <b>Total SOS Kilowatt Hour Charge</b> | \$0.09972 per kWhr         | \$0.10176 per kWhr         | \$0.13589 per kWhr         |

\*The Administrative Charge rates typically change every February, June and October.

| <b>Transmission Service Charge</b> | <b>Summer</b>  | <b>Winter</b>      |
|------------------------------------|----------------|--------------------|
| <b>Kilowatt-hour Charge</b>        | \$0.00901 kWhr | \$0.00901 per kWhr |

**Procurement Cost Adjustment**

See [www.pepco.com](http://www.pepco.com) for currently effective rate

**SOS – Type II Non-Residential (Generation, Transmission including separately calculated GRT, and Procurement Cost Adjustment)****Schedule MGT LV II**

| <b>Generation Service Charge</b>      | <b>02/01/25 – 02/28/25</b> | <b>03/01/25 – 05/31/25</b> | <b>06/01/25 – 08/31/25</b> |
|---------------------------------------|----------------------------|----------------------------|----------------------------|
| <b>SOS Kilowatt-hour Charge</b>       |                            |                            |                            |
| <b>On-Peak</b>                        | \$0.08417 per kWhr         | \$0.07329 per kWhr         | \$0.11609 per kWhr         |
| <b>Intermediate</b>                   | \$0.08417 per kWhr         | \$0.07218 per kWhr         | \$0.10575 per kWhr         |
| <b>Off-Peak</b>                       | \$0.08417 per kWhr         | \$0.07039 per kWhr         | \$0.10257 per kWhr         |
| <b>Administrative Charge</b>          | \$0.00255 per kWhr         | \$0.00255 per kWhr         | \$0.00302 per kWhr         |
| <b>Total SOS Kilowatt hour Charge</b> |                            |                            |                            |
| <b>On-Peak</b>                        | \$0.08672 per kWhr         | \$0.07584 per kWhr         | \$0.11911 per kWhr         |
| <b>Intermediate</b>                   | \$0.08672 per kWhr         | \$0.07473 per kWhr         | \$0.10877 per kWhr         |
| <b>Off-Peak</b>                       | \$0.08672 per kWhr         | \$0.07294 per kWhr         | \$0.10559 per kWhr         |

\*The Administrative Charge rates typically change every February, June and October.

| <b>Transmission Service Charge</b> | <b>Summer</b>      | <b>Winter</b>      |
|------------------------------------|--------------------|--------------------|
| <b>Kilowatt-hour Charge</b>        | \$0.00863 per kWhr | \$0.00863 per kWhr |
| <b>Kilowatt Charge</b>             |                    |                    |
| <b>On Peak</b>                     | \$1.9081 per kw    |                    |
| <b>Maximum</b>                     | \$1.3890 per kw    | \$1.3890 per kw    |

**Procurement Cost Adjustment**

See [www.pepco.com](http://www.pepco.com) for currently effective rate

**Schedule MGT 3A II**

| Generation Service Charge             | 02/01/25 – 02/28/25 | 03/01/25 – 05/31/25 | 06/01/25 – 08/31/25 |
|---------------------------------------|---------------------|---------------------|---------------------|
| <b>SOS Kilowatt-hour Charge</b>       |                     |                     |                     |
| On-Peak                               | \$0.08339 per kWhr  | \$0.07261 per kWhr  | \$0.11501 per kWhr  |
| Intermediate                          | \$0.08339 per kWhr  | \$0.07151 per kWhr  | \$0.10476 per kWhr  |
| Off-Peak                              | \$0.08339 per kWhr  | \$0.06973 per kWhr  | \$0.10162 per kWhr  |
| <b>Administrative Charge</b>          | \$0.00255 per kWhr  | \$0.00255 per kWhr  | \$0.00302 per kWhr  |
| <b>Total SOS Kilowatt Hour Charge</b> |                     |                     |                     |
| On-Peak                               | \$0.08594 per kWhr  | \$0.07516 per kWhr  | \$0.11803 per kWhr  |
| Intermediate                          | \$0.08594 per kWhr  | \$0.07406 per kWhr  | \$0.10778 per kWhr  |
| Off-Peak                              | \$0.08594 per kWhr  | \$0.07228 per kWhr  | \$0.10464 per kWhr  |

\*The Administrative Charge rates typically change every February, June and October.

| Transmission Service Charge | Summer             | Winter             |
|-----------------------------|--------------------|--------------------|
| <b>Kilowatt-hour Charge</b> | \$0.00850 per kWhr | \$0.00850 per kWhr |
| <b>Kilowatt Charge</b>      |                    |                    |
| On Peak                     | \$1.8493 per kw    |                    |
| Maximum                     | \$1.3602 per kw    | \$1.3602 per kw    |

**Procurement Cost Adjustment**

See [www.pepco.com](http://www.pepco.com) for currently effective rate

**SOS – Hourly Priced Service (HPS)****Schedules MGT LV III, MGT 3A III, GT LV, GT 3A, GT 3B, and TM-RT****Generation Service Charge****The Hourly Price Service will include:**

1. **Market Hourly Energy Charge** – The Customer's hourly energy usage, adjusted for applicable losses, multiplied by the hourly energy charge.

The hourly energy charge will consist of the 1) hourly integrated real time fixed nodal weighted aggregate Locational Marginal Price (LMP) values for the Pepco zone, or its successor for the retail load served in Pepco's Maryland service area, as determined and reported by the PJM; 2) An Administrative Charge (consisting of incremental, uncollectible and cash-working capital costs, an administrative adjustment, and a return) of \$ 0.00287, any applicable taxes, and other items as provided for in paragraphs 79 and 82 of the Phase I Settlement in Maryland Case No. 8908; and 3) Generation Ancillary Service Charges based on the previous month's average cents per kWh generation ancillary service cost for HPS customers in the Pepco Zone as determined and reported by PJM.

2. **Monthly Capacity Charge** – Determined by summing over each day during the Customer's billing period the Customer's obligation in MW multiplied by the daily cost per MW of procuring capacity. The daily Capacity procurement cost shall be in dollars per MW-day, based on capacity purchased to cover HPS shortages and any penalties or deficiency charges and broker fees accruing for the day of the calculation.

When a Customer's account does not have interval data, the Customer's historical data will be used to develop the hourly use.

**Transmission Service Charge** – The transmission service charges stated in this SOS – Hourly Priced Service (HPS) section apply only to Type III customers receiving HPS from Pepco.

**Transmission Service Charge****Schedule MGT LV III**

|                             | <b>Summer</b>      | <b>Winter</b>      |
|-----------------------------|--------------------|--------------------|
| <b>Kilowatt-hour Charge</b> | \$0.00863 per kWhr | \$0.00863 per kWhr |
| <b>Kilowatt Charge</b>      |                    |                    |
| <b>On Peak</b>              | \$ 1.9081 per kw   |                    |
| <b>Maximum</b>              | \$ 1.3890 per kw   | \$ 1.3890 per kw   |

**Schedule MGT 3A III**

|                             | <b>Summer</b>      | <b>Winter</b>      |
|-----------------------------|--------------------|--------------------|
| <b>Kilowatt-hour Charge</b> | \$0.00850 per kWhr | \$0.00850 per kWhr |
| <b>Kilowatt Charge</b>      |                    |                    |
| <b>On Peak</b>              | \$1.8493 per kw    |                    |
| <b>Maximum</b>              | \$1.3602 per kw    | \$1.3602 per kw    |

**Schedule GT LV**

|                             | <b>Summer</b>      | <b>Winter</b>      |
|-----------------------------|--------------------|--------------------|
| <b>Kilowatt-hour Charge</b> | \$0.00773 per kWhr | \$0.00773 per kWhr |
| <b>Kilowatt Charge</b>      |                    |                    |
| <b>On Peak</b>              | \$2.0515 per kw    |                    |
| <b>Maximum</b>              | \$1.5153 per kw    | \$1.5153 per kw    |

**Schedule GT 3A**

|                             | <b>Summer</b>      | <b>Winter</b>      |
|-----------------------------|--------------------|--------------------|
| <b>Kilowatt-hour Charge</b> | \$0.00737 per kWhr | \$0.00737 per kWhr |
| <b>Kilowatt Charge</b>      |                    |                    |
| <b>On Peak</b>              | \$1.9975 per kw    |                    |
| <b>Maximum</b>              | \$1.4938 per kw    | \$1.4938 per kw    |

**Schedule GT 3B**

|                             | <b>Summer</b>      | <b>Winter</b>      |
|-----------------------------|--------------------|--------------------|
| <b>Kilowatt-hour Charge</b> | \$0.00703 per kWhr | \$0.00703 per kWhr |
| <b>Kilowatt Charge</b>      |                    |                    |
| <b>On Peak</b>              | \$1.8429 per kw    |                    |
| <b>Maximum</b>              | \$1.3556 per kw    | \$1.3556 per kw    |

**Schedule TM-RT**

|                             | <b>Summer</b>      | <b>Winter</b>      |
|-----------------------------|--------------------|--------------------|
| <b>Kilowatt-hour Charge</b> | \$0.00702 per kWhr | \$0.00702 per kWhr |
| <b>Kilowatt Charge</b>      |                    |                    |
| <b>On Peak</b>              | \$1.2224 per kw    |                    |
| <b>Maximum</b>              | \$0.8793 per kw    | \$0.8793 per kw    |

The monthly HPS charges shall equal the actual cost of providing energy and capacity supply transmission service, ancillary service, and any other cost element directly related to the Company's HPS load obligation, including an Administrative Charge and applicable taxes.

The Company will determine an Hourly Price Service Procurement Cost Adjustment (HPS – PCA) which will reflect the difference between the actual cost of serving Customers under HPS (including any cost adjustments from the PJM Settlement system) and the amount billed to HPS Customers for the same time period. The Company will determine the HPS-PCA rate by dividing the HPS-PCA amount by the total kilowatt-hour sales of the then current HPS customers. The HPS-PCA rate will be applied to each of the then current HPS customers' sales to determine the credit/charge for the billing month.

At the conclusion of Hourly Price Service on June 1, 2006, any HPS PCA will be returned to, or collected from all Type II Customers regardless of their supplier.

**BILLING MONTHS**

**Summer** – Billing months of June through October  
**Winter** – Billing months of November through May.

**RATING PERIODS****Weekdays - (Excluding Holidays)**

|                     |                             |     |                             |
|---------------------|-----------------------------|-----|-----------------------------|
| On-Peak Period      | 12:00 noon                  | to  | 8:00 p.m.                   |
| Intermediate Period | 8:00 a.m.                   | to  | 12:00 noon                  |
|                     |                             | and |                             |
| Off-Peak Period     | 8:00 p.m.<br>12:00 midnight | to  | 12:00 midnight<br>8:00 a.m. |

**Saturdays, Sundays and Holidays**

Off-Peak Period      All Hours

**Holidays**

Holidays include all holidays as designated by the Federal Government.

**BILLING DEMANDS**

On-Peak (Summer Billing Months Only) - The billing demand shall be the maximum thirty (30) minute demand recorded during the on-peak period of the billing month.

Maximum (All Months) - The billing demand shall be the maximum thirty (30) minute demand recorded during the billing month.

**PROCUREMENT COST ADJUSTMENT**

In addition to the Standard Offer Service rates shown above, for Residential, Type I, and Type II customers (excludes HPS customers) there will be a monthly Procurement Cost Adjustment (PCA) shown as a separate line item on the Customer's bill. Refer to HPS for the Hourly Priced Service Procurement Cost Adjustment (HPS-PCA).

The PCA is a \$ per kilowatt-hour rate applied to the Customer's billed kilowatt-hours.

The PCA is an adjustment made in order to true-up the rates customers are billed to reflect the Company's actual costs of providing Standard Offer Service.

A true-up adjustment will be made to the PCA at least three (3) times per year- effective with the June, November and February billing months. These true-ups will revise the PCA based on actual and forecasted collections of SOS revenues by SOS Type and the actual and forecasted cost of providing Standard Offer Service.

The current applicable PCA rate by SOS Type is available on the Company's website at [www.pepco.com](http://www.pepco.com).

**PUBLICATION OF PRICES**

The Standard Offer Service Rates shown in this Rider are posted on the Company's website at [www.pepco.com](http://www.pepco.com).

The market hourly Locational Marginal Prices used for HPS are available on the PJM website at [www.pjm.com](http://www.pjm.com).

---

## Redlined Pages

**RATE SCHEDULES  
FOR  
ELECTRIC SERVICE  
IN  
MARYLAND  
POTOMAC ELECTRIC POWER COMPANY**



**RATES AND REGULATORY PRACTICES GROUP**

**TABLE OF CONTENTS  
RATE SCHEDULES**

|  |                  |
|--|------------------|
| RESIDENTIAL SERVICE - SCHEDULE "R" .....   | Page 3 - 3.1     |
| TIME METERED RESIDENTIAL SERVICE - SCHEDULE "R-TM" .....   | Page 4 - 4.1     |
| GENERAL SERVICE - SCHEDULE "GS" .....  | Page 5 - 5.1     |
| TEMPORARY SERVICE - SCHEDULE "T" .....   | Page 6 - 6.1     |
| TIME METERED MEDIUM GENERAL SERVICE - LOW VOLTAGE - TYPE II<br>SCHEDULE "MGT LV II" .....  | Page 7 - 7.2     |
| TIME METERED MEDIUM GENERAL SERVICE - LOW VOLTAGE - TYPE II A<br>SCHEDULE "MGT LV II A" (THIS SCHEDULE HAS BEEN DELETED) .....     | Page 7.3 – 7.5   |
| TIME METERED MEDIUM GENERAL SERVICE - LOW VOLTAGE - TYPE III<br>SCHEDULE "MGT LV III" .....  | Page 7.6 – 7.8   |
| TIME METERED MEDIUM GENERAL SERVICE - PRIMARY SERVICE - TYPE II<br>SCHEDULE "MGT 3A II" .....                                      | Page 8 - 8.2     |
| TIME METERED MEDIUM GENERAL SERVICE - PRIMARY SERVICE - TYPE II A<br>SCHEDULE "MGT 3A II A" (THIS SCHEDULE HAS BEEN DELETED) ..... | Page 8.2 – 8.5   |
| TIME METERED MEDIUM GENERAL SERVICE - PRIMARY SERVICE - TYPE III<br>SCHEDULE "MGT 3A III" .....                                    | Page 8.6 – 8.8   |
| TIME METERED GENERAL SERVICE - LOW VOLTAGE -<br>SCHEDULE "GT LV" .....   | Page 9 - 9.2     |
| TIME METERED GENERAL SERVICE - PRIMARY SERVICE -<br>SCHEDULE "GT 3A" .....   | Page 10 - 10.2   |
| TIME METERED GENERAL SERVICE - HIGH VOLTAGE -<br>SCHEDULE "GT 3B" .....  | Page 11 - 11.2   |
| TIME METERED RAPID TRANSIT SERVICE - SCHEDULE "TM-RT" .....  | Page 12 - 12.1   |
| ELECTRIC VEHICLE SERVICE - SCHEDULE "EV" .....   | Page 13 – 13.1   |
| (THIS SCHEDULE IS CLOSED TO NEW CUSTOMERS)   |                  |
| OUTDOOR LIGHTING SERVICE - SCHEDULE "OL" .....   | Page 14 - 14.1   |
| STREET LIGHTING SERVICE - SCHEDULE "SL" .....  | Page 15 - 15.1   |
| SERVICING STREET LIGHTS SERVED FROM OVERHEAD LINES -<br>SCHEDULE "SSL-OH" .....  | Page 16 - 16.3   |
| SERVICING STREET LIGHTS SERVED FROM UNDERGROUND<br>LINES - SCHEDULE "SSL-UG" .....   | Page 17 - 17.2   |
| SERVICING STREET LIGHTS SERVED FROM OVERHEAD LINES –<br>SCHEDULE "SSL-OH-LED" .....  | Page 17.3 – 17.5 |
| SERVICING STREET LIGHTS SERVED FROM UNDERGROUND LINES –<br>SCHEDULE "SSL-UG-LED" .....   | Page 17.6 – 17.9 |

|  |                                |
|--|--------------------------------|
| TELECOMMUNICATIONS NETWORK SERVICE - SCHEDULE "TN" .....   | <a href="#">Page 18 - 18.1</a> |
| COGENERATION AND SMALL POWER PRODUCTION INTERCONNECTION<br>SERVICE - SCHEDULE "CG-SPP" PURCHASE OF POWER ..... | <a href="#">Page 19 - 19.4</a> |
| STANDBY SERVICE - SCHEDULE "S" .....   | <a href="#">Page 20 - 20.1</a> |
| PLUG-IN VEHICLE CHARGING – SCHEDULE “PIV” .....  | <a href="#">Page 21 - 21.1</a> |
| RESIDENTIAL SERVICE – PLUG-IN VEHICLE CHARGING – SCHEDULE “R-PIV” .....  | <a href="#">Page 22 – 22.1</a> |
| COMMUNITY SOLAR PILOT PROGRAM – SCHEDULE “CS” .....  | <a href="#">Page 23 – 23.6</a> |
| RESIDENTIAL TIME-OF-USE PROGRAM – SCHEDULE “R-TOU-P” .....   | <a href="#">Page 24 – 24.1</a> |
| PUBLIC ELECTRIC VEHICLE CHARGING SERVICE – SCHEDULE “PC-PIV” .....   | <a href="#">Page 25 – 25.1</a> |
| RESERVED FOR FUTURE USE.....   | <a href="#">Page 25.2 – 26</a> |

## RIDERS

|  |                                |
|--|--------------------------------|
| MARKET PRICE SERVICE - RIDER "MPS" .....   | <a href="#">Page 27 - 27.1</a> |
| (THIS RIDER HAS BEEN DELETED)  |                                |
| UNIVERSAL SERVICE CHARGE RECOVERY - RIDER "USC" .....                                    | <a href="#">Page 28</a>        |
| GENERATION PROCUREMENT CREDIT - RIDER "GPC".....   | <a href="#">Page 29 - 29.1</a> |
| (THIS RIDER HAS BEEN DELETED)  |                                |
| EXPERIMENTAL RESIDENTIAL ELECTRIC VEHICLE SERVICE -<br>RIDER "R-EV" .....                | <a href="#">Page 30</a>        |
| EXPERIMENTAL RESIDENTIAL TIME-OF-USE ELECTRIC VEHICLE<br>SERVICE - RIDER "R-TM-EV" ..... | <a href="#">Page 30.2</a>      |
| NET ENERGY METERING "NEM" .....  | <a href="#">Page 31 – 31.3</a> |
| EXPERIMENTAL CONJUNCTIVE BILLING SERVICE – RIDER “CBS” .....                             | <a href="#">Page 32 – 32.1</a> |
| (THIS RIDER HAS BEEN DELETED)  |                                |
| TELECOMMUNICATION NETWORK CHARGE - RIDER "SL-TN" .....                                   | <a href="#">Page 33</a>        |
| POWER FACTOR - RIDER "PF" .....  | <a href="#">Page 34</a>        |
| THERMAL ENERGY STORAGE SERVICE - RIDER "TS" .....  | <a href="#">Page 35</a>        |
| DELIVERY TAX SURCHARGE - RIDER "DT" .....  | <a href="#">Page 36</a>        |
| MONTGOMERY COUNTY SURCHARGE - RIDER "MCS" .....  | <a href="#">Page 37</a>        |
| MARYLAND ENVIRONMENTAL SURCHARGE - RIDER "MES" .....                                     | <a href="#">Page 38</a>        |

|  |                                 |
|--|---------------------------------|
| TEMPORARY TAX COMPLIANCE SURCHARGE - RIDER "TTCS" .....<br>(THIS RIDER HAS BEEN DELETED)           | <a href="#">Page 39</a>         |
| OPTIONAL METER EQUIPMENT RELATED SERVICES - RIDER "OMRS".....                                      | <a href="#">Pages 40 – 40.2</a> |
| EXCESS FACILITIES - RIDER "EF" .....   | <a href="#">Page 41</a>         |
| DIVESTITURE SHARING CREDIT - RIDER "DS".....<br>(THIS RIDER HAS BEEN DELETED)                      | <a href="#">Page 42</a>         |
| STANDARD OFFER SERVICE - RIDER "SOS".....  | <a href="#">Page 43 – 43.7</a>  |
| ADMINISTRATIVE CREDIT – RIDER “AC” .....   | <a href="#">Page 44</a>         |
| SOS PHASE IN CREDIT/DEFERRED COST ADJUSTMENT–RIDER “SOS PIC/DCA”.<br>(THIS RIDER HAS BEEN DELETED) | <a href="#">Page 45 – 45.1</a>  |
| RESERVED DELIVERY CAPACITY SERVICE – RIDER “RDCS”.....   | <a href="#">Page 46 – 46.1</a>  |
| BILL STABILIZATION ADJUSTMENT – RIDER “BSA” .....  | <a href="#">Page 47 – 47.1</a>  |
| EMPOWER MD CHARGE - RIDER “E-MD” .....   | <a href="#">Page 48 – 48.1</a>  |
| RESIDENTIAL DIRECT LOAD CONTROL – RIDER “R-DLC” .....  | <a href="#">Page 49 – 49.1</a>  |
| RGGI RATE CREDIT – RIDER “RRC” .....   | <a href="#">Page 50</a>         |
| MASTER-METERED DIRECT LOAD CONTROL – RIDER “MM-DLC”.....<br>(THIS RIDER HAS BEEN DELETED)          | <a href="#">Page 51 – 51.1</a>  |
| AGGREGATE NET ENERGY METERING – RIDER “ANEM”.....  | <a href="#">Page 52 – 52.4</a>  |
| NON-RESIDENTIAL DIRECT LOAD CONTROL – RIDER “NR-DLC” .....   | <a href="#">Page 53</a>         |
| DEMAND RESOURCE SURCHARGE – RIDER “DRS” .....  | <a href="#">Page 54 – 54.1</a>  |
| DYNAMIC PRICING – PEAK ENERGY SAVINGS CREDIT – RIDER “DP” .....                                    | <a href="#">Page 55 – 55.1</a>  |
| GRID RESILIENCY CHARGE – RIDER “GRC” .....   | <a href="#">Page 56 – 56.1</a>  |
| COMMUNITY NET ENERGY METERING PILOT PROGRAM “RIDER CNM” .....                                      | <a href="#">Page 57 – 57.1</a>  |
| ELECTRIC VEHICLE CHARGING PROGRAM – RIDER “EVCP” .....   | <a href="#">Page 58 – 58.5</a>  |
| GREEN RIDER – RIDER “GREEN” .....  | <a href="#">Page 59</a>         |
| ELECTRIC VEHICLE CHARGING DISTRIBUTION DEMAND CHARGE   |                                 |
| CREDIT – RIDER “EVCDCCC” .....   | <a href="#">Page 60 - 60.1</a>  |
| ECONOMIC RELIEF AND RECOVERY RIDER - RIDER “ERR” .....   | <a href="#">Page 61 - 61.8</a>  |
| MULTI-YEAR PLAN (“MYP”) ADJUSTMENT RIDER – RIDER “MYP” ADJUSTMENT ...                              | <a href="#">Page 62 - 62.1</a>  |
| REVENUE DEFERRAL MECHANISM RIDER – RIDER “RDM”.....  | <a href="#">Page 63 – 63.10</a> |
| SMALL GENERATOR INTERCONNECTION STANDARD.....  | <a href="#">Page 64</a>         |

## Summary Rider

Rates and charges included in the Rate Schedules listed in the summary matrix shall be modified with the terms and conditions consistent with the indicated Riders:

|   | Rider           | Rate Schedule |      |    |   |           |            |           |            |       |       |       |       |    |    |
|---|-----------------|---------------|------|----|---|-----------|------------|-----------|------------|-------|-------|-------|-------|----|----|
|   |                 | R             | R-TM | GS | T | MGT LV II | MGT LV III | MGT 3A II | MGT 3A III | GT LV | GT 3A | GT 3B | TM-RT | EV | OL |
|   | <b>GRT</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| A | <b>USC</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
|   | <b>R-EV</b>     | X             |      |    |   |           |            |           |            |       |       |       |       |    |    |
|   | <b>R-TM-EV</b>  |               | X    |    |   |           |            |           |            |       |       |       |       |    |    |
|   | <b>NEM</b>      | X             | X    | X  |   | X         | X          | X         | X          | X     | X     | X     |       |    |    |
| I | <b>SL-TN</b>    |               |      |    |   |           |            |           |            |       |       |       |       |    |    |
|   | <b>PF</b>       |               |      | X  |   | X         | X          | X         | X          | X     | X     | X     |       |    |    |
|   | <b>TS</b>       |               |      |    |   | X         | X          | X         | X          | X     | X     | X     |       |    |    |
| F | <b>DT</b>       | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| E | <b>MCS</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| E | <b>MES</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
|   | <b>OMRS</b>     | X             | X    | X  |   | X         | X          | X         | X          | X     | X     | X     | X     |    |    |
|   | <b>EF</b>       |               |      |    |   | X         | X          | X         | X          | X     | X     | X     | X     |    |    |
| D | <b>SOS</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| G | <b>PCA*</b>     | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| G | <b>HPS*</b>     |               |      |    |   | X         |            |           | X          | X     | X     | X     |       |    |    |
| G | <b>AC</b>       | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
|   | <b>RDCS</b>     |               |      |    |   | X         | X          | X         | X          | X     | X     | X     | X     |    |    |
| G | <b>BSA</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     |       |    | X  |
| A | <b>E-MD</b>     | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
|   | <b>R-DLC</b>    | X             | X    |    |   |           |            |           |            |       |       |       |       |    |    |
| H | <b>RRC</b>      | X             | X    |    |   |           |            |           |            |       |       |       |       |    |    |
|   | <b>MM-DLC</b>   |               |      |    |   | X         | X          | X         | X          | X     | X     | X     | X     | X  |    |
|   | <b>ANEM</b>     | X             | X    | X  |   | X         | X          | X         | X          | X     | X     | X     |       |    |    |
|   | <b>NR-DLC</b>   |               |      | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| B | <b>DRS</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| A | <b>DP</b>       | X             | X    |    |   |           |            |           |            |       |       |       |       |    |    |
| A | <b>GRC</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
|   | <b>CNM</b>      |               |      |    |   |           |            |           |            |       |       |       |       |    |    |
|   | <b>EVCP</b>     | X             |      | X  |   | X         | X          | X         | X          | X     | X     | X     | X     |    |    |
| C | <b>GREEN</b>    |               |      |    |   |           |            |           |            |       |       |       |       |    |    |
|   | <b>EVCDCCC</b>  |               |      |    |   | X         | X          | X         | X          | X     | X     | X     | X     |    |    |
|   | <b>ERR</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
| I | <b>MYP ADJ.</b> | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |
|   | <b>RDM</b>      | X             | X    | X  | X | X         | X          | X         | X          | X     | X     | X     | X     | X  | X  |

**Key:**

X – Rider is applicable or available to the Rate Schedule indicated

\* – A component of Rider SOS

A – Rider is reconciled and updated annually during the first quarter of each year

B – Rider is reconciled and updated annually during the second quarter of each year

C – Rider is reconciled and updated biannually during the first and third quarters of each year

D – Rider is updated biannually with SOS – Type II rates updated on a quarterly basis

E – Off-rider rates are tracked on a monthly basis and updated annually

F – Off-rider rate is tracked on a monthly basis and updated upon change in the enacted franchise tax rate

G – Off-rider rates are tracked and updated on a monthly basis

H – Off-rider rates are tracked and updated on a quarterly basis

I – Rider is updated periodically

## Summary Rider

Rates and charges included in the Rate Schedules listed in the summary matrix shall be modified with the terms and conditions consistent with the indicated Riders:

|   | Rider    | SL | SSL-OH | SSL-UG | SSL-OH-LED | SSL-UG-LED | TN | S | PIV | R-PIV | CS | R-TOU-P | PC-PIV |
|---|----------|----|--------|--------|------------|------------|----|---|-----|-------|----|---------|--------|
|   | GRT      | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
| A | USC      |    |        |        |            |            |    |   |     | X     |    | X       |        |
|   | R-EV     |    |        |        |            |            |    |   |     |       |    |         |        |
|   | R-TM-EV  |    |        |        |            |            |    |   |     |       |    |         |        |
|   | NEM      |    |        |        |            |            |    |   | X   |       |    | X       |        |
| I | SL-TN    | X  | X      | X      | X          | X          |    |   |     |       |    |         |        |
|   | PF       |    |        |        |            |            |    |   |     |       |    |         |        |
|   | TS       |    |        |        |            |            |    |   |     |       |    |         |        |
| F | DT       | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
| E | MCS      | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
| E | MES      | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
|   | OMRS     |    |        |        |            |            |    |   |     |       |    | X       |        |
|   | EF       |    |        |        |            |            |    |   |     |       |    |         |        |
| D | SOS      | X  | X      | X      | X          | X          | X  |   |     |       |    | X       |        |
| G | PCA*     | X  | X      | X      | X          | X          | X  |   |     |       |    | X       |        |
| G | HPS*     |    |        |        |            |            |    |   |     |       |    |         |        |
| G | AC       | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
|   | RDCS     |    |        |        |            |            |    |   |     |       |    |         |        |
| G | BSA      |    |        |        |            |            |    |   | X   | X     |    | X       |        |
| A | E-MD     | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
|   | R-DLC    |    |        |        |            |            |    |   |     | X     |    | X       |        |
| H | RRC      |    |        |        |            |            |    |   |     |       |    | X       |        |
|   | MM-DLC   |    |        |        |            |            |    |   |     |       |    |         |        |
|   | ANEM     |    |        |        |            |            |    |   |     |       |    |         |        |
|   | NR-DLC   | X  | X      | X      | X          | X          | X  |   |     |       |    |         |        |
| B | DRS      | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
| A | DP       |    |        |        |            |            |    |   | X   | X     |    | X       |        |
| A | GRC      | X  | X      | X      | X          | X          | X  |   |     |       |    |         |        |
|   | CNM      |    |        |        |            |            |    |   |     |       | X  |         |        |
|   | EVCP     |    |        |        |            |            |    |   |     | X     |    | X       |        |
| C | GREEN    |    |        |        |            |            |    |   | X   | X     |    |         | X      |
|   | EVCDCC   |    |        |        |            |            |    |   |     |       |    |         |        |
|   | ERR      | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       | X      |
| I | MYP ADJ. | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |
|   | RDM      | X  | X      | X      | X          | X          | X  |   | X   | X     |    | X       |        |

**Key:**

X – Rider is applicable or available to the Rate Schedule indicated

\* – A component of Rider SOS

A – Rider is reconciled and updated annually during the first quarter of each year

B – Rider is reconciled and updated annually during the second quarter of each year

C – Rider is reconciled and updated biannually during the first and third quarters of each year

D – Rider is updated biannually with SOS – Type II rates updated on a quarterly basis

E – Off-rider rates are tracked on a monthly basis and updated annually

F – Off-rider rate is tracked on a monthly basis and updated upon change in the enacted franchise tax rate

G – Off-rider rates are tracked and updated on a monthly basis

H – Off-rider rates are tracked and updated on a quarterly basis

I – Rider is updated periodically

---

Date of Issue: June 24, 2004

Date Effective: July 1, 2004

**PLUG-IN VEHICLE CHARGING -  
SCHEDULE "PIV"**

**AVAILABILITY** – Available for Distribution and Standard Offer Service for low voltage electric service used for Plug-in Vehicle (“PIV”) battery charging purposes in premises where other electric requirements are furnished under Schedule “R” and “RTM”.

Customers taking service under Rider “NEM” (Net Energy Metering) are eligible for this Schedule “PIV”.

**CHARACTER OF SERVICE**

The service supplied under this schedule normally will be alternating current, sixty hertz, either (i) single phase, three wire, 120/240 volts or 120/208 volts, or (ii) three phase, four wire, 120/208 volts.

Service will be supplied from the regular service connection facilities.

**MONTHLY RATE**

| Distribution Service Charge   | Rate Year 1<br>Effective<br>April 1, 2024 |
|-------------------------------|---|
| Kilowatt-Hour Charge (Summer) | \$0.08760                                 |
| Kilowatt-Hour Charge (Winter) | \$0.04328                                 |

| Generation Service Charge             | Rate Effective<br>November 1, 2024 -<br>January 31, 2025<br>Winter | Rate Effective<br>February 1, 2025 -<br>May 31, 2025<br>Winter | Rate Effective<br>June 1, 2025 -<br>October 31, 2025<br>Summer |
|---------------------------------------|--|--|--|
| <b>SOS Kilowatt-Hour Charge</b>       |  |  |  |
| On-Peak                               | \$0.15995 per kWhr   | \$0.15995 per kWhr   | \$0.16479 per kWhr   |
| Off-Peak                              | \$0.08527 per kWhr   | \$0.08527 per kWhr   | \$0.07666 per kWhr   |
| <b>Administrative Charge</b>          | \$0.00391 per kWhr   | \$0.00589 per kWhr   | \$0.00515 per kWhr   |
| <b>Total SOS Kilowatt Hour Charge</b> |  |  |  |
| On-Peak                               | \$0.16386 per kWhr   | \$0.16584 per kWhr   | \$0.16994 per kWhr   |
| Off-Peak                              | \$0.08918 per kWhr   | \$0.09116 per kWhr   | \$0.08181 per kWhr   |

\*The Administrative Charge rates typically change every February, June and October.

| Transmission Service Charge          | Rate Effective<br><del>September 1, 2025</del> |
|--------------------------------------|--|
| <b>Kilowatt-Hour Charge (Summer)</b> | <del>\$-0.021010-01954</del>                   |
| <b>Kilowatt-Hour Charge (Winter)</b> | <del>\$-0.021010-01954</del>                   |

Procurement Cost Adjustment

See [www.pepco.com](http://www.pepco.com) for currently effective rate

## MD - PIV

**Generation and Transmission Service Charges** – Customers who do not receive service from an alternative Electric Supplier as defined in the Company's General Terms and Conditions will receive Generation and Transmission Services from the Company under the provisions of Schedule "PIV". Supply Service Charges for Schedule "PIV" will be updated to reflect changes to Rider "SOS" rates.

**Billing Credit** – A monthly billing credit in the amount of \$0.61 per residential customer will be applied to the bill of each customer receiving a consolidated bill from an alternative supplier for services provided both by Pepco and by the alternative supplier.

### BILLING MONTHS

**Summer** – Billing months of June through October.  
**Winter** – Billing months of November through May.

### RATING PERIODS

On-peak hours are from 12:00 p.m. to 8 p.m. Monday through Friday excluding holidays falling on weekdays. All other hours are off-peak.

### SUPPLY CAPACITY REQUIREMENT

Should additional service capacity be required for the "off-peak" service, in excess of that provided for regular service, the customer will pay to the Company an amount equal to the estimated cost of the additional facilities. Such payment must be made prior to the commencement of service under this schedule.

### GROSS RECEIPTS TAX

A surcharge of 2.0408% is applied to the transmission and distribution components of the customer's bill to recover the amount attributable to the Gross Receipt's Tax.

### GENERAL TERMS AND CONDITION

This schedule is subject in all respects to the Company's "General Terms and Conditions for Furnishing Electric Service" and the Company's "Electric Service Rules and Regulations."

### APPLICABLE RIDERS

Net Energy Metering  
Administrative Credit  
Delivery Tax Surcharge  
Montgomery County Surcharge  
Maryland Environmental Surcharge  
Bill Stabilization Adjustment  
Empower MD Charge  
Demand Resource Surcharge  
Dynamic Pricing – Peak Energy Savings Credit  
Green Rider  
Economic Relief and Recovery Rider  
MYP Adjustment Rider  
Revenue Deferral Mechanism Rider

**RESIDENTIAL SERVICE - WITH PLUG-IN  
VEHICLE CHARGING SCHEDULE "R-PIV"**

**AVAILABILITY** – Available for Distribution Service and Standard Offer Service when modified by Rider “SOS” in the Maryland portion of the Company’s service area for low voltage electric service where the use is primarily for residential purposes and for farm operations where the electricity for both farm and residential purposes is delivered through the same meter.

The service supplied under this Schedule is for Plug-in Vehicle (“PIV”) battery charging purposes in addition to the electric requirements for residential purposes and for farm operations as described above. The electricity for PIV battery charging purposes is delivered through the same meter as for both farm and residential purposes.

Not available for residential premises in which five (5) or more rooms are furnished under Schedules “R” and “RTM” for hire.

Not available for seasonal loads metered separately from lighting and other usage in the same occupancy.

Not available for temporary, auxiliary or emergency service.

**CHARACTER OF SERVICE**

The service supplied under this schedule normally will be alternating current, sixty hertz, either (i) single phase, three wire, 120/240 volts or 120/208 volts, or (ii) three phase, four wire, 120/208 volts.

Service will be supplied from the regular service connection facilities.

**MONTHLY RATE**

| Distribution Service Charge   | Rate Year 1<br>Effective<br>April 1, 2024 |
|-------------------------------|---|
| Customer Charge               | \$ 8.44                                   |
| Kilowatt-Hour Charge (Summer) | \$0.08760                                 |
| Kilowatt-Hour Charge (Winter) | \$0.04328                                 |

| Generation Service Charge      | Rate Effective<br>November 1, 2024 –<br>January 31, 2025<br>Winter | Rate Effective<br>February 1, 2025 –<br>May 31, 2025<br>Winter | Rate Effective<br>June 1, 2025 -<br>October 31, 2025<br>Summer |
|--------------------------------|--|--|--|
| SOS Kilowatt-Hour Charge       |  |  |  |
| On-Peak                        | \$0.21973 per kWhr   | \$0.21973 per kWhr   | \$0.17528 per kWhr   |
| Off-Peak                       | \$0.07135 per kWhr   | \$0.07135 per kWhr   | \$0.07116 per kWhr   |
| Administrative Charge          | \$0.00391 per kWhr   | \$0.00589 per kWhr   | \$0.00515 per kWhr   |
| Total SOS Kilowatt Hour Charge |  |  |  |
| On-Peak                        | \$0.22364 per kWhr   | \$0.22562 per kWhr   | \$0.18043 per kWhr   |
| Off-Peak                       | \$0.07526 per kWhr   | \$0.07724 per kWhr   | \$0.07631 per kWhr   |

\*The Administrative Charge rates typically change every February, June and October.

**MONTHLY RATES (Continued)**

|                                      |   |
|--------------------------------------|---|
| <b>Transmission Service Charge</b>   | <b>Rate Effective<br/>September 1, 2025</b> |
| <b>Kilowatt-Hour Charge (Summer)</b> | \$ <u>0.021010.01951</u>                    |
| <b>Kilowatt-Hour Charge (Winter)</b> | \$ <u>0.02101-0.01954</u>                   |

**Procurement Cost Adjustment**See [www.pepco.com](http://www.pepco.com) for currently effective rate

**Generation and Transmission Service Charges** – Customers must receive Generation and Transmission Services from the Company under the provisions of Schedule “R-PIV”. Supply Service Charges for Schedule “R-PIV” will be updated to reflect changes to Rider “SOS” rates.

**BILLING MONTHS**

**Summer** – Billing months of June through October.

**Winter** – Billing months of November through May.

**RATING PERIODS**

On-peak hours are from 12:00 p.m. to 8 p.m. Monday through Friday excluding holidays falling on weekdays. All other hours are off-peak.

**SUPPLY CAPACITY REQUIREMENT**

Should additional service capacity be required for the “off-peak” service, in excess of that provided for regular service, the customer will pay to the Company an amount equal to the estimated cost of the additional facilities. Such payment must be made prior to the commencement of service under this schedule.

**GROSS RECEIPTS TAX**

A surcharge of 2.0408% is applied to the transmission and distribution components of the customer’s bill to recover the amount attributable to the Gross Receipt’s Tax.

**GENERAL TERMS AND CONDITION**

This schedule is subject in all respects to the Company’s “General Terms and Conditions for Furnishing Electric Service” and the Company’s “Electric Service Rules and Regulations.”

**APPLICABLE RIDERS**

Net Energy Metering

Administrative Credit

Delivery Tax Surcharge

Montgomery County Surcharge

Maryland Environmental Surcharge

Bill Stabilization Adjustment

Empower MD Charge

Residential Direct Load Control

Demand Resource Surcharge

Dynamic Pricing – Peak Energy Savings Credit

Universal Service Charge Recovery

Green Rider

Economic Relief and Recovery Rider

MYP Adjustment Rider

Revenue Deferral Mechanism Rider

## **STANDARD OFFER SERVICE RIDER “SOS”**

### **RIDER “SOS” – STANDARD OFFER SERVICE**

Available in the Maryland portion of the Company's service area for the provision of Generation and Transmission Services to customers who do not have an alternate supplier for Generation and Transmission Services as defined in the Customer Choice Act, Section 7-510(C)(2).

Standard Offer Service (SOS) is available beginning July 1, 2004 in accordance with the provisions contained in the Maryland Case No. 8908 Settlement Agreements (Phase I and II) approved by the Maryland Public Service Commission in Order Nos. 78400 and 78710 and in the Code of Maryland Regulations (COMAR) 20.52 Electric Standard Offer Service.

### **DESCRIPTION OF SOS TYPES**

#### **Residential**

Applicable to customers served on Schedules “R”, “R-TM” and “R-TOU-P”.

Customers may leave or return to Rider “SOS” without penalty by the Company, subject to the Company's General Terms and Conditions.

A Customer shall not change Type within the SOS year.

#### **Type I Non-Residential**

Applicable to customers served on Schedules “GS”, “T”, “SL”, “TN”, “EV”, and “OL”.

Customers may leave or return to Rider “SOS” without penalty by the Company, subject to the Company's General Terms and Conditions.

A Customer shall not change Type within the SOS year.

#### **Type II Non-Residential**

Applicable to customers served on Schedules “MGT LV II” and “MGT 3A II”.

Customers may leave or return to Rider “SOS” without penalty by the Company, subject to the Company's General Terms and Conditions.

A Customer shall not change Type within the SOS year.

#### **Hourly-Priced Service (HPS)**

Applicable to customers served on Schedules “MGT LV III”, “MGT 3A III”, “GT LV”, “GT 3A”, “GT 3B” and “TM-RT”.

Customers may leave or return to Rider “SOS” without penalty by the Company, subject to the Company's General Terms and Conditions.

When a customer purchasing from an alternate supplier, other than the Company, returns or is returned to the Company on or after June 1, 2005, the customer will receive HPS.

A Customer shall not change Type within the SOS year.

**MD – SOS****MONTHLY RATE**

Customers receiving Standard Offer Service will pay the Distribution Service Charge, Transmission Service Charge and Generation Service Charge including all applicable riders. The Distribution Service Charges are stated in the Monthly Rates for the Customer's applicable Rate Schedule.

The Standard Offer Service Rate for each Rate Schedule within each SOS Type, including any usage incurred under associated Riders, will include the following components:

1. The seasonally-differentiated and, if applicable, time-of-use differentiated load weighted average of all awarded electric supply prices for specific services in each year.
2. Retail charges designed to recover, on an aggregate basis, FERC-approved transmission charges and any other PJM charges and costs incurred by Pepco.
3. An administrative charge, consisting of incremental, uncollectible and cash working capital cost, an administrative adjustment and a return (included in Generation rates tables below); and;
4. Applicable taxes.

**SOS – Residential (Generation, Transmission including separately calculated GRT, and Procurement Cost Adjustment)**

**Schedule R**

| Generation Service Charge             | 10/01/24 – 01/31/25 | 02/01/25 – 05/31/25 | 06/01/25 – 09/30/25 |
|---------------------------------------|---------------------|---------------------|---------------------|
| <b>SOS Kilowatt-hour Charge</b>       | \$0.10115 per kWhr  | \$0.10115 per kWhr  | \$0.09882 per kWhr  |
| <b>Administrative Charge</b>          | \$0.00391 per kWhr  | \$0.00589 per kWhr  | \$0.00515 per kWhr  |
| <b>Total SOS Kilowatt Hour Charge</b> | \$0.10506 per kWhr  | \$0.10704 per kWhr  | \$0.10397 per kWhr  |

\*The Administrative Charge rates typically change every February, June and October.

| Transmission Service Charge | Summer                    | Winter                    |
|-----------------------------|---------------------------|---------------------------|
| Kilowatt-hour Charge        | \$0.021010.01951 per kWhr | \$0.021010.01951 per kWhr |

**Procurement Cost Adjustment**

See [www.pepco.com](http://www.pepco.com) for currently effective rate

**Schedule R-TM**

| Generation Service Charge             | 10/01/24 – 01/31/25 | 02/01/25 – 05/31/25 | 06/01/25 – 09/30/25 |
|---------------------------------------|---------------------|---------------------|---------------------|
| <b>SOS Kilowatt-hour Charge</b>       |                     |                     |                     |
| On Peak                               | \$0.10231 per kWhr  | \$0.10231 per kWhr  | \$0.10243 per kWhr  |
| Intermediate                          | \$0.10221 per kWhr  | \$0.10221 per kWhr  | \$0.09707 per kWhr  |
| Off Peak                              | \$0.10028 per kWhr  | \$0.10028 per kWhr  | \$0.09773 per kWhr  |
| <b>Administrative Charge</b>          | \$0.00391 per kWhr  | \$0.00589 per kWhr  | \$0.00515 per kWhr  |
| <b>Total SOS Kilowatt Hour Charge</b> |                     |                     |                     |
| On Peak                               | \$0.10622 per kWhr  | \$0.10820 per kWhr  | \$0.10758 per kWhr  |
| Intermediate                          | \$0.10612 per kWhr  | \$0.10810 per kWhr  | \$0.10222 per kWhr  |
| Off Peak                              | \$0.10419 per kWhr  | \$0.10617 per kWhr  | \$0.10288 per kWhr  |

\*The Administrative Charge rates typically change every February, June and October.

| Transmission Service Charge | Summer                    | Winter                    |
|-----------------------------|---------------------------|---------------------------|
| Kilowatt-hour Charge        | \$0.020920.01978 per kWhr | \$0.020920.01978 per kWhr |

**Procurement Cost Adjustment**

See [www.pepco.com](http://www.pepco.com) for currently effective rate

**MD – SOS**

Thirty-Fifth Revised Page No. 43.2

**Schedule R-TOU-P**

|                                       |                            |                            |                            |
|---------------------------------------|----------------------------|----------------------------|----------------------------|
| <b>Generation Service Charge</b>      | <b>02/01/25 – 05/31/25</b> | <b>06/01/25 – 09/01/25</b> | <b>09/01/25 – 09/30/25</b> |
| <b>SOS Kilowatt-hour Charge</b>       |                            |                            |                            |
| On Peak                               | \$0.20418 per kWhr         | \$0.28656 per kWhr         | \$0.29398 per kWh          |
| Off Peak                              | \$0.09651 per kWhr         | \$0.07571 per kWhr         | \$0.07571 per kWh          |
| <b>Administrative Charge</b>          | \$0.00589 per kWhr         | \$0.00515 per kWhr         | \$0.00515 per kWh          |
| <b>Total SOS Kilowatt Hour Charge</b> |                            |                            |                            |
| On Peak                               | \$0.21007 per kWhr         | \$0.29171 per kWhr         | \$0.29913 per kWh          |
| Off Peak                              | \$0.10240 per kWhr         | \$0.08086 per kWhr         | \$0.08086 per kWh          |

\*The Administrative Charge rates typically change every February, June and October.

**Transmission Service Charge**

|                                    |   |
|------------------------------------|---|
| <b>Kilowatt-hour Charge</b>        | <b>Included in Generation Service Charge</b>  |
| <b>Procurement Cost Adjustment</b> | <b>See <a href="http://www.pepco.com">www.pepco.com</a> for currently effective rate.</b> |

**Note:** Schedule R-TOU-P billing periods are as follows:

Summer – Billing months are June through September, and On-Peak hours will be between the hours of 2:00 pm and 7:00 pm excluding weekends and holidays. All other hours are off-peak.

Winter - Billing months are October through May, and On-Peak hours will be between the hours of 6:00 am and 9:00 am and the hours of 5:00 pm and 9:00 pm, excluding weekends and holidays. All other hours are off-peak.

**SOS – Type I Non-Residential (Generation, Transmission including separately calculated GRT, and Procurement Cost Adjustment)****Schedule GS and EV**

|                                       |                            |                            |                            |
|---------------------------------------|----------------------------|----------------------------|----------------------------|
| <b>Generation Service Charge</b>      | <b>10/01/24 – 01/31/25</b> | <b>02/01/25 – 05/31/25</b> | <b>06/01/25 – 09/30/25</b> |
| <b>SOS Kilowatt-hour Charge</b>       | \$0.10050 per kWhr         | \$0.10050 per kWhr         | \$0.09806 per kWhr         |
| <b>Administrative Charge</b>          | \$0.00326 per kWhr         | \$0.00530 per kWhr         | \$0.00421 per kWhr         |
| <b>Total SOS Kilowatt Hour Charge</b> | \$0.10376 per kWhr         | \$0.10580 per kWhr         | \$0.10227 per kWhr         |

\*The Administrative Charge rates typically change every February, June and October.

| <b>Transmission Service Charge</b> | <b>Summer</b>                       | <b>Winter</b>                       |
|------------------------------------|-------------------------------------|-------------------------------------|
| <b>Kilowatt-hour Charge</b>        | <b>\$0.01423 \$0.01302 per kWhr</b> | <b>\$0.01423 \$0.01302 per kWhr</b> |

**Procurement Cost Adjustment** See [www.pepco.com](http://www.pepco.com) for currently effective rate**Schedule T**

|                                       |                            |                            |                            |
|---------------------------------------|----------------------------|----------------------------|----------------------------|
| <b>Generation Service Charge</b>      | <b>10/01/24 – 01/31/25</b> | <b>02/01/25 – 05/31/25</b> | <b>06/01/25 – 09/30/25</b> |
| <b>SOS Kilowatt-hour Charge</b>       | \$0.10050 per kWhr         | \$0.10050 per kWhr         | \$0.09806 per kWhr         |
| <b>Administrative Charge</b>          | \$0.00326 per kWhr         | \$0.00530 per kWhr         | \$0.00421 per kWhr         |
| <b>Total SOS Kilowatt Hour Charge</b> | \$0.10376 per kWhr         | \$0.10580 per kWhr         | \$0.10227 per kWhr         |

\*The Administrative Charge rates typically change every February, June and October.

| <b>Transmission Service Charge</b> | <b>Summer</b>                       | <b>Winter</b>                       |
|------------------------------------|-------------------------------------|-------------------------------------|
| <b>Kilowatt-hour Charge</b>        | <b>\$0.01063 \$0.00939 per kWhr</b> | <b>\$0.01063 \$0.00939 per kWhr</b> |

**Procurement Cost Adjustment** See [www.pepco.com](http://www.pepco.com) for currently effective rate**Schedule SL**

|                                       |                            |                            |                            |
|---------------------------------------|----------------------------|----------------------------|----------------------------|
| <b>Generation Service Charge</b>      | <b>10/01/24 – 01/31/25</b> | <b>02/01/25 – 05/31/25</b> | <b>06/01/25 – 09/30/25</b> |
| <b>SOS Kilowatt-hour Charge</b>       | \$0.09791 per kWhr         | \$0.09791 per kWhr         | \$0.09353 per kWhr         |
| <b>Administrative Charge</b>          | \$0.00326 per kWhr         | \$0.00530 per kWhr         | \$0.00421 per kWhr         |
| <b>Total SOS Kilowatt Hour Charge</b> | \$0.10117 per kWhr         | \$0.10321 per kWhr         | \$0.09774 per kWhr         |

\*The Administrative Charge rates typically change every February, June and October.

| <b>Transmission Service Charge</b> | <b>Summer</b>                        | <b>Winter</b>                        |
|------------------------------------|--------------------------------------|--------------------------------------|
| <b>Kilowatt-hour Charge</b>        | <b>\$0.000070 \$0.00004 per kWhr</b> | <b>\$0.000070 \$0.00004 per kWhr</b> |

**Procurement Cost Adjustment** See [www.pepco.com](http://www.pepco.com) for currently effective rate

**MONTHLY RATE (continued)****Schedule OL**

| Mercury Vapor (10/01/24 to 01/31/25) |                          |                      |                       |          |
|--------------------------------------|--------------------------|----------------------|-----------------------|----------|
| Generation Rates                     | \$/kWh Rate <sup>1</sup> | kW/lamp <sup>2</sup> | kWh / mo <sup>3</sup> | \$ Lamp  |
| 175 Watt Lamp                        | \$0.10117                | 0.210                | 73.50                 | \$ 7.44  |
| 250 Watt Lamp                        | \$0.10117                | 0.290                | 101.50                | \$ 10.27 |
| 400 Watt Lamp                        | \$0.10117                | 0.445                | 155.75                | \$ 15.76 |

| Mercury Vapor (02/01/25 to 05/31/25) |                          |                      |                       |          |
|--------------------------------------|--------------------------|----------------------|-----------------------|----------|
| Generation Rates                     | \$/kWh Rate <sup>1</sup> | kW/lamp <sup>2</sup> | kWh / mo <sup>3</sup> | \$ Lamp  |
| 175 Watt Lamp                        | \$0.10321                | 0.210                | 73.50                 | \$ 7.59  |
| 250 Watt Lamp                        | \$0.10321                | 0.290                | 101.50                | \$ 10.48 |
| 400 Watt Lamp                        | \$0.10321                | 0.445                | 155.75                | \$ 16.07 |

| Mercury Vapor (06/01/25 to 09/30/25) |                          |                      |                       |          |
|--------------------------------------|--------------------------|----------------------|-----------------------|----------|
| Generation Rates                     | \$/kWh Rate <sup>1</sup> | kW/lamp <sup>2</sup> | kWh / mo <sup>3</sup> | \$ Lamp  |
| 175 Watt Lamp                        | \$0.09774                | 0.210                | 73.50                 | \$ 7.18  |
| 250 Watt Lamp                        | \$0.09774                | 0.290                | 101.50                | \$ 9.92  |
| 400 Watt Lamp                        | \$0.09774                | 0.445                | 155.75                | \$ 15.22 |

| High Pressure Sodium (10/01/24 to 01/31/25) |                          |                      |                       |          |
|---|--------------------------|----------------------|-----------------------|----------|
| Generation Rates                            | \$/kWh Rate <sup>1</sup> | kW/lamp <sup>2</sup> | kWh / mo <sup>3</sup> | \$ Lamp  |
| 100 Watt Lamp                               | \$0.10117                | 0.120                | 42.00                 | \$ 4.25  |
| 150 Watt Lamp                               | \$0.10117                | 0.175                | 61.25                 | \$ 6.20  |
| 250 Watt Lamp                               | \$0.10117                | 0.295                | 103.25                | \$ 10.45 |

| High Pressure Sodium (02/01/25 to 05/31/25) |                          |                      |                       |          |
|---|--------------------------|----------------------|-----------------------|----------|
| Generation Rates                            | \$/kWh Rate <sup>1</sup> | kW/lamp <sup>2</sup> | kWh / mo <sup>3</sup> | \$ Lamp  |
| 100 Watt Lamp                               | \$0.10321                | 0.120                | 42.00                 | \$ 4.33  |
| 150 Watt Lamp                               | \$0.10321                | 0.175                | 61.25                 | \$ 6.32  |
| 250 Watt Lamp                               | \$0.10321                | 0.295                | 103.25                | \$ 10.66 |

| High Pressure Sodium (06/01/25 to 09/30/25) |                          |                      |                       |          |
|---|--------------------------|----------------------|-----------------------|----------|
| Generation Rates                            | \$/kWh Rate <sup>1</sup> | kW/lamp <sup>2</sup> | kWh / mo <sup>3</sup> | \$ Lamp  |
| 100 Watt Lamp                               | \$0.09774                | 0.120                | 42.00                 | \$ 4.11  |
| 150 Watt Lamp                               | \$0.09774                | 0.175                | 61.25                 | \$ 5.99  |
| 250 Watt Lamp                               | \$0.09774                | 0.295                | 103.25                | \$ 10.09 |

<sup>1)</sup>Administrative charge included in \$/kWh rate<sup>2)</sup>kW/lamp includes ballast<sup>3)</sup>kWh/month = 4200 Burning Hours / Year \*kW/lamp/12<sup>4)</sup>Winter rates are available after Tranche 3

| Transmission Service Charge | Summer          | Winter          |
|-----------------------------|-----------------|-----------------|
| 175 Watt                    | \$0.00 per lamp | \$0.00 per lamp |
| 250 Watt                    | \$0.00 per lamp | \$0.00 per lamp |
| 400 Watt                    | \$0.00 per lamp | \$0.00 per lamp |

**Procurement Cost Adjustment**See [www.pepco.com](http://www.pepco.com) for currently effective rate

**MD – SOS****MONTHLY RATE (continued)****Schedule TN and Rider SL-TN**

| <b>Generation Service Charge</b>      | <b>10/01/24 – 01/31/25</b> | <b>02/01/25 – 05/31/25</b> | <b>06/01/25 – 09/30/25</b> |
|---------------------------------------|----------------------------|----------------------------|----------------------------|
| <b>SOS Kilowatt-hour Charge</b>       | \$0.09646 per kWhr         | \$0.09646 per kWhr         | \$0.13168 per kWhr         |
| <b>Administrative Charge</b>          | \$0.00326 per kWhr         | \$0.00530 per kWhr         | \$0.00421 per kWhr         |
| <b>Total SOS Kilowatt Hour Charge</b> | \$0.09972 per kWhr         | \$0.10176 per kWhr         | \$0.13589 per kWhr         |

\*The Administrative Charge rates typically change every February, June and October.

| <b>Transmission Service Charge</b> | <b>Summer</b>                 | <b>Winter</b>                     |
|------------------------------------|-------------------------------|-----------------------------------|
| <b>Kilowatt-hour Charge</b>        | <b>\$0.00901 0.00768-kWhr</b> | <b>\$0.00901 0.00768 per kWhr</b> |

**Procurement Cost Adjustment**

See [www.pepco.com](http://www.pepco.com) for currently effective rate

**SOS – Type II Non-Residential (Generation, Transmission including separately calculated GRT, and Procurement Cost Adjustment)****Schedule MGT LV II**

| <b>Generation Service Charge</b>      | <b>02/01/25 – 02/28/25</b> | <b>03/01/25 – 05/31/25</b> | <b>06/01/25 – 08/31/25</b> |
|---------------------------------------|----------------------------|----------------------------|----------------------------|
| <b>SOS Kilowatt-hour Charge</b>       |                            |                            |                            |
| <b>On-Peak</b>                        | \$0.08417 per kWhr         | \$0.07329 per kWhr         | \$0.11609 per kWhr         |
| <b>Intermediate</b>                   | \$0.08417 per kWhr         | \$0.07218 per kWhr         | \$0.10575 per kWhr         |
| <b>Off-Peak</b>                       | \$0.08417 per kWhr         | \$0.07039 per kWhr         | \$0.10257 per kWhr         |
| <b>Administrative Charge</b>          | \$0.00255 per kWhr         | \$0.00255 per kWhr         | \$0.00302 per kWhr         |
| <b>Total SOS Kilowatt hour Charge</b> |                            |                            |                            |
| <b>On-Peak</b>                        | \$0.08672 per kWhr         | \$0.07584 per kWhr         | \$0.11911 per kWhr         |
| <b>Intermediate</b>                   | \$0.08672 per kWhr         | \$0.07473 per kWhr         | \$0.10877 per kWhr         |
| <b>Off-Peak</b>                       | \$0.08672 per kWhr         | \$0.07294 per kWhr         | \$0.10559 per kWhr         |

\*The Administrative Charge rates typically change every February, June and October.

| <b>Transmission Service Charge</b> | <b>Summer</b>                    | <b>Winter</b>                    |
|------------------------------------|----------------------------------|----------------------------------|
| <b>Kilowatt-hour Charge</b>        | <b>\$0.008630.00766 per kWhr</b> | <b>\$0.008630.00766 per kWhr</b> |
| <b>Kilowatt Charge</b>             |                                  |                                  |
| <b>On Peak</b>                     | <b>\$1.90811.6946 per kw</b>     |                                  |
| <b>Maximum</b>                     | <b>\$1.3890 1.2336 per kw</b>    | <b>\$1.3890 1.2336 per kw</b>    |

**Procurement Cost Adjustment**

See [www.pepco.com](http://www.pepco.com) for currently effective rate

**MD – SOS****Schedule MGT 3A II**

| Generation Service Charge             | 02/01/25 – 02/28/25 | 03/01/25 – 05/31/25 | 06/01/25 – 08/31/25 |
|---------------------------------------|---------------------|---------------------|---------------------|
| <b>SOS Kilowatt-hour Charge</b>       |                     |                     |                     |
| <b>On-Peak</b>                        | \$0.08339 per kwhr  | \$0.07261 per kwhr  | \$0.11501 per kwhr  |
| <b>Intermediate</b>                   | \$0.08339 per kwhr  | \$0.07151 per kwhr  | \$0.10476 per kwhr  |
| <b>Off-Peak</b>                       | \$0.08339 per kwhr  | \$0.06973 per kwhr  | \$0.10162 per kwhr  |
| <b>Administrative Charge</b>          | \$0.00255 per kwhr  | \$0.00255 per kwhr  | \$0.00302 per kwhr  |
| <b>Total SOS Kilowatt Hour Charge</b> |                     |                     |                     |
| <b>On-Peak</b>                        | \$0.08594 per kwhr  | \$0.07516 per kwhr  | \$0.11803 per kwhr  |
| <b>Intermediate</b>                   | \$0.08594 per kwhr  | \$0.07406 per kwhr  | \$0.10778 per kwhr  |
| <b>Off-Peak</b>                       | \$0.08594 per kwhr  | \$0.07228 per kwhr  | \$0.10464 per kwhr  |

\*The Administrative Charge rates typically change every February, June and October.

| Transmission Service Charge | Summer                     | Winter                     |
|-----------------------------|----------------------------|----------------------------|
| <b>Kilowatt-hour Charge</b> | \$0.00850 0.00703 per kwhr | \$0.00850 0.00703 per kwhr |
| <b>Kilowatt Charge</b>      |                            |                            |
| <b>On Peak</b>              | \$1.8493 1.5294 per kw     |                            |
| <b>Maximum</b>              | \$1.3602 1.1249 per kw     | \$1.3602 1.1249 per kw     |

**Procurement Cost Adjustment**

See [www.pepco.com](http://www.pepco.com) for currently effective rate

**SOS – Hourly Priced Service (HPS)****Schedules MGT LV III, MGT 3A III, GT LV, GT 3A, GT 3B, and TM-RT****Generation Service Charge****The Hourly Price Service will include:**

- Market Hourly Energy Charge** – The Customer's hourly energy usage, adjusted for applicable losses, multiplied by the hourly energy charge.

The hourly energy charge will consist of the 1) hourly integrated real time fixed nodal weighted aggregate Locational Marginal Price (LMP) values for the Pepco zone, or its successor for the retail load served in Pepco's Maryland service area, as determined and reported by the PJM; 2) An Administrative Charge (consisting of incremental, uncollectible and cash-working capital costs, an administrative adjustment, and a return) of \$ 0.00287, any applicable taxes, and other items as provided for in paragraphs 79 and 82 of the Phase I Settlement in Maryland Case No. 8908; and 3) Generation Ancillary Service Charges based on the previous month's average cents per kwh generation ancillary service cost for HPS customers in the Pepco Zone as determined and reported by PJM.

- Monthly Capacity Charge** – Determined by summing over each day during the Customer's billing period the Customer's obligation in MW multiplied by the daily cost per MW of procuring capacity. The daily Capacity procurement cost shall be in dollars per MW-day, based on capacity purchased to cover HPS shortages and any penalties or deficiency charges and broker fees accruing for the day of the calculation.

When a Customer's account does not have interval data, the Customer's historical data will be used to develop the hourly use.

**Transmission Service Charge** – The transmission service charges stated in this SOS – Hourly Priced Service (HPS) section apply only to Type III customers receiving HPS from Pepco.

**Transmission Service Charge****Schedule MGT LV III**

|                             | <b>Summer</b>             | <b>Winter</b>              |
|-----------------------------|---------------------------|----------------------------|
| <b>Kilowatt-hour Charge</b> | \$0.008630.00766 per kWhr | \$0.00863 0.00766 per kWhr |
| <b>Kilowatt Charge</b>      |                           |                            |
| <b>On Peak</b>              | \$ 1.90811.6946 per kw    |                            |
| <b>Maximum</b>              | \$ 1.3890 1.2336 per kw   | \$ 1.3890 1.2336 per kw    |

**Schedule MGT 3A III**

|                             | <b>Summer</b>              | <b>Winter</b>              |
|-----------------------------|----------------------------|----------------------------|
| <b>Kilowatt-hour Charge</b> | \$0.00850 0.00703 per kWhr | \$0.00850 0.00703 per kWhr |
| <b>Kilowatt Charge</b>      |                            |                            |
| <b>On Peak</b>              | \$1.8493 1.5294 per kw     |                            |
| <b>Maximum</b>              | \$1.3602 1.1249 per kw     | \$1.3602 1.1249 per kw     |

**Schedule GT LV**

|                             | <b>Summer</b>              | <b>Winter</b>              |
|-----------------------------|----------------------------|----------------------------|
| <b>Kilowatt-hour Charge</b> | \$0.00773 0.00691 per kWhr | \$0.00773 0.00691 per kWhr |
| <b>Kilowatt Charge</b>      |                            |                            |
| <b>On Peak</b>              | \$2.0515 1.8335 per kw     |                            |
| <b>Maximum</b>              | \$1.5153 1.3543 per kw     | \$1.5153 1.3543 per kw     |

**Schedule GT 3A**

|                             | <b>Summer</b>              | <b>Winter</b>              |
|-----------------------------|----------------------------|----------------------------|
| <b>Kilowatt-hour Charge</b> | \$0.00737 0.00661 per kWhr | \$0.00737 0.00661 per kWhr |
| <b>Kilowatt Charge</b>      |                            |                            |
| <b>On Peak</b>              | \$1.9975 1.7925 per kw     |                            |
| <b>Maximum</b>              | \$1.4938 1.3405 per kw     | \$1.4938 1.3405 per kw     |

**Schedule GT 3B**

|                             | <b>Summer</b>              | <b>Winter</b>              |
|-----------------------------|----------------------------|----------------------------|
| <b>Kilowatt-hour Charge</b> | \$0.00703 0.00586 per kWhr | \$0.00703 0.00586 per kWhr |
| <b>Kilowatt Charge</b>      |                            |                            |
| <b>On Peak</b>              | \$1.8429 1.5361 per kw     |                            |
| <b>Maximum</b>              | \$1.3556 1.1299 per kw     | \$1.3556 1.1299 per kw     |

**Schedule TM-RT**

|                             | <b>Summer</b>              | <b>Winter</b>              |
|-----------------------------|----------------------------|----------------------------|
| <b>Kilowatt-hour Charge</b> | \$0.00702 0.00575 per kWhr | \$0.00702 0.00575 per kWhr |
| <b>Kilowatt Charge</b>      |                            |                            |
| <b>On Peak</b>              | \$1.2224 1.0019 per kw     |                            |
| <b>Maximum</b>              | \$0.8793 0.7207 per kw     | \$0.8793 0.7207 per kw     |

The monthly HPS charges shall equal the actual cost of providing energy and capacity supply transmission service, ancillary service, and any other cost element directly related to the Company's HPS load obligation, including an Administrative Charge and applicable taxes.

The Company will determine an Hourly Price Service Procurement Cost Adjustment (HPS – PCA) which will reflect the difference between the actual cost of serving Customers under HPS (including any cost adjustments from the PJM Settlement system) and the amount billed to HPS Customers for the same time period. The Company will determine the HPS-PCA rate by dividing the HPS-PCA amount by the total kilowatt-hour sales of the then current HPS customers. The HPS-PCA rate will be applied to each of the then current HPS customers' sales to determine the credit/charge for the billing month.

At the conclusion of Hourly Price Service on June 1, 2006, any HPS PCA will be returned to, or collected from all Type II Customers regardless of their supplier.

## **BILLING MONTHS**

**Summer** – Billing months of June through October

**Winter** – Billing months of November through May.

## **RATING PERIODS**

### **Weekdays - (Excluding Holidays)**

|                     |            |     |                |
|---------------------|------------|-----|----------------|
| On-Peak Period      | 12:00 noon | to  | 8:00 p.m.      |
| Intermediate Period | 8:00 a.m.  | to  | 12:00 noon     |
|                     |            | and |                |
|                     | 8:00 p.m.  | to  | 12:00 midnight |

Off-Peak Period      12:00 midnight      to      8:00 a.m.

### **Saturdays, Sundays and Holidays**

Off-Peak Period      All Hours

### **Holidays**

Holidays include all holidays as designated by the Federal Government.

## **BILLING DEMANDS**

On-Peak (Summer Billing Months Only) - The billing demand shall be the maximum thirty (30) minute demand recorded during the on-peak period of the billing month.

Maximum (All Months) - The billing demand shall be the maximum thirty (30) minute demand recorded during the billing month.

## **PROCUREMENT COST ADJUSTMENT**

In addition to the Standard Offer Service rates shown above, for Residential, Type I, and Type II customers (excludes HPS customers) there will be a monthly Procurement Cost Adjustment (PCA) shown as a separate line item on the Customer's bill. Refer to HPS for the Hourly Priced Service Procurement Cost Adjustment (HPS-PCA).

The PCA is a \$ per kilowatt-hour rate applied to the Customer's billed kilowatt-hours.

The PCA is an adjustment made in order to true-up the rates customers are billed to reflect the Company's actual costs of providing Standard Offer Service.

A true-up adjustment will be made to the PCA at least three (3) times per year- effective with the June, November and February billing months. These true-ups will revise the PCA based on actual and forecasted collections of SOS revenues by SOS Type and the actual and forecasted cost of providing Standard Offer Service.

The current applicable PCA rate by SOS Type is available on the Company's website at [www.pepco.com](http://www.pepco.com).

## **PUBLICATION OF PRICES**

The Standard Offer Service Rates shown in this Rider are posted on the Company's website at [www.pepco.com](http://www.pepco.com).

The market hourly Locational Marginal Prices used for HPS are available on the PJM website at [www.pjm.com](http://www.pjm.com).

## **Attachment B**

Potomac Electric Power Company  
 Maryland  
 July 7, 2025 Retail Transmission Rate Filing

Attachment B  
 Page 1 of 1

Transmission Revenue Requirement  
 Change in FERC Formula Rate Effective 6/1/2025  
 Twelve Months Ended December 2024

|   |          |   |
|---|----------|---|
| (1) Transmission Enhancement Charge (\$/kW)                           | \$ 7.10  | Source: See Attachment C, Page 5 of 5, Column (I), Line (245), divided by 1000. |
| (2) Network Service Transmission Rate (\$/kW)                         | \$ 59.32 | Source: See Attachment D, Page 1 of 1, Line (10) divided by 1000.               |
| (3) June 2025 - December 2025 EL05-121 Settlement Adjustments (\$/kW) | \$ 1.08  | Source: See Attachment E, Page 1 of 1, Column (B), Line (7), divided by 1000.   |
| (4) Total Wholesale Transmission Rate (\$/kW)                         | \$ 67.50 | Calculation: Line (4) = Line (1) + Line (2) + Line (3)                          |

(5) Total Wholesale Transmission Rate (\$/MW) \$ 67,500.95 Calculation: Line (5) = Line (4) X 1,000

(6) Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) 6,161.70 Source: PJM Network Transmission Service Peak Loads for 2025

(7) Pepco Zone - June 2025 to May 2026 Transmission Revenue Requirement \$ 415,920,573.62 Calculation: Line (7) = Line (5) X Line (6)

|                                | (A)<br>Annualized Current<br>Retail Transmission<br>Revenue | (B)<br>Transmission Peak<br>Load Contribution<br>(kW) | (C)<br>Transmission<br>Enhancement<br>Charge (\$/kW) | (D)<br>Network Service<br>Transmission Rate<br>(\$/kW) | (E)<br>June 2025 - December 2025<br>EL05-121 Settlement<br>Adjustments (\$/kW) | (F) = (C) + (D) + (E)<br>Total<br>Transmission Rate<br>(\$/kW) | (G) = (B) x (F)<br>Annualized Proposed<br>Retail Transmission<br>Revenue | (H) = (G) - (A)<br>\$ Increase /<br>(Decrease) | (I) = (H) / (A)<br>% Increase /<br>(Decrease) |
|--------------------------------|---|---|--|--|--|--|--|--|---|
| <b>Residential</b>             |   |   |  |  |  |  |  |  |   |
| (8) Residential                | \$ 91,201,010.69  | 1,450,405.00  | \$ 7.10  | \$ 59.32   | \$ 1.08  | \$ 67.72   | \$ 98,217,489.71   | \$ 7,016,479.02                                | 7.69%   |
| (9) RTM                        | \$ 15,891,783.82  | 248,157.00  | \$ 7.10  | \$ 59.32   | \$ 1.08  | \$ 67.72   | \$ 16,804,518.46   | \$ 912,734.63                                  | 5.74%   |
| (10) Subtotal Residential      | \$ 107,092,794.52   | 1,698,562.00  |  |  |  |  | \$ 115,022,008.17  | \$ 7,929,213.65                                |   |
| <b>Small Commercial</b>        |   |   |  |  |  |  |  |  |   |
| (11) GS & EV                   | \$ 4,146,109.19   | 66,937.00   | \$ 7.10  | \$ 59.32   | \$ 1.08  | \$ 67.72   | \$ 4,532,791.95  | \$ 386,682.76                                  | 9.33%   |
| (12) T                         | \$ 122,190.81   | 2,043.00  | \$ 7.10  | \$ 59.32   | \$ 1.08  | \$ 67.72   | \$ 138,346.41  | \$ 16,155.60                                   | 13.22%  |
| (13) SL                        | \$ 2,270.81   | 62.00   | \$ 7.10  | \$ 59.32   | \$ 1.08  | \$ 67.72   | \$ 4,198.47  | \$ 1,927.66                                    | 84.89%  |
| (14) OL                        | \$ -  | -   | \$ 7.10  | \$ 59.32   | \$ 1.08  | \$ 67.72   | \$ -   | \$ -   | 0.00%   |
| (15) TN                        | \$ 138,410.52   | 2,398.00  | \$ 7.10  | \$ 59.32   | \$ 1.08  | \$ 67.72   | \$ 162,386.05  | \$ 23,975.53                                   | 17.32%  |
| (16) Subtotal Small Commercial | \$ 4,408,981.33   | 71,440.00   |  |  |  |  | \$ 4,837,722.89  | \$ 428,741.55                                  |   |
| <b>Large Commercial</b>        |   |   |  |  |  |  |  |  |   |
| (17) MGT-LV                    | \$ 53,033,388.08  | 881,827.00  | \$ 7.10  | \$ 59.32   | \$ 1.08  | \$ 67.72   | \$ 59,714,930.86   | \$ 6,681,542.78                                | 12.60%  |
| (18) MGT-3A                    | \$ 966,320.22   | 17,255.00   | \$ 7.10  | \$ 59.32   | \$ 1.08  | \$ 67.72   | \$ 1,168,461.76  | \$ 202,141.55                                  | 20.92%  |
| (19) GT-LV                     | \$ 10,963,408.57  | 181,146.00  | \$ 7.10  | \$ 59.32   | \$ 1.08  | \$ 67.72   | \$ 12,266,715.43   | \$ 1,303,306.86                                | 11.89%  |
| (20) GT-3A                     | \$ 18,144,046.68  | 298,579.00  | \$ 7.10  | \$ 59.32   | \$ 1.08  | \$ 67.72   | \$ 20,218,959.44   | \$ 2,074,912.75                                | 11.44%  |
| (21) GT-3B                     | \$ 2,682,555.33   | 47,527.00   | \$ 7.10  | \$ 59.32   | \$ 1.08  | \$ 67.72   | \$ 3,218,399.44  | \$ 535,844.10                                  | 19.98%  |
| (22) RT                        | \$ 1,960,354.04   | 35,319.00   | \$ 7.10  | \$ 59.32   | \$ 1.08  | \$ 67.72   | \$ 2,391,706.81  | \$ 431,352.77                                  | 22.00%  |
| (23) Subtotal Large Commercial | \$ 87,750,072.93  | 1,461,653.00  |  |  |  |  | \$ 98,979,173.74   | \$ 11,229,100.81                               |   |
| (24) Total Jurisdiction        | \$ 199,251,848.78   | 3,231,655.00  |  |  |  |  | \$ 218,838,904.79  | \$ 19,587,056.02                               | 9.83%   |

**Notes:**

(A) Source: See Attachment F, Page 1 to 13 of 14, Column (C), Total Transmission Present Revenue for each Rate Schedule.

(B) Source: See Attachment F, Page 14 of 14, Column (B) for each Rate Schedule.

## Attachment C

|      | (A)   | (B)              | (C)                 | (D)                         | (E) = (C) + (D)           | (F)              | (G) = (E) x (F)    | (H)   | (I) = (G) / (H)                              |
|------|---|------------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|---|--|
|      | Trans-Allegheny Interstate Line Company (TrAILCo)   | PJM Upgrade ID   | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (1)  |   | b0216            | \$ 3,045,582        | \$ -                        | \$ 3,045,582              | 3.79%            | \$ 115,428         | 6,162   | \$ 18.73                                     |
| (2)  | Black Oak Install -100/+525 MVAR dynamic reactive device  | b0216_dfax       | \$ 3,045,582        | \$ -                        | \$ 3,045,582              | 12.11%           | \$ 368,820         | 6,162   | \$ 59.86                                     |
| (3)  | Install third & forth Wylie Ridge 500/345kV transformer   | b0218            | \$ 1,978,530        | \$ -                        | \$ 1,978,530              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (4)  | Build new Meadow Brook - Loudoun 500kV circuit (65 of 81 miles)   | b0328.1          | \$ 56,566,736       | \$ -                        | \$ 56,566,736             | 3.79%            | \$ 2,143,879       | 6,162   | \$ 347.94                                    |
| (5)  | Build new Meadow Brook - Loudoun 500kV circuit (65 of 81 miles)   | b0328.1_dfax     | \$ -                | \$ -                        | \$ -                      | 8.04%            | \$ -               | 6,162   | \$ -   |
| (6)  | Build new Meadow Brook - Loudoun 500kV circuit (26 of 81 miles)   | b0328.2          | \$ 2,833,993        | \$ -                        | \$ 2,833,993              | 8.04%            | \$ 227,853         | 6,162   | \$ 36.98                                     |
| (7)  | Build new Mt. Storm - 502 Junction 500kV circuit  | b0347.1          | \$ 13,243,404       | \$ -                        | \$ 13,243,404             | 16.83%           | \$ 2,228,865       | 6,162   | \$ 361.73                                    |
| (8)  | Build new Mt. Storm - Meadow Brook 500kV circuit  | b0347.2          | \$ 35,515,425       | \$ -                        | \$ 35,515,425             | 10.11%           | \$ 3,590,610       | 6,162   | \$ 582.73                                    |
| (9)  | Build new 502 Junction 500kV substation   | b0347.3          | \$ 3,657,605        | \$ -                        | \$ 3,657,605              | 16.83%           | \$ 615,575         | 6,162   | \$ 99.90                                     |
| (10) | Upgrade Meadow Brook 500kV substation   | b0347.4          | \$ 1,316,308        | \$ -                        | \$ 1,316,308              | 10.11%           | \$ 133,079         | 6,162   | \$ 21.60                                     |
| (11) | Replace the North Shenandoah 138/115kV transformer  | b0323            | \$ 185,370          | \$ -                        | \$ 185,370                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (12) | Install fourth Meadow Brook 500/138kV transformer   | b0230            | \$ 755,221          | \$ -                        | \$ 755,221                | 3.95%            | \$ 29,831          | 6,162   | \$ 4.84                                      |
| (13) | Install a 200 MVAR capacitor at Meadow Brook 500 kV substation  | b0559            | \$ 446,565          | \$ -                        | \$ 446,565                | 3.79%            | \$ 16,925          | 6,162   | \$ 2.75                                      |
| (14) | Install a 200 MVAR capacitor at Meadow Brook 500 kV substation  | b0559_dfax       | \$ 446,565          | \$ -                        | \$ 446,565                | 10.11%           | \$ 45,148          | 6,162   | \$ 7.33                                      |
| (15) | Install fourth Bedington 500/138kV transformer  | b0229            | \$ 955,052          | \$ -                        | \$ 955,052                | 17.64%           | \$ 168,471         | 6,162   | \$ 27.34                                     |
| (16) | Replace existing Kammer 765 / 500 KV transformer with a new larger transformer  | b0495            | \$ 1,887,575        | \$ -                        | \$ 1,887,575              | 3.79%            | \$ 71,539          | 6,162   | \$ 11.61                                     |
| (17) | Replace existing Kammer 765 / 500 KV transformer with a new larger transformer  | b0495_dfax       | \$ 1,887,575        | \$ -                        | \$ 1,887,575              | 9.97%            | \$ 188,191         | 6,162   | \$ 30.54                                     |
| (18) | Replace Doubs 500/230 kV transformer #2   | b0343            | \$ 1,198,120        | \$ -                        | \$ 1,198,120              | 35.19%           | \$ 421,618         | 6,162   | \$ 68.43                                     |
| (19) | Replace Doubs 500/230 kV transformer #3   | b0344            | \$ 515,766          | \$ -                        | \$ 515,766                | 35.20%           | \$ 181,550         | 6,162   | \$ 29.46                                     |
| (20) | Replace Doubs 500/230 kV transformer #4   | b0345            | \$ 527,142          | \$ -                        | \$ 527,142                | 35.20%           | \$ 185,554         | 6,162   | \$ 30.11                                     |
| (21) | Install a 4th Cabot 500/38kV autotransformer  | b0704            | \$ 1,294,018        | \$ -                        | \$ 1,294,018              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (22) | Install two 12 MVAR 115 kV capacitors at Potter Substation  | b1243            | \$ 218,629          | \$ -                        | \$ 218,629                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (23) | Install a 25 MVAR capacitor at Farmers Valley 115 kV bus  | b0563            | \$ 271,441          | \$ -                        | \$ 271,441                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (24) | Install 25 MVAR capacitor at the Ridgeway 115 kV bus  | b0564            | \$ 86,125           | \$ -                        | \$ 86,125                 | 0.00%            | \$ -               | 6,162   | \$ -   |
| (25) | Construct new 138 kV line from Osage - Whiteley (D-02834)   | b0674            | \$ 2,329,975        | \$ -                        | \$ 2,329,975              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (26) | Replace Osage 138kV breaker Collins#126   | b0674.1          | \$ -                | \$ -                        | \$ -                      | 0.00%            | \$ -               | 6,162   | \$ -   |
| (27) | Install second 138 kV Osage-Whiteley circuit and loop into 502 Junction Substation  | b1023.3          | \$ 110,096          | \$ -                        | \$ 110,096                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (28) | Install a 50 MVAR cap bank on the Buffalo Road 115 kV bus   | b1770            | \$ 45,814           | \$ -                        | \$ 45,814                 | 0.00%            | \$ -               | 6,162   | \$ -   |
| (29) | Install a 25 MVAR 115 kV Capacitor at Grandview   | b1990            | \$ 67,305           | \$ -                        | \$ 67,305                 | 0.00%            | \$ -               | 6,162   | \$ -   |
| (30) | Install a 44 MVAR 138 kV capacitor at Luxor substation  | b1985            | \$ 129,494          | \$ -                        | \$ 129,494                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (31) | Install additional 33 MVAR capacitors at Grand Point 138 kV SS and Guildford 138 kV SS  | b1839            | \$ 185,325          | \$ -                        | \$ 185,325                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (32) | Install a 75 MVAR 115 kV Capacitor at Shawville   | b1998            | \$ 275,036          | \$ -                        | \$ 275,036                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (33) | Install a 50 MVAR capacitor at Grover 230 kV substation   | b0556            | \$ 95,037           | \$ -                        | \$ 95,037                 | 0.00%            | \$ -               | 6,162   | \$ -   |
| (34) | Upgrade Conemaugh 500/230 kV transformer and new line from Conemaugh-Seward 230 kV  | b1153            | \$ 3,074,498        | \$ -                        | \$ 3,074,498              | 0.55%            | \$ 16,910          | 6,162   | \$ 2.74                                      |
| (35) | Install a 500/138 kV transformer at 502 Junction  | b1023.1          | \$ 2,623,594        | \$ -                        | \$ 2,623,594              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (36) | Loop the Homer City-Handsome Lake 345 kV line into the Armstrong substation and install a 345/138 kV transformer at Armstrong   | b1941            | \$ 2,972,077        | \$ -                        | \$ 2,972,077              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (37) | Build a 300 MVAR Switched Shunt at Doubs 500 kV and increase (~50 MVAR) in size the existing Switched Shunt at Doubs 500 kV   | b1803            | \$ 368,017          | \$ -                        | \$ 368,017                | 3.79%            | \$ 13,948          | 6,162   | \$ 2.26                                      |
| (38) | Build a 300 MVAR Switched Shunt at Doubs 500 kV and increase (~50 MVAR) in size the existing Switched Shunt at Doubs 500 kV   | b1803_dfax       | \$ 368,017          | \$ -                        | \$ 368,017                | 7.14%            | \$ 26,276          | 6,162   | \$ 4.26                                      |
| (39) | Build a 500 MVAR SVC at Hunterstown 500 kV  | b1800            | \$ 2,654,011        | \$ -                        | \$ 2,654,011              | 3.79%            | \$ 100,587         | 6,162   | \$ 16.32                                     |
| (40) | Build a 500 MVAR SVC at Hunterstown 500 kV  | b1800_dfax       | \$ 2,654,011        | \$ -                        | \$ 2,654,011              | 12.71%           | \$ 337,325         | 6,162   | \$ 54.75                                     |
| (41) | Build a 600 MVAR SVC at Meadow Brook 500 kV   | b1804            | \$ 3,330,492        | \$ -                        | \$ 3,330,492              | 3.79%            | \$ 126,226         | 6,162   | \$ 20.49                                     |
| (42) | Build a 600 MVAR SVC at Meadow Brook 500 kV   | b1804_dfax       | \$ 3,330,492        | \$ -                        | \$ 3,330,492              | 10.11%           | \$ 336,713         | 6,162   | \$ 54.65                                     |
| (43) | Install breaker and a half 138 kV substation (Waldo Run) with 4 breakers to accommodate service to MarkWest Sherwood Facility including metering which is cut into Glen Falls-Lambert 138 kV line | b2433.1-b.2433.3 | \$ 6,586,276        | \$ -                        | \$ 6,586,276              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (44) | Replace the Blairsville 138/115 kV transformer  | b1967            | \$ 397,365          | \$ -                        | \$ 397,365                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (45) | Construct Four Mile Junction 230/115 kV substation. Loop the Erie South - Erie East 230 kV line, Buffalo Road - Corry East and Buffalo Road - Erie South 138 kV lines                             | b1609            | \$ 1,045,618        | \$ -                        | \$ 1,045,618              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (46) | Install a 75 MVAR cap bank on the Four Mile 230 kV bus  | b1769            | \$ -                | \$ -                        | \$ -                      | 0.00%            | \$ -               | 6,162   | \$ -   |
| (47) | Install second 230/115 kV autotransformer at Johnstown  | b1945            | \$ 513,779          | \$ -                        | \$ 513,779                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (48) | Install a new 230 kV breaker at Yeagertown  | b1610            | \$ 116,563          | \$ -                        | \$ 116,563                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (49) | Build a 250 MVAR SVC at Altoona 230 kV  | b1801            | \$ 3,834,451        | \$ -                        | \$ 3,834,451              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (50) | Convert Moshannon substation to a 4 breaker 230 kV ring bus   | b1964            | \$ 837,213          | \$ -                        | \$ 837,213                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (51) | Construct a new 138 kV switching station (Shuman Hill substation) , which is next the Mobley 138kV substation and a 345/138 kV line   | b2342            | \$ 177,064          | \$ -                        | \$ 177,064                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (52) | Install a 31.7 MVAR capacitor   | b1672            | \$ 59,444           | \$ -                        | \$ 59,444                 | 0.00%            | \$ -               | 6,162   | \$ -   |
| (53) | Install a 31.7 MVAR capacitor at West Union 138kV substation  | b2343            | \$ 104,072          | \$ -                        | \$ 104,072                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (54) | Loop the Buckhannon - Glen Falls 138 kV line into West Milford Substation   | b1840            | \$ 1,906,163        | \$ -                        | \$ 1,906,163              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (55) | Install a TCR/FC at the Monocacy 230 kV bus to enable a smooth controlled VAR operation between a range of -150   | b2235            | \$ 4,146,908        | \$ -                        | \$ 4,146,908              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (56) | MVAR to 50 MVAR   | b2260            | \$ 70,433           | \$ -                        | \$ 70,433                 | 0.00%            | \$ -               | 6,162   | \$ -   |
| (57) | Build a 100 MVAR Fast Switched Shunt and 100 MVAR Switched Shunt near Mansfield at the new Mainesburg 345 kV substation   | b1802            | \$ -                | \$ -                        | \$ -                      | 0.00%            | \$ -               | 6,162   | \$ -   |
| (58) | Construct a new 345/115 kV substation (Mainesburg) and loop the Mansfield - Everts 115 kV   | b1608            | \$ 2,524,067        | \$ -                        | \$ 2,524,067              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (59) | Install two 345 kV 80 MVAR shunt reactors at Mainesburg station   | b2944            | \$ 1,118,443        | \$ -                        | \$ 1,118,443              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (60) | Install a 100 MVAR capacitor at Johnstown 230 kV substation   | b0555            | \$ 148,216          | \$ -                        | \$ 148,216                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (61) | Construct a 115 kV ring bus at Clayscburg Substation. Bedford North and Saxton lines will no longer share a common breaker  | b1943            | \$ 787,055          | \$ -                        | \$ 787,055                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (62) | Install a new 230/138kV transformer at Squab Hollow 230kV substation. Loop the Brookville - Elko 138 kV line into Squab Hollow  | b2364-b2364.1    | \$ 1,885,462        | \$ -                        | \$ 1,885,462              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (63) | Install a 250 MVAR SVC at Squab Hollow 230 kV   | b2362            | \$ 3,418,354        | \$ -                        | \$ 3,418,354              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (64) | Install a 75 MVAR 230 kV capacitor at Shingletown Substation  | b2156            | \$ 177,933          | \$ -                        | \$ 177,933                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (65) | Install a 51.8 MVAR (rated) 138 kV capacitor at Nyswaner 138 kV substation  | b2546            | \$ 97,287           | \$ -                        | \$ 97,287                 | 0.00%            | \$ -               | 6,162   | \$ -   |
| (66) | 0   | b2545            | \$ 7,951,591        | \$ -                        | \$ 7,951,591              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (67) | Install +250/-100 MVAR SVC at the Erie South 230 kV station   | b2441            | \$ 4,860,042        | \$ -                        | \$ 4,860,042              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (68) | Construct a new 138 kV six breaker ring bus Joffre substation   | b2547.1          | \$ 5,165,655        | \$ -                        | \$ 5,165,655              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (69) | Construct a new line between Oak Mount 138 kV substation and Waldo Run 138 kV substation  | b2475            | \$ 12,285,118       | \$ -                        | \$ 12,285,118             | 0.00%            | \$ -               | 6,162   | \$ -   |
| (70) | Construct Pierce Brook 345/230 kV and 230/115 kV substation. Loop the Homer City-Stolle Road 345 kV line into Farmers Valley  | b1991            | \$ 4,203,060        | \$ -                        | \$ 4,203,060              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (71) | Install a 33 MVAR capacitor at Damascus   | b2261            | \$ (216,673)        | \$ -                        | \$ (216,673)              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (72) | Construct Warren 230 kV ring bus and install a second Warren 230/115 kV transformer   | b2494            | \$ 2,891,883        | \$ -                        | \$ 2,891,883              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (73) | Install 138 kV breaker at Joffre substation and construct approximately 1.3 miles of radial 138 kV line from Joffre substation to new customer facility   | s1041            | \$ -                | \$ -                        | \$ -                      | 0.00%            | \$ -               | 6,162   | \$ -   |
| (74) | Reconfigure Pierce Brook 345 kV station to a ring bus and install a 125 MVAR shunt reactor at the substation  | b2587            | \$ 403,187          | \$ -                        | \$ 403,187                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (75) | Add 44 MVAR Cap at New Martinsville   | b2118            | \$ -                | \$ -                        | \$ -                      | 0.00%            | \$ -               | 6,162   | \$ -   |
| (76) | New Flint Run 500-138 kV substation   | b2990-b2996.2    | \$ 19,661,945       | \$ -                        | \$ 19,661,945             | 0.00%            | \$ -               | 6,162   | \$ -   |

| (77) | Total  | \$ 243,649,896 | \$ -                | \$ 243,649,896              | \$                        | \$ 11,690,920    | \$                 | \$ 1,897.35   |  |
|------|--|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|---|--|
| (78) |  | (B)            | (C)                 | (D)                         | (E) = (C) + (D)           | (F)              | (G) = (E) x (F)    | (H)   | (I) = (G) / (H)                              |
| (79) | Baltimore Gas & Electric Company's Network Customers   | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (80) | Replace both Conastone 500/230kV transformer banks with larger transformers, and other configuration changes   | b0298          | \$ 6,252,594        | \$ -                        | \$ 6,252,594              | 7.88%            | \$ 492,704         | 6,162   | \$ 79.96                                     |
| (81) | Install a 4th Waugh Chapel 500/230 kV transformer, terminate the transformer in a new 500 kV bay and operate the existing in-service spare transformer on standby and other associated configuration changes | b0244          | \$ 4,668,740        | \$ -                        | \$ 4,668,740              | 13.61%           | \$ 635,416         | 6,162   | \$ 103.12                                    |
| (82) | Replace the Waugh Chapel 500/230 kV transformer #1 with three single phase transformers  | b0477          | \$ 3,006,686        | \$ -                        | \$ 3,006,686              | 4.01%            | \$ 120,568         | 6,162   | \$ 19.57                                     |
| (83) | Install a second Conastone - Graceton 230 kV circuit and replace Conastone 230 kV breaker 2323/2302  | b0497          | \$ 2,942,284        | \$ -                        | \$ 2,942,284              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (84) | Rebuild Graceton - Bagley 230 kV as double circuit line using 1590 ACSR. Terminate new line at Graceton with a new circuit breaker   | b1016          | \$ 12,076,193       | \$ -                        | \$ 12,076,193             | 6.66%            | \$ 804,274         | 6,162   | \$ 130.53                                    |
| (85) | Rebuild the existing Bagley - Raphael Rd. 230 kV line to double circuit 230 kV line  | b1251          | \$ 3,243,605        | \$ -                        | \$ 3,243,605              | 5.21%            | \$ 168,992         | 6,162   | \$ 27.43                                     |
| (87) | Reconfigure Raphael Rd. to terminate new circuit   | b1251.1        | \$ 4,068,150        | \$ -                        | \$ 4,068,150              | 5.21%            | \$ 211,951         | 6,162   | \$ 34.40                                     |
| (88) | Upgrade substation equipment at Conastone 500 kV (on the Peach Bottom - Conastone 500 kV circuit) to increase facility rating to 3826 MVA normal and 3625 MVA emergency                                      | b2766.1        | \$ 610,104          | \$ -                        | \$ 610,104                | 3.79%            | \$ 23,123          | 6,162   | \$ 3.75                                      |
| (89) | Upgrade substation equipment at Conastone 500 kV (on the Peach Bottom - Conastone 500 kV circuit) to increase facility rating to 3826 MVA normal and 3625 MVA emergency                                      | b2766.1_dfax   | \$ 610,104          | \$ -                        | \$ 610,104                | 18.76%           | \$ 114,455         | 6,162   | \$ 18.58                                     |
| (90) | Replacing short segment of substation conductor on the Windy Edge to Glenarm 110512 115kV circuit  | b2992.3        | \$ 49,231           | \$ -                        | \$ 49,231                 | 20.53%           | \$ 10,107          | 6,162   | \$ 1.64                                      |
| (91) | Reconductor the Raphael Road - Northeast 2315 & 2337 230kV circuits  | b2992.4        | \$ 1,677,361        | \$ -                        | \$ 1,677,361              | 20.53%           | \$ 344,362         | 6,162   | \$ 55.89                                     |
| (92) | Reconductor the Conastone to Graceton 230 kV 2323 & 2324 circuits. Replace 7 disconnect switches at Conastone Substation   | b2992.1        | \$ 3,249,405        | \$ -                        | \$ 3,249,405              | 20.53%           | \$ 666,898         | 6,162   | \$ 108.23                                    |
| (93) | Add Bundle conductor on the Graceton-Bagley-Raphael Road 2305 & 2313 230kV circuits  | b2992.2        | \$ 4,197,370        | \$ -                        | \$ 4,197,370              | 20.53%           | \$ 901,720         | 6,162   | \$ 139.65                                    |
| (94) | Total  |                | \$ 46,650,826       | \$ -                        | \$ 46,650,826             | \$               | \$ 4,454,570       | \$ -  | \$ 723                                       |

PJM Schedule 12 - Transmission Enhancement Charges for June 2025 - May 2026 for Non-Pepco Zone Required Transmission Enhancements

| (A)   | (B)   | (C)            | (D)                 | (E) = (C) + (D)             | (F)                       | (G) = (E) x (F)  | (H)                | (I) = (G) / (H)   |  |
|-------|---|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|---|--|
|       | Dominion Virginia Power's Network Customers   | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (95)  | Upgrade Mt. Storm - Doubs 500kV   | b0217          | \$ 97,506           | \$ -                        | \$ 97,506                 | 3.79%            | \$ 3,695           | 6,162   | \$ 0.60                                      |
| (96)  | Upgrade Mt. Storm - Doubs 500kV   | b0217_dfax     | \$ 97,506           | \$ -                        | \$ 97,506                 | 7.14%            | \$ 6,962           | 6,162   | \$ 1.13                                      |
| (97)  | Install 150 MVAR capacitor at Loudoun 500kV   | b0222          | \$ 79,233           | \$ -                        | \$ 79,233                 | 3.79%            | \$ 3,003           | 6,162   | \$ 0.49                                      |
| (98)  | Install 150 MVAR capacitor at Loudoun 500kV   | b0222_dfax     | \$ 79,233           | \$ -                        | \$ 79,233                 | 8.04%            | \$ 6,370           | 6,162   | \$ 1.03                                      |
| (99)  | Install 500/230kV transformer at Clifton and Clifton 230kV 150 MVAR capacitor   | b0226          | \$ 799,190          | \$ -                        | \$ 799,190                | 7.04%            | \$ 56,263          | 6,162   | \$ 9.13                                      |
| (100) | 2nd Dooms 500/230kV transformer addition  | b0403          | \$ 875,894          | \$ -                        | \$ 875,894                | 7.39%            | \$ 64,729          | 6,162   | \$ 10.50                                     |
| (101) | Build new Meadow Brook - Loudoun 500kV circuit (65 of 81 miles)   | b0328.1        | \$ 12,069,157       | \$ -                        | \$ 12,069,157             | 3.79%            | \$ 457,421         | 6,162   | \$ 74.24                                     |
| (102) | Build new Meadow Brook - Loudoun 500kV circuit (65 of 81 miles)   | b0328.1_dfax   | \$ 12,069,157       | \$ -                        | \$ 12,069,157             | 8.04%            | \$ 970,360         | 6,162   | \$ 157.48                                    |
| (103) | Upgrade Mt. Storm 500kV substation and add two new bays   | b0328.3        | \$ 739,621          | \$ -                        | \$ 739,621                | 3.79%            | \$ 28,032          | 6,162   | \$ 4.55                                      |
| (104) | Upgrade Mt. Storm 500kV substation and add two new bays   | b0328.3_dfax   | \$ 739,621          | \$ -                        | \$ 739,621                | 10.11%           | \$ 74,776          | 6,162   | \$ 12.14                                     |
| (105) | Upgrade Loudoun 500kV substation  | b0328.4        | \$ 166,877          | \$ -                        | \$ 166,877                | 3.79%            | \$ 6,325           | 6,162   | \$ 1.03                                      |
| (106) | Upgrade Loudoun 500kV substation  | b0328.4_dfax   | \$ 166,877          | \$ -                        | \$ 166,877                | 8.04%            | \$ 13,417          | 6,162   | \$ 2.18                                      |
| (107) | Loop line #251 Idywood - Arlington into the GIS sub   | b0768          | \$ 2,509,762        | \$ -                        | \$ 2,509,762              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (108) | Lexington 230kV bus reconfiguration   | b0337          | \$ 642,630          | \$ -                        | \$ 642,630                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (109) | Reconductor Idywood to Arlington circuit 251 230kV  | b0311          | \$ 324,691          | \$ -                        | \$ 324,691                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (110) | Install 500 kV breakers & 500 kV bus work at Suffolk  | b0231          | \$ 1,111,749        | \$ -                        | \$ 1,111,749              | 3.79%            | \$ 42,135          | 6,162   | \$ 6.84                                      |
| (111) | Install 500 kV breakers & 500 kV bus work at Suffolk  | b0231_dfax     | \$ 1,111,749        | \$ -                        | \$ 1,111,749              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (112) | Reconductor 9.4 miles of Edinburg - Mt. Jackson 115kV Line #128   | b0456          | \$ 470,472          | \$ -                        | \$ 470,472                | 14.05%           | \$ 66,101          | 6,162   | \$ 10.73                                     |
| (113) | Install 500/230kV transformer at Bristers   | b0227          | \$ 2,029,770        | \$ -                        | \$ 2,029,770              | 12.20%           | \$ 247,632         | 6,162   | \$ 40.19                                     |
| (114) | Add 2nd Endless Caverns 230/15kv transformer  | b0455          | \$ 328,533          | \$ -                        | \$ 328,533                | 7.67%            | \$ 25,199          | 6,162   | \$ 4.09                                      |
| (115) | Convert Remington - Swoego 115kV to 230kV   | b0453.1        | \$ 153,400          | \$ -                        | \$ 153,400                | 3.86%            | \$ 5,921           | 6,162   | \$ 0.96                                      |
| (116) | Add Swoego - Gainesville 230kV  | b0453.2        | \$ 1,466,647        | \$ -                        | \$ 1,466,647              | 3.86%            | \$ 56,613          | 6,162   | \$ 9.19                                      |
| (117) | Add 230/115kV Auto transformer at Bristers to feed Swoego   | b0453.3        | \$ 341,502          | \$ -                        | \$ 341,502                | 3.86%            | \$ 13,182          | 6,162   | \$ 2.14                                      |
| (118) | Mount Storm 500 kV - replace the existing MOD on the 500 kV side of the RSS2 transformer with a circuit breaker   | b0387          | \$ 37,447           | \$ -                        | \$ 37,447                 | 3.79%            | \$ 1,419           | 6,162   | \$ 0.23                                      |
| (119) | Mount Storm 500 kV - replace the existing MOD on the 500 kV side of the RSS2 transformer with a circuit breaker   | b0837_dfax     | \$ 37,447           | \$ -                        | \$ 37,447                 | 0.00%            | \$ -               | 6,162   | \$ -   |
| (120) | Build 2nd Harrisonburg-Valley 230 kV  | b0327          | \$ 608,915          | \$ -                        | \$ 608,915                | 4.03%            | \$ 24,539          | 6,162   | \$ 3.98                                      |
| (121) | Replace Chesapeake 115kV breaker T242'  | b0329.2A       | \$ 4,352,698        | \$ -                        | \$ 4,352,698              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (122) | Replace Chesapeake 115kV breaker T242'  | b0329.2B       | \$ 8,783,270        | \$ -                        | \$ 8,783,270              | 3.79%            | \$ 332,886         | 6,162   | \$ 54.03                                     |
| (123) | Replace Chesapeake 115kV breaker T242'  | b0329.2B_dfax  | \$ 8,783,270        | \$ -                        | \$ 8,783,270              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (124) | Reconductor the Dickerson - Pleasant View 230kV circuit   | b0467.2        | \$ 556,258          | \$ -                        | \$ 556,258                | 41.86%           | \$ 232,849         | 6,162   | \$ 37.79                                     |
| (125) | Terminal Equipment upgrade at Mt. Storm 500 kV substation   | b1507          | \$ 17,614,308       | \$ -                        | \$ 17,614,308             | 3.79%            | \$ 667,582         | 6,162   | \$ 108.34                                    |
| (126) | Terminal Equipment upgrade at Mt. Storm 500 kV substation   | b1507_dfax     | \$ 17,614,308       | \$ -                        | \$ 17,614,308             | 7.14%            | \$ 1,257,662       | 6,162   | \$ 204.11                                    |
| (127) | Replace both wave traps on Dooms - Lexington 500kV  | b0457          | \$ 5,532            | \$ -                        | \$ 5,532                  | 3.79%            | \$ 210             | 6,162   | \$ 0.03                                      |
| (128) | Replace both wave traps on Dooms - Lexington 500kV  | b0457_dfax     | \$ 5,532            | \$ -                        | \$ 5,532                  | 8.17%            | \$ 452             | 6,162   | \$ 0.07                                      |
| (129) | Replace wave traps on North Anna to Ladysmith 500 kV  | b0784          | \$ 3,836            | \$ -                        | \$ 3,836                  | 3.79%            | \$ 145             | 6,162   | \$ 0.02                                      |
| (130) | Replace wave traps on North Anna to Ladysmith 500 kV  | b0784_dfax     | \$ 3,836            | \$ -                        | \$ 3,836                  | 7.61%            | \$ 292             | 6,162   | \$ 0.05                                      |
| (131) | Install 2nd Clover 500/230 kV transformer and a 150 MVAR capacitor  | b1224          | \$ 1,536,776        | \$ -                        | \$ 1,536,776              | 11.04%           | \$ 169,660         | 6,162   | \$ 27.53                                     |
| (132) | Upgrade 115kV shunt capacitor banks at Merck and Edinburg   | b1508.3        | \$ 126,710          | \$ -                        | \$ 126,710                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (133) | Upgrade the name plate rating at Morrisville 500kV breaker 'H1T573' with 50kA breaker.  | b1647          | \$ 848              | \$ -                        | \$ 848                    | 3.79%            | \$ 32              | 6,162   | \$ 0.01                                      |
| (134) | Upgrade the name plate rating at Morrisville 500kV breaker 'H1T573' with 50kA breaker.  | b1647_dfax     | \$ 848              | \$ -                        | \$ 848                    | 0.00%            | \$ -               | 6,162   | \$ -   |
| (135) | Upgrade name plate rating at Morrisville 500kV breaker 'H2T545' with 50kA breaker.  | b1648          | \$ 848              | \$ -                        | \$ 848                    | 3.79%            | \$ 32              | 6,162   | \$ 0.01                                      |
| (136) | Upgrade name plate rating at Morrisville 500kV breaker 'H2T545' with 50kA breaker.  | b1648_dfax     | \$ 848              | \$ -                        | \$ 848                    | 0.00%            | \$ -               | 6,162   | \$ -   |
| (137) | Replace Morrisville 500kV breaker 'H1T580' with 50kA breaker.   | b1649          | \$ 44,767           | \$ -                        | \$ 44,767                 | 3.79%            | \$ 1,697           | 6,162   | \$ 0.28                                      |
| (138) | Replace Morrisville 500kV breaker 'H1T580' with 50kA breaker.   | b1649_dfax     | \$ 44,767           | \$ -                        | \$ 44,767                 | 0.00%            | \$ -               | 6,162   | \$ -   |
| (139) | Replace Morrisville 500kV breaker 'H2T569' with 50kA breaker.   | b1650          | \$ 44,767           | \$ -                        | \$ 44,767                 | 3.79%            | \$ 1,697           | 6,162   | \$ 0.28                                      |
| (140) | Replace Morrisville 500kV breaker 'H2T569' with 50kA breaker.   | b1650_dfax     | \$ 44,767           | \$ -                        | \$ 44,767                 | 0.00%            | \$ -               | 6,162   | \$ -   |
| (141) | Install one 500/230 kV transformer and two 230 kV breakers at Brambleton  | b1186.6        | \$ 1,817,192        | \$ -                        | \$ 1,817,192              | 14.76%           | \$ 268,218         | 6,162   | \$ 43.53                                     |
| (142) | Build new Brambleton 500 kV three breaker ring bus connected to the Loudoun to Pleasant View 500 kV line  | b1189          | \$ 79,093           | \$ -                        | \$ 79,093                 | 3.79%            | \$ 2,998           | 6,162   | \$ 0.49                                      |
| (143) | Build new Brambleton 500 kV three breaker ring bus connected to the Loudoun to Pleasant View 500 kV line  | b1188_dfax     | \$ 79,093           | \$ -                        | \$ 79,093                 | 0.00%            | \$ -               | 6,162   | \$ -   |
| (144) | Build a new 500-115kV substation at Spotsylvania Substation (Gold Dale Junction) with one 500-115kV, 336 MVA transformer bank. Install a 500kV ring bus and a 115kV breaker and a half bus at this location | b1321          | \$ 4,213,920        | \$ -                        | \$ 4,213,920              | 1.19%            | \$ 50,146          | 6,162   | \$ 8.14                                      |
| (145) | Install two 500 kV breakers at Chancellor 500 kV  | b0756.1        | \$ 220,452          | \$ -                        | \$ 220,452                | 3.79%            | \$ 8,355           | 6,162   | \$ 1.36                                      |
| (146) | Install two 500 kV breakers at Chancellor 500 kV  | b0756.1_dfax   | \$ 220,452          | \$ -                        | \$ 220,452                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (147) | Wreck and rebuild 7 miles of the Dominion owned section of Cloerdale - Lexington 500 kV   | b1797          | \$ 979,761          | \$ -                        | \$ 979,761                | 3.79%            | \$ 37,133          | 6,162   | \$ 6.03                                      |
| (148) | Wreck and rebuild 7 miles of the Dominion owned section of Cloerdale - Lexington 500 kV   | b1797_dfax     | \$ 979,761          | \$ -                        | \$ 979,761                | 16.91%           | \$ 165,678         | 6,162   | \$ 26.89                                     |

| (A)   | (B)            | (C)                 | (D)                         | (E) = (C) + (D)           | (F)              | (G) = (E) x (F)    | (H)   | (I) = (G) / (H)                              |
|---|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|---|--|
| PSE&G's Network Customers   | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (149) Build 150 MVAR Switched Shunt at Pleasant View 500 kV   | b1799          | \$ 1,421,226        | \$ -                        | \$ 1,421,226              | 3.79% \$         | \$ 53,864          | 6,162   | \$ 8.74                                      |
| (150) Build 150 MVAR Switched Shunt at Pleasant View 500 kV   | b1799_dfax     | \$ 1,421,226        | \$ -                        | \$ 1,421,226              | 10.87% \$        | \$ 154,487         | 6,162   | \$ 25.07                                     |
| (151) Build two +250/-150 MVAR SVCs and 300 MVAR switched shunt at Mosby 500 kV   | b1798          | \$ 6,016,977        | \$ -                        | \$ 6,016,977              | 3.79% \$         | \$ 228,043         | 6,162   | \$ 37.01                                     |
| (152) Build two +250/-150 MVAR SVCs and 300 MVAR switched shunt at Mosby 500 kV   | b1798_dfax     | \$ 6,016,977        | \$ -                        | \$ 6,016,977              | 8.04% \$         | \$ 483,765         | 6,162   | \$ 79.51                                     |
| (153) Build a +250/-150 MVAR SVC at Mt. Storm 500 kV & change voltage regulation at Mt. Storm to 15 pu  | b1805          | \$ 2,004,807        | \$ -                        | \$ 2,004,807              | 3.79% \$         | \$ 75,982          | 6,162   | \$ 12.33                                     |
| (154) Build a +250/-150 MVAR SVC at Mt. Storm 500 kV & change voltage regulation at Mt. Storm to 15 pu  | b1805_dfax     | \$ 2,004,807        | \$ -                        | \$ 2,004,807              | 16.83% \$        | \$ 337,409         | 6,162   | \$ 54.76                                     |
| (155) Build a 2nd 230 kV Line Harrisonburg to Endless Caverns   | b1508.1        | \$ 7,110,052        | \$ -                        | \$ 7,110,052              | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| (156) Install a 3rd 230-115kV Tx at Endless Caverns   | b1508.2        | \$ 1,302,368        | \$ -                        | \$ 1,302,368              | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| (157) Rebuild Altavista - Skinner 28 mile 115 kV line   | b2053          | \$ 4,781,575        | \$ -                        | \$ 4,781,575              | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| (158) At Yardin 500 kV, install six 500 kV breakers to loop in Septa - Fentress 500 kV  | b1906.1        | \$ 557,901          | \$ -                        | \$ 557,901                | 3.79% \$         | \$ 21,144          | 6,162   | \$ 3.43                                      |
| (159) At Yardin 500 kV, install six 500 kV breakers to loop in Septa - Fentress 500 kV  | b1906.1_dfax   | \$ 557,901          | \$ -                        | \$ 557,901                | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| (160) Rebuild Lexington - Dooms 500 kV  | b1908          | \$ 7,080,043        | \$ -                        | \$ 7,080,043              | 3.79% \$         | \$ 268,334         | 6,162   | \$ 43.55                                     |
| (161) Rebuild Lexington - Dooms 500 kV  | b1908_dfax     | \$ 7,080,043        | \$ -                        | \$ 7,080,043              | 8.17% \$         | \$ 578,439         | 6,162   | \$ 93.88                                     |
| (162) Surry 500 kV Station Work   | b1905.2        | \$ 101,956          | \$ -                        | \$ 101,956                | 3.79% \$         | \$ 3,864           | 6,162   | \$ 0.63                                      |
| (163) Surry 500 kV Station Work   | b1905.2_dfax   | \$ 101,956          | \$ -                        | \$ 101,956                | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| Upgrade the 3.63 mile line section between Possum and Dumfries substations, replace the 1600 amp wave trap at Eddystone Point   | b1328          | \$ 434,306          | \$ -                        | \$ 434,306                | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| Install a 2nd 500/230 kV transformer at Brambleton  | b1698          | \$ 2,574,863        | \$ -                        | \$ 2,574,863              | 22.04% \$        | \$ 567,600         | 6,162   | \$ 92.10                                     |
| Install a 3rd 500/230 kV TX at Clover   | b1907          | \$ 2,093,803        | \$ -                        | \$ 2,093,803              | 7.64% \$         | \$ 159,967         | 6,162   | \$ 25.96                                     |
| Upgrade Bremo - Midlothian 230 kV to its maximum operating temperature  | b1909          | \$ 380,925          | \$ -                        | \$ 380,925                | 7.98% \$         | \$ 30,398          | 6,162   | \$ 4.93                                      |
| Install four +/- 125 MVAR STATCOM at Landstown, Chesapeake, Fentress, and Lynnhaven   | b1912          | \$ 11,220,895       | \$ -                        | \$ 11,220,895             | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| Reconductor Fredericksburg - Cranes Corner 230 kV   | b1701          | \$ 363,428          | \$ -                        | \$ 363,428                | 17.09% \$        | \$ 62,110          | 6,162   | \$ 10.08                                     |
| (170) Wreck and rebuild 2.1 mile section of Line #11 section between Gordonsville and Somerset  | b1791          | \$ 287,743          | \$ -                        | \$ 287,743                | 9.54% \$         | \$ 27,451          | 6,162   | \$ 4.46                                      |
| (171) Rebuild Loudoun - Brambleton 500 kV   | b1694          | \$ 2,639,628        | \$ -                        | \$ 2,639,628              | 3.79% \$         | \$ 100,042         | 6,162   | \$ 16.24                                     |
| (172) Rebuild Loudoun - Brambleton 500 kV   | b1694_dfax     | \$ 2,639,628        | \$ -                        | \$ 2,639,628              | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| (173) Add a second Valley 500/230 kV TX   | b1911          | \$ 2,483,729        | \$ -                        | \$ 2,483,729              | 7.93% \$         | \$ 196,960         | 6,162   | \$ 31.97                                     |
| Replace Midlothian 500 kV breaker 563T576 and motor operated switches with 3 breaker 500 kV ring bus. Terminate Lines #563 Carson - Midlothian - North Anna. Transformer #2 in new ring   | b2471_dfax     | \$ 440,938          | \$ -                        | \$ 440,938                | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| Replace Midlothian 500 kV breaker 563T576 and motor operated switches with 3 breaker 500 kV ring bus. Terminate Lines #563 Carson - Midlothian - North Anna. Transformer #2 in new ring   | b2471          | \$ 440,938          | \$ -                        | \$ 440,938                | 3.79% \$         | \$ 16,712          | 6,162   | \$ 2.71                                      |
| (175) Surry to Skiffes Creek 500 kV Line (7 miles overhead)   | b1905.1        | \$ 15,026,848       | \$ -                        | \$ 15,026,848             | 3.79% \$         | \$ 569,518         | 6,162   | \$ 92.43                                     |
| (177) Surry to Skiffes Creek 500 kV Line (7 miles overhead)   | b1905.1_dfax   | \$ 15,026,848       | \$ -                        | \$ 15,026,848             | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| (178) Wheaton 230 kV breakers   | b1905.5        | \$ 600,834          | \$ -                        | \$ 600,834                | 0.16% \$         | \$ 961             | 6,162   | \$ 0.16                                      |
| Install a breaker and a half scheme with a minimum of eight 230 kV breakers for five existing lines at Idylwood 230 kV  | b1696          | \$ 23,105,243       | \$ -                        | \$ 23,105,243             | 1.34% \$         | \$ 309,610         | 6,162   | \$ 50.25                                     |
| Build a 2nd Loudoun - Brambleton 500 kV line within the existing ROW. The Loudoun - Brambleton 230 kV line will be relocated as an underbuild on the new 500 kV line  | b2373          | \$ 2,503,691        | \$ -                        | \$ 2,503,691              | 3.79% \$         | \$ 94,890          | 6,162   | \$ 15.40                                     |
| Build a 2nd Loudoun - Brambleton 500 kV line within the existing ROW. The Loudoun - Brambleton 230 kV line will be relocated as an underbuild on the new 500 kV line  | b2373_dfax     | \$ 2,503,691        | \$ -                        | \$ 2,503,691              | 11.14% \$        | \$ 278,911         | 6,162   | \$ 45.27                                     |
| (181) Skiffes Creek 500-230 kV Tx and Switching Station   | b1905.3        | \$ 13,379,730       | \$ -                        | \$ 13,379,730             | 0.16% \$         | \$ 21,408          | 6,162   | \$ 3.47                                      |
| (183) New Skiffes Creek - Wheaton 230 kV line   | b1905.4        | \$ 9,912,144        | \$ -                        | \$ 9,912,144              | 0.16% \$         | \$ 15,859          | 6,162   | \$ 2.57                                      |
| (184) Rebuild the Carson - Rogers Rd 500 kV circuit   | b2744_dfax     | \$ 3,318,564        | \$ -                        | \$ 3,318,564              | 3.83% \$         | \$ 127,101         | 6,162   | \$ 20.63                                     |
| (185) Rebuild the Carson - Rogers Rd 500 kV circuit   | b2744          | \$ 3,318,564        | \$ -                        | \$ 3,318,564              | 3.79% \$         | \$ 125,774         | 6,162   | \$ 20.41                                     |
| (186) Yorktown 230 kV work  | b1905.6        | \$ 164,602          | \$ -                        | \$ 164,602                | 0.16% \$         | \$ 263             | 6,162   | \$ 0.04                                      |
| (187) Lanexa 115 kV work  | b1905.7        | \$ 12,879           | \$ -                        | \$ 12,879                 | 0.16% \$         | \$ 21              | 6,162   | \$ 0.00                                      |
| (188) Kings Mill, Pennington, Toano, Waller, Warwick  | b1905.9        | \$ 10,290           | \$ -                        | \$ 10,290                 | 0.16% \$         | \$ 16              | 6,162   | \$ 0.00                                      |
| Rebuild the Elmont - Cunningham 500 kV line   | b2582          | \$ 5,445,076        | \$ -                        | \$ 5,445,076              | 3.79% \$         | \$ 206,368         | 6,162   | \$ 33.49                                     |
| Rebuild the Elmont - Cunningham 500 kV line   | b2582_dfax     | \$ 5,445,076        | \$ -                        | \$ 5,445,076              | 7.05% \$         | \$ 383,678         | 6,162   | \$ 62.30                                     |
| (191) Construct new underground 230kV line from Glebe to Station C.   | b2443          | \$ 5,940,893        | \$ -                        | \$ 5,940,893              | 2.71% \$         | \$ 160,998         | 6,162   | \$ 26.13                                     |
| (192) Rebuild the Cunningham - Dooms 500 kV line  | b2665          | \$ 4,640,397        | \$ -                        | \$ 4,640,397              | 3.79% \$         | \$ 175,671         | 6,162   | \$ 28.54                                     |
| (193) Rebuild the Cunningham - Dooms 500 kV line  | b2665_dfax     | \$ 4,640,397        | \$ -                        | \$ 4,640,397              | 11.38% \$        | \$ 528,077         | 6,162   | \$ 85.70                                     |
| (194) Rebuild Line #549 Dooms - Valley 500kV  | b2758          | \$ 3,423,567        | \$ -                        | \$ 3,423,567              | 3.79% \$         | \$ 129,753         | 6,162   | \$ 21.06                                     |
| (195) Rebuild Line #549 Dooms - Valley 500kV  | b2758_dfax     | \$ 3,423,567        | \$ -                        | \$ 3,423,567              | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| Optimal Capacitors Configuration: New 175 MVAR 230 kV capacitor bank at Brambleton substation, new 175 MVAR 230 kV capacitor bank at Ashburn substation, new 300 MVAR 230 kV capacitor bank at Shelbourn substation, new 150 MVAR 230 kV capacitor bank at Liberty substation | b2729          | \$ 1,112,228        | \$ -                        | \$ 1,112,228              | 20.23% \$        | \$ 225,004         | 6,162   | \$ 36.52                                     |
| (196) Rebuild four structures of 500kV Line #567 from Chickahominy to Surry using galvanized steel and replace the river crossing conductor with 3-1534 ACSR. This will increase the Line #567 Line Rating from 1954 MVA to 2600 MVA.   | b2928          | \$ 1,911,375        | \$ -                        | \$ 1,911,375              | 3.79% \$         | \$ 72,441          | 6,162   | \$ 11.76                                     |
| (197) Replace fixed series capacitors on 500kV Line #547 at Lexington   | b2960.1        | \$ 1,081,703        | \$ -                        | \$ 1,081,703              | 3.79% \$         | \$ 40,997          | 6,162   | \$ 6.65                                      |
| (200) Replace fixed series capacitors on 500kV Line #547 at Lexington   | b2960.1_dfax   | \$ 1,081,703        | \$ -                        | \$ 1,081,703              | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| (201) Replace fixed series capacitors on 500kV Line #548 at Valley  | b2960.2        | \$ 1,130,782        | \$ -                        | \$ 1,130,782              | 3.79% \$         | \$ 42,857          | 6,162   | \$ 6.96                                      |
| (202) Replace fixed series capacitors on 500kV Line #548 at Valley  | b2960.2_dfax   | \$ 1,130,782        | \$ -                        | \$ 1,130,782              | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| (203) Install 2-125 MVAR STATCOMs at Rawlings and 1-125 MVAR STATCOM at Clover 500 kV Substations   | b2978          | \$ 6,600,387        | \$ -                        | \$ 6,600,387              | 3.79% \$         | \$ 250,155         | 6,162   | \$ 40.60                                     |
| (204) Install 2-125 MVAR STATCOMs at Rawlings and 1-125 MVAR STATCOM at Clover 500 kV Substations   | b2978_dfax     | \$ 6,600,387        | \$ -                        | \$ 6,600,387              | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| (205) Rebuild Line #550 Mt. Storm - Valley 500kV  | b2759          | \$ 39,732,389       | \$ -                        | \$ 39,732,389             | 3.79% \$         | \$ 1,505,858       | 6,162   | \$ 244.39                                    |
| (206) Rebuild Line #550 Mt. Storm - Valley 500kV  | b2759_dfax     | \$ 39,732,389       | \$ -                        | \$ 39,732,389             | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| (207) Add a 2nd 500/230 kV 840 MVA transformer at Dominion's Ladysmith Substation   | b3027.1        | \$ 3,101,081        | \$ -                        | \$ 3,101,081              | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| (208) Rebuild 500kV Line #552 Bristlers to Chancellor - 21.6 miles long   | b3019          | \$ 5,940,753        | \$ -                        | \$ 5,940,753              | 3.79% \$         | \$ 225,155         | 6,162   | \$ 36.54                                     |
| (209) Rebuild 500kV Line #552 Bristlers to Chancellor - 21.6 miles long   | b3019_dfax     | \$ 5,940,753        | \$ -                        | \$ 5,940,753              | 0.00% \$         | \$ 6,162           | \$ -  |  |
| (210) Rebuild 500kV Line #574 Ladysmith to Elmont - 26.2 miles long   | b3020          | \$ 2,269,660        | \$ -                        | \$ 2,269,660              | 3.79% \$         | \$ 85,078          | 6,162   | \$ 12.95                                     |
| (211) Rebuild 500kV Line #574 Ladysmith to Elmont - 26.2 miles long   | b3020_dfax     | \$ 2,269,660        | \$ -                        | \$ 2,269,660              | 15.46% \$        | \$ 350,719         | 6,162   | \$ 56.92                                     |
| (212) Rebuild 500kV Line #581 Ladysmith to Chancellor - 15.2 miles long   | b3021          | \$ 3,838,281        | \$ -                        | \$ 3,838,281              | 3.79% \$         | \$ 145,471         | 6,162   | \$ 23.61                                     |
| (213) Rebuild 500kV Line #581 Ladysmith to Chancellor - 15.2 miles long   | b3021_dfax     | \$ 3,838,281        | \$ -                        | \$ 3,838,281              | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| Install one 13.5 Ohm series reactor to control the power flow on the 230 kV line #2054 from Charlottesville to Profitt Rd 230 kV line.  | b3702          | \$ (270,119)        | \$ -                        | \$ (270,119)              | 9.69% \$         | \$ (26,175)        | 6,162   | \$ (4.25)                                    |
| Construct a new 500 kV transmission line for ~ 3.5 miles along with substation upgrades at Wishing Star and Mars. New right-of-way will be needed and will share same structures with the line. New conductor to have a minimum summer normal rating of 4357 MVA              | b3718.3        | \$ 19,406,322       | \$ -                        | \$ 19,406,322             | 3.79% \$         | \$ 735,500         | 6,162   | \$ 119.37                                    |
| Construct a new 500 kV transmission line for ~ 3.5 miles along with substation upgrades at Wishing Star and Mars. New right-of-way will be needed and will share same structures with the line. New conductor to have a minimum summer normal rating of 4357 MVA              | b3718.3_dfax   | \$ 19,406,322       | \$ -                        | \$ 19,406,322             | 0.00% \$         | \$ -               | 6,162   | \$ -   |
| Total   |                | \$ 470,480,939      | \$ -                        | \$ 470,480,939            | \$               | \$ 15,521,524      | \$  | \$ 2,519                                     |

| (A)                       | (B)            | (C)                 | (D)                         | (E) = (C) + (D)           | (F)              | (G) = (E) x (F)    | (H)   | (I) = (G) / (H)                              |
|---------------------------|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|---|--|
| PSE&G's Network Customers | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |

PJM Schedule 12 - Transmission Enhancement Charges for June 2024 - May 2025 for Non-Pepco Zone Required Transmission Enhancements

|       |  |                 |               |               |               |            |              |       |          |           |
|-------|--|-----------------|---------------|---------------|---------------|------------|--------------|-------|----------|-----------|
| (217) | Replace all de-rated Branchburg 500/230 kV transformers  | b0130           | \$ 1,414,616  | \$ -          | \$ 1,414,616  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (218) | Upgrade or re-tension PSEG portion of Kittatinny - Newton 230 kV circuit   | b0134           | \$ 582,673    | \$ -          | \$ 582,673    | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (219) | Build new Essex - Aldene 230kV cable connected through a phase angle regulator at Essex  | b0145           | \$ 6,242,098  | \$ -          | \$ 6,242,098  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (220) | Install 4th 500/230kV transformer at New Freedom   | b0411           | \$ 1,577,732  | \$ -          | \$ 1,577,732  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (221) | Loop the 5021 circuit into New Freedom 500 kV substation   | b0498           | \$ 1,013,245  | \$ -          | \$ 1,013,245  | 3.79%      | \$ 38,402    | -     | 6,162    | \$ 6.23   |
| (222) | Loop the 5021 circuit into New Freedom 500 kV substation   | b0498 dfax      | \$ 1,013,245  | \$ -          | \$ 1,013,245  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (223) | Install 230/138kV transformer at Metuchen substation   | b0161           | \$ 1,960,730  | \$ -          | \$ 1,960,730  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (224) | Build a new 230 kV section from Branchburg - Flagtown and move the Flagtown - Somerville 230 kV circuit to the new section                             | b0169           | \$ 1,198,221  | \$ -          | \$ 1,198,221  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (225) | Reconductor the Flagtown-Somerville-Bridgewater 230 kV circuit with 1590 ACSS  | b0170           | \$ 522,161    | \$ -          | \$ 522,161    | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (226) | Construct a Susquehanna - Roseland 500kV circuit (PSEG 500 kV equipment)   | b0489           | \$ 34,225,122 | \$ -          | \$ 34,225,122 | 3.79%      | \$ 1,297,132 | -     | 6,162    | \$ 210.52 |
| (227) | Construct a Susquehanna - Roseland 500kV circuit (PSEG 500 kV equipment)   | b0489 dfax      | \$ 34,225,122 | \$ -          | \$ 34,225,122 | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (228) | Install two Roseland 500/230 kV transformers and upgrade 230 kV substation and switchyard  | b0489.4         | \$ 3,708,524  | \$ -          | \$ 3,708,524  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (229) | Replace wave trap on 5016 line at Branchburg 500kV substation  | b0172.2         | \$ 1,018      | \$ -          | \$ 1,018      | 3.79%      | \$ 39        | -     | 6,162    | \$ 0.01   |
| (230) | Replace wave trap on 5016 line at Branchburg 500kV substation  | b0172.2 dfax    | \$ 1,018      | \$ -          | \$ 1,018      | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (231) | Reconductor Hudson-South Waterfront 230 kV   | b0813           | \$ 728,878    | \$ -          | \$ 728,878    | 1.11%      | \$ 8,091     | -     | 6,162    | \$ 1.31   |
| (232) | Reconductor South Mahwah - Waldwick 345 kV J-3410 circuit  | b1017           | \$ 1,663,179  | \$ -          | \$ 1,663,179  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (233) | Reconductor South Mahwah - Waldwick 345 kV K-3411 circuit  | b1018           | \$ 1,731,433  | \$ -          | \$ 1,731,433  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (234) | Replace Roseland 230 kV breaker 42H with 80 kA   | b0489.5-9       | \$ 10,491     | \$ -          | \$ 10,491     | 3.79%      | \$ 398       | -     | 6,162    | \$ 0.06   |
| (235) | Replace Roseland 230 kV breaker 42H with 80 kA   | b0489.5-9 dfax  | \$ 10,491     | \$ -          | \$ 10,491     | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (236) | Replace Salem 500kV breaker 11X  | b1410-1415      | \$ 675,112    | \$ -          | \$ 675,112    | 3.79%      | \$ 25,587    | -     | 6,162    | \$ 4.15   |
| (237) | Replace Salem 500kV breaker 11X  | b1410-1415 dfax | \$ 675,112    | \$ -          | \$ 675,112    | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (238) | Install 400MVAR capacitor in the Branchburg 500kV vicinity   | b0290           | \$ 3,182,838  | \$ -          | \$ 3,182,838  | 3.79%      | \$ 120,630   | -     | 6,162    | \$ 19.58  |
| (239) | Install 400MVAR capacitor in the Branchburg 500kV vicinity   | b0290 dfax      | \$ 3,182,838  | \$ -          | \$ 3,182,838  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (240) | Increase the emergency rating of Saddle Brook - Athenia 230 kV by 25% by adding forced cooling   | b0472           | \$ 1,193,282  | \$ -          | \$ 1,193,282  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (241) | Branchburg - Flagtown - Reconductor circuit - upgrade 230kV with 2x1033 ACSS (4 mil)   | b0664-0665      | \$ 1,542,051  | \$ -          | \$ 1,542,051  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (242) | Somerville - Bridgewater - upgrade 230kV with double 1033 ACSS conductor   | b0668           | \$ 532,762    | \$ -          | \$ 532,762    | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (243) | New Essex-Kearny 138 kV circuit and Kearny 138 kV bus tie  | b0814           | \$ 3,860,924  | \$ -          | \$ 3,860,924  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (244) | Convert the Burlingam, Camden, and Cuthbert Blvd 138 kV substations and associated lines from 138 kV to 230 kV   | b1156           | \$ 30,735,725 | \$ -          | \$ 30,735,725 | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (245) | Convert the West Orange 138 kV substation, the Roseland - West Orange 138 kV circuit , and the Roseland - Sewaren 138 kV circuit from 138 kV to 230 kV | b1154           | \$ 31,495,646 | \$ -          | \$ 31,495,646 | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (246) | Re-configure the Lawrence 230 kV substation to breaker and half  | b1228           | \$ 1,845,210  | \$ -          | \$ 1,845,210  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (247) | Build a new 69 kV substation (Ridge Road) and build new 69 kV circuits from Montgomery - Ridge Road - Penns Neck/Dow Jones                             | b1255           | \$ 4,133,251  | \$ -          | \$ 4,133,251  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (248) | Reconductor the Eagle Point - Gloucester 230 kV circuit #1 and #2 with higher conductor rating   | b1588           | \$ 1,077,866  | \$ -          | \$ 1,077,866  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (249) | Reconductor the Mickleton - Gloucester 230 kV parallel circuits with double bundle conductor   | b2139           | \$ 1,752,169  | \$ -          | \$ 1,752,169  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (250) | Convert the existing D1304' and G1307' 138 kV circuits between Roseland - Kearny- Hudson to 230 kV operation   | b1304.1-4       | \$ 56,729,036 | \$ -          | \$ 56,729,036 | 1.04%      | \$ 589,982   | -     | 6,162    | \$ 95.75  |
| (251) | 0 b1398  | \$ 39,103,074   | \$ -          | \$ 39,103,074 | 0.57%         | \$ 222,888 | -            | 6,162 | \$ 36.17 |           |
| (252) | Build a new 230 kV circuit from Branchburg to Bridgewater and reconfigure the Bridgewater 230 kV substation to breaker and a half configuration        | b1155           | \$ 5,402,256  | \$ -          | \$ 5,402,256  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (253) | Convert the 138 kV path from Aldene-Springfield Rd - West Orange to 230 kV   | b1399           | \$ 6,362,601  | \$ -          | \$ 6,362,601  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (254) | Convert the Marion - Bayonne "L" 138 kV circuit to 345 kV and any associated substation upgrades   | b2436.21 dfax   | \$ 3,110,677  | \$ -          | \$ 3,110,677  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (255) | Convert the Marion - Bayonne "L" 138 kV circuit to 345 kV and any associated substation upgrades   | b2436.21        | \$ 3,110,677  | \$ -          | \$ 3,110,677  | 3.79%      | \$ 117,895   | -     | 6,162    | \$ 19.13  |
| (256) | Convert the Marion - Bayonne "C" 138 kV circuit to 345 kV and any associated substation upgrades   | b2436.22 dfax   | \$ 2,299,962  | \$ -          | \$ 2,299,962  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (257) | Convert the Marion - Bayonne "C" 138 kV circuit to 345 kV and any associated substation upgrades   | b2436.22        | \$ 2,299,962  | \$ -          | \$ 2,299,962  | 3.79%      | \$ 87,169    | -     | 6,162    | \$ 14.15  |
| (258) | Relocate the overhead portion of Linden - North Ave "T" 138 kV circuit to Bayway; convert it to 345 kV, and any associated substation upgrades         | b2436.81 dfax   | \$ 2,595,298  | \$ -          | \$ 2,595,298  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (259) | Relocate the overhead portion of Linden - North Ave "T" 138 kV circuit to Bayway; convert it to 345 kV, and any associated substation upgrades         | b2436.81        | \$ 2,595,298  | \$ -          | \$ 2,595,298  | 3.79%      | \$ 98,362    | -     | 6,162    | \$ 15.96  |
| (260) | Convert the Bayway - Linden "Z" 138 kV circuit to 345 kV and any associated substation upgrades  | b2436.83 dfax   | \$ 2,595,298  | \$ -          | \$ 2,595,298  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (261) | Convert the Bayway - Linden "Z" 138 kV circuit to 345 kV and any associated substation upgrades  | b2436.83        | \$ 2,595,298  | \$ -          | \$ 2,595,298  | 3.79%      | \$ 98,362    | -     | 6,162    | \$ 15.96  |
| (262) | Relocate Farragut - Hudson "B" and "C" 345 kV circuits to Marion 345 kV and any associated substation upgrades   | b2436.90 dfax   | \$ 1,439,564  | \$ -          | \$ 1,439,564  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (263) | Relocate Farragut - Hudson "B" and "C" 345 kV circuits to Marion 345 kV and any associated substation upgrades   | b2436.90        | \$ 1,439,564  | \$ -          | \$ 1,439,564  | 3.79%      | \$ 54,559    | -     | 6,162    | \$ 8.85   |
| (264) | New Bergen 345/230 kV transformer and any associated substation upgrades   | b2437.10        | \$ 2,557,009  | \$ -          | \$ 2,557,009  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (265) | New Bayway 345/138 kV transformer #1 and any associated substation upgrades  | b2437.20        | \$ 834,009    | \$ -          | \$ 834,009    | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (266) | New Bayway 345/138 kV transformer #2 and any associated substation upgrades  | b2437.21        | \$ 833,983    | \$ -          | \$ 833,983    | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (267) | New Linden 345/230 kV transformer and any associated substation upgrades   | b2437.30        | \$ 3,216,691  | \$ -          | \$ 3,216,691  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (268) | Upgrade the PSEG portion of the Camden - Richmond 230 kV circuit to six wire conductor and replace terminal equipment at Camden                        | b1590           | \$ 996,031    | \$ -          | \$ 996,031    | 1.93%      | \$ 19,223    | -     | 6,162    | \$ 3.12   |
| (269) | Build a second 230 kV circuit from Cox's Corner - Lumberton  | b1787           | \$ 2,891,431  | \$ -          | \$ 2,891,431  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (270) | Convert the Bergen - Marion 138 kV path to double circuit 345 kV and associated substation upgrades  | b2436.10 dfax   | \$ 8,242,073  | \$ -          | \$ 8,242,073  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (271) | Convert the Bergen - Marion 138 kV path to double circuit 345 kV and associated substation upgrades  | b2436.10        | \$ 8,242,073  | \$ -          | \$ 8,242,073  | 3.79%      | \$ 312,375   | -     | 6,162    | \$ 50.70  |
| (272) | Convert the Bergen - Linden "W" 138 kV circuit to 345 kV and any associated substation upgrades  | b2436.84 dfax   | \$ 2,517,763  | \$ -          | \$ 2,517,763  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (273) | Convert the Bergen - Linden "W" 138 kV circuit to 345 kV and any associated substation upgrades  | b2436.84        | \$ 2,517,763  | \$ -          | \$ 2,517,763  | 3.79%      | \$ 95,423    | -     | 6,162    | \$ 15.49  |
| (274) | Convert the Bayway - Linden "M" 138 kV circuit to 345 kV and any associated substation upgrades  | b2436.85 dfax   | \$ 2,517,763  | \$ -          | \$ 2,517,763  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (275) | Convert the Bayway - Linden "M" 138 kV circuit to 345 kV and any associated substation upgrades  | b2436.85        | \$ 2,517,763  | \$ -          | \$ 2,517,763  | 3.79%      | \$ 95,423    | -     | 6,162    | \$ 15.49  |
| (276) | Install 250 MVAR capacitor at Conemaugh 500kV substation   | b0376           | \$ 50,325     | \$ -          | \$ 50,325     | 3.79%      | \$ 1,907     | -     | 6,162    | \$ 0.31   |
| (277) | Install 250 MVAR capacitor at Conemaugh 500kV substation   | b0376 dfax      | \$ 50,325     | \$ -          | \$ 50,325     | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (278) | Re-configure the Kearny 230 kV substation and loop the P-2216-1 (Essex - NJT Meadows) 230 kV circuit   | b1589           | \$ 2,114,197  | \$ -          | \$ 2,114,197  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (279) | Re-configure the Brunswick 230 kV and 69 kV substations  | b2146           | \$ 15,122,916 | \$ -          | \$ 15,122,916 | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (280) | Install two 175 MVAR reactors at Hopatcong 500 kV  | b2702 dfax      | \$ 1,070,346  | \$ -          | \$ 1,070,346  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (281) | Install two 175 MVAR reactors at Hopatcong 500 kV  | b2702           | \$ 1,070,346  | \$ -          | \$ 1,070,346  | 3.79%      | \$ 40,566    | -     | 6,162    | \$ 6.58   |
| (282) | Add a new 500 kV bay at Hope Creek (Expansion of Hope Creek substation)  | b2633.4         | \$ 2,737,138  | \$ -          | \$ 2,737,138  | 3.79%      | \$ 103,738   | -     | 6,162    | \$ 16.84  |
| (283) | Add a new 500 kV bay at Hope Creek (Expansion of Hope Creek substation)  | b2633.4 dfax    | \$ 2,737,138  | \$ -          | \$ 2,737,138  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (284) | Add a new 500/230 kV autotransformer at Hope Creek and a new Hope Creek 230 kV substation  | b2633.5         | \$ 7,299,631  | \$ -          | \$ 7,299,631  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (285) | Wreck and re-build the VFT - Wannanaco - Aldene 230 kV circuit with paired conductor.  | b2955           | \$ 9,846,477  | \$ -          | \$ 9,846,477  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (286) | Convert the R-1318 and Q1317 (Edison - Metuchen) 138 kV circuits to one 230 kV circuit (Brunswick - Meadow Road)                                       | b2835.1         | \$ 8,251,975  | \$ -          | \$ 8,251,975  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (287) | Convert the R-1318 and Q1317 (Edison - Metuchen) 138 kV circuits to one 230 kV circuit (Meadow Road - Pierson Ave)                                     | b2835.2         | \$ 5,288,126  | \$ -          | \$ 5,288,126  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (288) | Convert the R-1318 and Q1317 (Edison - Metuchen) 138 kV circuits to one 230 kV circuit (Pierson Ave - Metuchen)  | b2835.3         | \$ 876,783    | \$ -          | \$ 876,783    | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (289) | Convert the N-1340 and T-1372/D-1330 (Brunswick - Trenton) 138 kV circuits to 230 kV circuits (Hunterleng - Trenton)                                   | b2836.2         | \$ 7,868,343  | \$ -          | \$ 7,868,343  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (290) | Convert the N-1340 and T-1372/D-1330 (Brunswick - Trenton) 138 kV circuits to 230 kV circuits (Brunswick - Devils Brook)                               | b2836.3         | \$ 5,113,661  | \$ -          | \$ 5,113,661  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (291) | Convert the N-1340 and T-1372/D-1330 (Brunswick - Trenton) 138 kV circuits to 230 kV circuits (Devils Brook - Trenton)                                 | b2836.4         | \$ 9,833,891  | \$ -          | \$ 9,833,891  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |
| (292) | Convert the F-1358/Z-1326 and K-1363/Y-1325 (Trenton - Burlington) 138 kV circuits to 230 kV circuits (Trenton - Yardville K)                          | b2837.1         | \$ 3,777,221  | \$ -          | \$ 3,777,221  | 0.00%      | \$ -         | -     | 6,162    | \$ -      |

|              | (A)  | (B)            | (C)                   | (D)                         | (E) = (C) + (D)           | (F)              | (G) = (E) x (F)     | (H)   | (I) = (G) / (H)                              |
|--------------|--|----------------|-----------------------|-----------------------------|---------------------------|------------------|---------------------|---|--|
|              | PPL Electric Utilities Corp. dba PPL Utilities   | PJM Upgrade ID | Revenue Requirement   | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges  | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (354)        | Construct a Susquehanna - Roseland 500kV circuit (PPL 500 kV equipment)                    | b0487          | \$ 30,920,357         | \$ -                        | \$ 30,920,357             | 3.79%            | \$ 1,171,882        | 6,162   | \$ 190.19                                    |
| (355)        | Construct a Susquehanna - Roseland 500kV circuit (PPL 500 kV equipment)                    | b0487 dfax     | \$ 30,920,357         | \$ -                        | \$ 30,920,357             | 0.00%            | \$ -                | 6,162   | \$ -   |
| (356)        | Replace wavetrap at Hosesack 500kV substation to increase rating of Elroy - Hosesack 500kV | b0171.2        | \$ 3,421              | \$ -                        | \$ 3,421                  | 3.79%            | \$ 130              | 6,162   | \$ 0.02                                      |
| (357)        | Replace wavetrap at Hosesack 500kV substation to increase rating of Elroy - Hosesack 500kV | b0171.2 dfax   | \$ 3,421              | \$ -                        | \$ 3,421                  | 0.00%            | \$ -                | 6,162   | \$ -   |
| (358)        | Replace wave trap at Alburtis 500kV substation   | b0172.1        | \$ 2,453              | \$ -                        | \$ 2,453                  | 3.79%            | \$ 93               | 6,162   | \$ 0.02                                      |
| <b>Total</b> |  |                | <b>\$ 803,731,504</b> | <b>\$ -</b>                 | <b>\$ 803,731,504</b>     |                  | <b>\$ 3,428,148</b> | <b>6,162</b>  | <b>\$ 556.36</b>                             |

|       | (A)  | (B)            | (C)                 | (D)                         | (E) = (C) + (D)           | (F)              | (G) = (E) x (F)    | (H)   | (I) = (G) / (H)                              |
|-------|--|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|---|--|
|       | PPL Electric Utilities Corp. dba PPL Utilities   | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (354) | Construct a Susquehanna - Roseland 500kV circuit (PPL 500 kV equipment)                    | b0487          | \$ 30,920,357       | \$ -                        | \$ 30,920,357             | 3.79%            | \$ 1,171,882       | 6,162   | \$ 190.19                                    |
| (355) | Construct a Susquehanna - Roseland 500kV circuit (PPL 500 kV equipment)                    | b0487 dfax     | \$ 30,920,357       | \$ -                        | \$ 30,920,357             | 0.00%            | \$ -               | 6,162   | \$ -   |
| (356) | Replace wavetrap at Hosesack 500kV substation to increase rating of Elroy - Hosesack 500kV | b0171.2        | \$ 3,421            | \$ -                        | \$ 3,421                  | 3.79%            | \$ 130             | 6,162   | \$ 0.02                                      |
| (357) | Replace wavetrap at Hosesack 500kV substation to increase rating of Elroy - Hosesack 500kV | b0171.2 dfax   | \$ 3,421            | \$ -                        | \$ 3,421                  | 0.00%            | \$ -               | 6,162   | \$ -   |
| (358) | Replace wave trap at Alburtis 500kV substation   | b0172.1        | \$ 2,453            | \$ -                        | \$ 2,453                  | 3.79%            | \$ 93              | 6,162   | \$ 0.02                                      |

PJM Schedule 12 - Transmission Enhancement Charges for June 2024 - May 2025 for Non-Pepco Zone Required Transmission Enhancements

|       |  |                |                     |                             |                           |                  |                    |   |   |  |
|-------|--|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|---|---|--|
| (359) | Replace wave trap at Alburtis 500kV substation   | b0172.1_dfax   | \$ 2,453            | \$ -                        | \$ 2,453                  | 0.00%            | \$ -               | -   | 6,162   | \$ -   |
| (360) | Replace two wave traps at Juniata 500kV - on the two Juniata - new Airydale 500kV line   | b0284.2        | \$ 4,977            | \$ -                        | \$ 4,977                  | 3.79%            | \$ 189             | -   | 6,162   | \$ 0.03                                      |
| (361) | Replace two wave traps at Juniata 500kV - on the two Juniata - new Airydale 500kV line   | b0284.2_dfax   | \$ 4,977            | \$ -                        | \$ 4,977                  | 0.00%            | \$ -               | -   | 6,162   | \$ -   |
| (362) | Install Lackawanna 500/230 kV substation and upgrade 230 kV substation and switchyard  | b0487.1        | \$ 1,470,482        | \$ -                        | \$ 1,470,482              | 0.00%            | \$ -               | -   | 6,162   | \$ -   |
| (363) | Add a fourth 230/69 kV transformer at Stanton  | b0791          | \$ 324,108          | \$ -                        | \$ 324,108                | 0.00%            | \$ -               | -   | 6,162   | \$ -   |
| (364) | Build a new substation with two 150 MVA transformers between Dauphin and Hummelstown 230 / 69 kV substations by sectionalizing the Middletown Junction – North Lebanon 230 kV line   | b0468          | \$ 2,000,393        | \$ -                        | \$ 2,000,393              | 0.00%            | \$ -               | -   | 6,162   | \$ -   |
| (365) | Install Lauschtown 500/230 kV substation (below 500 kV portion) - Includes the 500/230 kV transformer  | b2006          | \$ 946,903          | \$ -                        | \$ 946,903                | 0.00%            | \$ -               | -   | 6,162   | \$ -   |
| (366) | Install Lauschtown 500/230 kV substation (500 kV portion) - Includes 500 kV yard work, 500 kV CBs, and 500 kV line tie-in  | b2006.1        | \$ 2,006,359        | \$ -                        | \$ 2,006,359              | 3.79%            | \$ 76,041          | -   | 6,162   | \$ 12.34                                     |
| (367) | Install Lauschtown 500/230 kV substation (500 kV portion) - Includes 500 kV yard work, 500 kV CBs, and 500 kV line tie-in  | b2006.1_dfax   | \$ 2,006,359        | \$ -                        | \$ 2,006,359              | 0.00%            | \$ -               | -   | 6,162   | \$ -   |
| (368) | 200 MVAR shunt reactor at Alburtis 500 kV  | b2237          | \$ 725,831          | \$ -                        | \$ 725,831                | 3.79%            | \$ 27,509          | -   | 6,162   | \$ 4.46                                      |
| (369) | 200 MVAR shunt reactor at Alburtis 500 kV  | b2237_dfax     | \$ 725,831          | \$ -                        | \$ 725,831                | 0.00%            | \$ -               | -   | 6,162   | \$ -   |
| (370) | Add a 200 MVAR shunt reactor at Lackawanna 500 kV substation   | b2716          | \$ 681,163          | \$ -                        | \$ 681,163                | 3.79%            | \$ 25,816          | -   | 6,162   | \$ 4.19                                      |
| (371) | Add a 200 MVAR shunt reactor at Lackawanna 500 kV substation   | b2716_dfax     | \$ 681,163          | \$ -                        | \$ 681,163                | 0.00%            | \$ -               | -   | 6,162   | \$ -   |
| (372) | Reconfigure/Expand the Lackawanna 500 kV substation by adding a third bay with three breakers  | b2824          | \$ 830,329          | \$ -                        | \$ 830,329                | 3.79%            | \$ 31,469          | -   | 6,162   | \$ 5.11                                      |
| (373) | Reconfigure/Expand the Lackawanna 500 kV substation by adding a third bay with three breakers  | b2824_dfax     | \$ 830,329          | \$ -                        | \$ 830,329                | 0.00%            | \$ -               | -   | 6,162   | \$ -   |
| (374) | Lackawanna 230 kV Yard: Upgrade Oxbow terminal equipment   | b2552.2        | \$ 65,668           | \$ -                        | \$ 65,668                 | 0.00%            | \$ -               | -   | 6,162   | \$ -   |
| (375) | Lackawanna 230 kV Yard: Upgrade Oxbow terminal equipment   | b3698          | \$ 2,166,594        | \$ 1                        | \$ 2,166,595              | 4.68%            | \$ 101,397         | -   | 6,162   | \$ 16.46                                     |
| (376) | Total  |                | \$ 77,323,923       | \$ -                        | \$ 77,323,924.00          | \$ -             | \$ 1,434,525       | \$ -  | 6,162   | \$ 232.81                                    |
| (377) |  |                |                     |                             |                           |                  |                    |   |   |  |
| (378) |  | (A)            | (B)                 | (C)                         | (D)                       | (E) = (C) + (D)  | (F)                | (G) = (E) x (F)   | (H)   | (I) = (G) / (H)                              |
| (379) | AEP East Operating Companies and AEP Transmission Companies*   | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (380) | Add two advanced technology circuit breakers at Hanging Rock 765 kV to improve operational performance   | b0504          | \$ 299,033          | \$ -                        | \$ 299,033                | 3.79%            | \$ 11,333          | 6,162   | \$ 1.84   |  |
| (381) | Add two advanced technology circuit breakers at Hanging Rock 765 kV to improve operational performance   | b0504_dfax     | \$ 299,033          | \$ -                        | \$ 299,033                | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (382) | Install a 765/138 kV transformer at Amos   | b0318          | \$ 1,200,012        | \$ -                        | \$ 1,200,012              | 1.00%            | \$ 12,000          | 6,162   | \$ 1.95   |  |
| (383) | Replace existing 450 MVA transformer at Twin Branch 345 / 138 kV with a 675 MVA transformer  | b0839          | \$ 731,865          | \$ -                        | \$ 731,865                | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (384) | Replace the existing 138/69-12 kV transformer at West Moulton Station with a 138/69 kV transformer and a 69/12 kV transformer. Reconducto  | b1231          | \$ 1,164,771        | \$ -                        | \$ 1,164,771              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (385) | Reconducto East Side Lima - Sterling 138 kV  | b0570          | \$ 1,346,644        | \$ -                        | \$ 1,346,644              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (386) | Replace the 100 MVAR 765 kV shunt reactor bank on Rockport - Jefferson 765 kV line with a 300 MVAR bank at Rockport Station  | b1465.2        | \$ 765,761          | \$ -                        | \$ 765,761                | 3.79%            | \$ 29,022          | 6,162   | \$ 4.71   |  |
| (387) | Replace the 100 MVAR 765 kV shunt reactor bank on Rockport - Jefferson 765 kV line with a 300 MVAR bank at Rockport Station  | b1465.2_dfax   | \$ 765,761          | \$ -                        | \$ 765,761                | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (388) | Make switching changes at Jefferson 765 kV station   | b1465.4        | \$ 318,780          | \$ -                        | \$ 318,780                | 3.79%            | \$ 12,082          | 6,162   | \$ 1.96   |  |
| (389) | Make switching changes at Jefferson 765 kV station   | b1465.4_dfax   | \$ 318,780          | \$ -                        | \$ 318,780                | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (390) | Establish new South Canton - West Canton 138kV line (replacing Torrey - West Canton) and Wagenhals - Wayview 138kV   | b1034.1        | \$ 1,688,930        | \$ -                        | \$ 1,688,930              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (391) | Replace all 138kV circuit breakers at South Canton Station and operate the station in a breaker and a half configuration   | b1034.6        | \$ 256,235          | \$ -                        | \$ 256,235                | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (392) | Transpose the Rockport - Sullivan 765 kV line and the Rockport - Jefferson 765 kV line   | b1465.3        | \$ 1,089,502        | \$ -                        | \$ 1,089,502              | 3.79%            | \$ 41,292          | 6,162   | \$ 6.70   |  |
| (393) | Transpose the Rockport - Sullivan 765 kV line and the Rockport - Jefferson 765 kV line   | b1465.3_dfax   | \$ 1,089,502        | \$ -                        | \$ 1,089,502              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (394) | Rebuild the Altavista - Leesville 138 kV line  | b1712.2        | \$ 233,343          | \$ -                        | \$ 233,343                | 24.70%           | \$ 57,636          | 6,162   | \$ 9.35   |  |
| (395) | Add second West Bellaire - Brues 138 kV circuit  | b1864.2        | \$ 235,064          | \$ -                        | \$ 235,064                | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (396) | Replace both Tanners Creek 345/138 kV transformer #1 and #2 with one bigger transformer  | b2048          | \$ 651,843          | \$ -                        | \$ 651,843                | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (397) | Install additional 138kV circuit breakers at the West Canton, South Canton, Canton Central, and Wagenhals stations to accommodate the new circuits   | b1034.8        | \$ 512,387          | \$ -                        | \$ 512,387                | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (398) | Replace the Ohio Central transformer # 135/138/12 kV 450 MVA for a 345/138/34.5 kV 675 MVA transformer   | b1870          | \$ 816,307          | \$ -                        | \$ 816,307                | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (399) |  | b1032.2        | \$ 2,821,368        | \$ -                        | \$ 2,821,368              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (400) | Loop the existing South Canton - Wayview 138kV circuit in-and-out of West Canton   | b1034.2        | \$ 1,223,321        | \$ -                        | \$ 1,223,321              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (401) | Install a 345/38kV 450 MVA transformer at Canton Central   | b1034.3        | \$ 1,656,966        | \$ -                        | \$ 1,656,966              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (402) | Rebuild Amos - Kanawha River 138 kV corridor   | b2020          | \$ 18,239,564       | \$ -                        | \$ 18,239,564             | 0.02%            | \$ 3,648           | 6,162   | \$ 0.59   |  |
| (403) | Add 345/138 transformer at Sporn, Kanawha River & Muskingum River stations   | b2021          | \$ 5,275,639        | \$ -                        | \$ 5,275,639              | 0.04%            | \$ 2,110           | 6,162   | \$ 0.34   |  |
| (404) | Build approximately 14 miles of 765 kV line from existing Dumont - Marysville line   | b1659.14       | \$ 3,407,295        | \$ -                        | \$ 3,407,295              | 3.79%            | \$ 129,136         | 6,162   | \$ 20.96  |  |
| (405) | Build approximately 14 miles of 765 kV line from existing Dumont - Marysville line   | b1659.14_dfax  | \$ 3,407,295        | \$ -                        | \$ 3,407,295              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (406) | Rebuild 138 kV Elliot tap - Poston line  | b2032          | \$ 475,343          | \$ -                        | \$ 475,343                | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (407) | Replace all obsolete 138kV circuit breakers at the Torrey and Wagenhals stations   | b1034.7        | \$ 545,241          | \$ -                        | \$ 545,241                | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (408) | Loop Conesville - Bixby 345 kV circuit into Ohio Central   | b2018          | \$ 2,541,862        | \$ -                        | \$ 2,541,862              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (409) | Add two additional 345/138 kV transformers at Kammer   | b1864.1        | \$ 9,132,025        | \$ -                        | \$ 9,132,025              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (410) | Install a 765 kV circuit breaker at Wyoming station  | b1661          | \$ 109,044          | \$ -                        | \$ 109,044                | 3.79%            | \$ 4,133           | 6,162   | \$ 0.67   |  |
| (411) | Install a 765 kV circuit breaker at Wyoming station  | b1661_dfax     | \$ 109,044          | \$ -                        | \$ 109,044                | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (412) | Reconductor or rebuild Sporn - Waterford - Muskingum River 345 kV line   | b2017          | \$ 8,984,709        | \$ -                        | \$ 8,984,709              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (413) | Expand the Allen station by installing a second 345/138 kV transformer and adding four 138 kV exits by cutting in the Lincoln - Sterling and Milan - Timber Switch 138 kV double circuit tower line                                  | b1818          | \$ 8,051,041        | \$ -                        | \$ 8,051,041              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (414) | Rebuild the Robison Park - Sorenson 138 kV line corridor as a 345 kV double circuit line with one side operated at 345 kV and one side at 138 kV   | b1819          | \$ 10,833,331       | \$ -                        | \$ 10,833,331             | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (415) | Install 138/69kV transformer at new station and connect in the Ross - Highland 69kV line with two 69 kV exits  | b1032.4        | \$ 930,913          | \$ -                        | \$ 930,913                | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (416) | Build new nine (9) breaker 138 kV station near Ohio Power Company's Morrical Switch Station tapping both circuits of the Etna/Central - East Lima 138 kV line  | b1666          | \$ 2,699,841        | \$ -                        | \$ 2,699,841              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (417) | Terminate Transformer #2 at SW Lima in a new bay position  | b1957          | \$ 1,213,386        | \$ -                        | \$ 1,213,386              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (418) | Add four 765 kV breakers at Kammer   | b1962          | \$ 1,153,645        | \$ -                        | \$ 1,153,645              | 3.79%            | \$ 43,723          | 6,162   | \$ 7.10   |  |
| (419) | Add four 765 kV breakers at Kammer   | b1962_dfax     | \$ 1,153,645        | \$ -                        | \$ 1,153,645              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (420) | Establish Holloway 345/138 kV station  | b2019          | \$ 7,248,989        | \$ -                        | \$ 7,248,989              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (421) | Construct a new 345/138/6 kV station on the Marquis - Bixby 345 kV line near the intersection with Ross - Highland 69 kV   | b1032.1        | \$ 3,521,113        | \$ -                        | \$ 3,521,113              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (422) | Establish a new 765/345 interconnection at Sporn. Install a 765/345 kV transformer at Mountaineer and build ½ mile of 345 kV to Sporn  | b1948          | \$ 5,728,736        | \$ -                        | \$ 5,728,736              | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (423) | Terminal Tristate - Kyger Creek 345 kV line at Sporn   | b2022          | \$ 444,239          | \$ -                        | \$ 444,239                | 0.00%            | \$ -               | 6,162   | \$ -  |  |
| (424) | Install a 765/500 kV transformer at Cloverdale   | b1660          | \$ 178,934          | \$ -                        | \$ 178,934                | 3.79%            | \$ 6,782           | 6,162   | \$ 1.10   |  |
| (425) | Install a 765/500 kV transformer at Cloverdale   | b1660_dfax     | \$ 178,934          | \$ -                        | \$ 178,934                | 33.81%           | \$ 60,498          | 6,162   | \$ 9.82   |  |
| (426) | Cloverdale: install 6 765kV breakers, which includes incremental work for 2 additional breakers (total of 6 installed), reconfigure and relocate miscellaneous facilities, establish 500kV station and 500kV tie with 765kV station. | b1660.1        | \$ 1,569,155        | \$ -                        | \$ 1,569,155              | 3.79%            | \$ 59,471          | 6,162   | \$ 9.65   |  |
| (427) | Cloverdale: install 6 765kV breakers, which includes incremental work for 2 additional breakers (total of 6 installed), reconfigure and relocate miscellaneous facilities, establish 500kV station and 500kV tie with 765kV station. | b1660.1_dfax   | \$ 1,569,155        | \$ -                        | \$ 1,569,155              | 33.81%           | \$ 530,531         | 6,162   | \$ 86.10  |  |
| (428) | Install 2 765 kV circuit breakers, breaker disconnect switches and associated bus work for the new 765 kV breakers, and new relays for the 765 kV breakers at Jackson's Ferry  | b1663.2        | \$ 280,963          | \$ -                        | \$ 280,963                | 3.79%            | \$ 10,648          | 6,162   | \$ 1.73   |  |
| (429) | Install 2 765 kV circuit breakers, breaker disconnect switches and associated bus work for the new 765 kV breakers, and new relays for the 765 kV breakers at Jackson's Ferry  | b1663.2_dfax   | \$ 280,963          | \$ -                        | \$ 280,963                | 0.00%            | \$ -               | 6,162   | \$ -  |  |

PJM Schedule 12 - Transmission Enhancement Charges for June 2024 - May 2025 for Non-Pepco Zone Required Transmission Enhancements

|       |  |                |                |      |                |        |              |       |           |      |
|-------|--|----------------|----------------|------|----------------|--------|--------------|-------|-----------|------|
| (430) | Build 25 miles of new 138 kV circuit from Bradley Station through Mollys Creek and Nuttall stations and terminating at Quinwood 138 kV station. The new 138kV circuit repurposed some of the right-of-way from the old area 69kV.<br>McClun will be retired and replaced by Quinwood | b1875          | \$ 9,113,290   | \$ - | \$ 9,113,290   | 0.00%  | \$ -         |       | 6,162     | \$ - |
| (431) | Reconductor the AEP portion of the Cloverdale - Lexington 500 kV line with 2-1780 ACSS   | b1797.1        | \$ 3,168,301   | \$ - | \$ 3,168,301   | 3.79%  | \$ 120,079   | 6,162 | \$ 19.49  |      |
| (432) | Reconductor the AEP portion of the Cloverdale - Lexington 500 kV line with 2-1780 ACSS   | b1797.1 dfax   | \$ 3,168,301   | \$ - | \$ 3,168,301   | 16.91% | \$ 535,760   | 6,162 | \$ 86.95  |      |
| (433) | Build a Sorenson 765/345 kV transformer and 345 kV work at Sorenson  | b1659          | \$ 5,593,231   | \$ - | \$ 5,593,231   | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (434) | Establish 765 kV yard at Sorenson and install four 765 kV breakers   | b1659.13       | \$ 2,685,487   | \$ - | \$ 2,685,487   | 3.79%  | \$ 101,780   | 6,162 | \$ 16.52  |      |
| (435) | Establish 765 kV yard at Sorenson and install four 765 kV breakers   | b1659.13 dfax  | \$ 2,685,487   | \$ - | \$ 2,685,487   | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (436) | Add a second 765/345 kV transformer at Baker Station. Replace Baker 345 kV breakers 'G', 'G2', 'J1', 'G1', 'J', and 'J2' with 63kA breakers  | b1495          | \$ 4,466,460   | \$ - | \$ 4,466,460   | 0.94%  | \$ 41,985    | 6,162 | \$ 6.81   |      |
| (437) | Perform sag study on Altavista - Leesville 138 kV line   | b1712.1        | \$ 26,402      | \$ - | \$ 26,402      | 24.70% | \$ 6,521     | 6,162 | \$ 1.06   |      |
| (438) | Add a 3rd 2250 MVA 765/345 kV transformer at Sullivan station and 345 kV switching changes at Sullivan/Breed   | b1465.1        | \$ 3,534,198   | \$ - | \$ 3,534,198   | 1.66%  | \$ 58,668    | 6,162 | \$ 9.52   |      |
| (439) | Replace existing 150 MVAR reactor at Amos 765 kV substation on Amos - N. Proctorville - Hanging Rock with 300 MVAR reactor   | b2230          | \$ 688,011     | \$ - | \$ 688,011     | 3.79%  | \$ 26,076    | 6,162 | \$ 4.23   |      |
| (440) | Replace existing 150 MVAR reactor at Amos 765 kV substation on Amos - N. Proctorville - Hanging Rock with 300 MVAR reactor   | b2230_dfax     | \$ 688,011     | \$ - | \$ 688,011     | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (441) | Install a 300 MVAR shunt reactor at AEP's Wyoming 765 kV station   | b2423          | \$ 1,067,362   | \$ - | \$ 1,067,362   | 3.79%  | \$ 40,453    | 6,162 | \$ 6.57   |      |
| (442) | Install a 300 MVAR shunt reactor at AEP's Wyoming 765 kV station   | b2423_dfax     | \$ 1,067,362   | \$ - | \$ 1,067,362   | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (443) | Install a +/- 450 MVAR SVC at Jacksons Ferry 765 kV substation   | b2687.1        | \$ 3,868,871   | \$ - | \$ 3,868,871   | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (444) | Install a +/- 450 MVAR SVC at Jacksons Ferry 765 kV substation   | b2687.1 dfax   | \$ 3,868,871   | \$ - | \$ 3,868,871   | 3.79%  | \$ 146,630   | 6,162 | \$ 23.80  |      |
| (445) | Install a 300 MVAR shunt line reactor on the Broadford end of the Broadford - Jacksons Ferry 765 kV line   | b2687.2        | \$ 510,659     | \$ - | \$ 510,659     | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (446) | Install a 300 MVAR shunt line reactor on the Broadford end of the Broadford - Jacksons Ferry 765 kV line   | b2687.2 dfax   | \$ 510,659     | \$ - | \$ 510,659     | 3.79%  | \$ 19,354    | 6,162 | \$ 3.14   |      |
| (447) | Make switching changes at Sullivan 765 kV station  | b1465.5        | \$ 479,382     | \$ - | \$ 479,382     | 3.79%  | \$ 18,169    | 6,162 | \$ 2.95   |      |
| (448) | Make switching changes at Sullivan 765 kV station  | b1465.5 dfax   | \$ 479,382     | \$ - | \$ 479,382     | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (449) | Upgrade Tanner Creek to Miami Fort 345 kV line (AEP portion)   | b2831.1        | \$ 74,514      | \$ - | \$ 74,514      | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (450) | Reconductor the Maddox Creek - East Lima 345 kV circuit with 2-954 ACSS Cardinal conductor   | b2833          | \$ 2,978,589   | \$ - | \$ 2,978,589   | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (451) | Reconductor the entire Dequine - Eugene 345 kV circuit #1  | b2777          | \$ 5,073,739   | \$ - | \$ 5,073,739   | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (452) | Reconductor Dequine - Meadow Lake 345 kV circuit #1 utilizing dual 954 ACSR 54/7 cardinal conductor  | b2668          | \$ 357,988     | \$ - | \$ 357,988     | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (453) | Reconductor the entire Dequine - Meadow Lake 345 kV circuit #2   | b2776          | \$ 1,138,757   | \$ - | \$ 1,138,757   | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (454) |  | b3775.10_rel   | \$ -           | \$ - | \$ -           | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (455) |  | b3775.10_mkt   | \$ -           | \$ - | \$ -           | 3.91%  | \$ -         | 6,162 | \$ -      |      |
| (456) | Perform sag study mitigation work on the Dumont-Stillwell 345 kV line (remove a center-pivot irrigation system from under the line, allowing for the normal and emergency ratings of the line to increase, replace two structures and modify a third structure)                      | b3775.6_rel    | \$ -           | \$ - | \$ -           | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (457) | Perform sag study mitigation work on the Dumont-Stillwell 345 kV line (remove a center-pivot irrigation system from under the line, allowing for the normal and emergency ratings of the line to increase, replace two structures and modify a third structure)                      | b3775.6_mkt    | \$ -           | \$ - | \$ -           | 3.91%  | \$ -         | 6,162 | \$ -      |      |
| (458) |  | b3775.7_rel    | \$ -           | \$ - | \$ -           | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (459) |  | b3775.7_mkt    | \$ -           | \$ - | \$ -           | 3.91%  | \$ -         | 6,162 | \$ -      |      |
| (460) | Rebuild/reconductor the Sunnyside - Torrey 138kV line  | b1034.4        | \$ 837,626     | \$ - | \$ 837,626     | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (461) | Disconnect/eliminate the West Canton 138kV terminal at Torrey Station  | b1034.5        | \$ -           | \$ - | \$ -           | 0.00%  | \$ -         | 6,162 | \$ -      |      |
| (462) |  | b3800.121      | \$ 3,481       | \$ - | \$ 3,481       | 3.79%  | \$ 132       | 6,162 | \$ 0.02   |      |
| (463) |  | b3800.121 dfax | \$ 3,481       | \$ - | \$ 3,481       | 8.93%  | \$ 311       | 6,162 | \$ 0.05   |      |
|       | <b>Total</b>   |                | \$ 176,887,145 | \$ - | \$ 176,887,145 | \$ -   | \$ 2,129,962 |       | \$ 345.68 |      |

AEP East Operating Companies

|       | (A)   | (B)            | (C)                 | (D)                         | (E) = (C) + (D)           | (F)              | (G) = (E) x (F)    | (H)   | (I) = (G) / (H)                              |
|-------|---|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|---|--|
|       | Atlantic Electric's Network Customers   | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (464) | Upgrade AE portion of Delco Tap - Mickleton 230kV circuit   | b0265          | \$ 420,857          | \$ -                        | \$ 420,857                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (465) | Replace both Monroe 230/69 kV transformers  | b0276          | \$ 648,116          | \$ -                        | \$ 648,116                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (466) | Reconductor Union - Corson 138kV circuit  | b0211          | \$ 1,100,826        | \$ -                        | \$ 1,100,826              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (467) |   | b0210.A        | \$ 1,093,550        | \$ -                        | \$ 1,093,550              | 3.79%            | \$ 41,446          | 6,162   | \$ 6.73                                      |
| (468) |   | b0210.A dfax   | \$ 1,093,550        | \$ -                        | \$ 1,093,550              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (469) |   | b0210.B        | \$ 1,559,482        | \$ -                        | \$ 1,559,482              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (470) | Reconductor the existing Mickleton - Thorofare 230 kV circuit (AE portion of the Mickleton-Gloucester line)                           | b1398.5        | \$ 405,762          | \$ -                        | \$ 405,762                | 0.57%            | \$ 2,313           | 6,162   | \$ 0.38                                      |
| (471) | Build a second 230 kV parallel overhead circuit from Mickleton to Thorofare (AE portion of the new line from Mickleton to Gloucester) | b1398.3.1      | \$ 1,260,794        | \$ -                        | \$ 1,260,794              | 0.57%            | \$ 7,187           | 6,162   | \$ 1.17                                      |
| (472) | Upgrade the Mill T2 138/69 kV transformer   | b1600          | \$ 1,506,062        | \$ -                        | \$ 1,506,062              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (473) | Orchard-Cumberland - Install second 230kV line  | b0210.1        | \$ 1,335,422        | \$ -                        | \$ 1,335,422              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (474) | Corson upgrade 138kV line trap  | b0212          | \$ 5,711            | \$ -                        | \$ 5,711                  | 0.00%            | \$ -               | 6,162   | \$ -   |
|       | <b>Total</b>  |                | \$ 10,430,131       | \$ -                        | \$ 10,430,131             | \$ -             | \$ 50,945          |   | \$ 8.27                                      |

PJM Schedule 12 - Transmission Enhancement Charges for June 2025 - May 2026 for Non-Pepco Zone Required Transmission Enhancements

|       | (A)   | (B)            | (C)                 | (D)                         | (E) = (C) + (D)           | (F)              | (G) = (E) x (F)    | (H)   | (I) = (G) / (H)                              |
|-------|---|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|---|--|
|       | Delmarva's Network Customers  | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (475) | Red Lion Sub - 500/230kV work   | b024.1         | \$ 1,379,327        | \$ -                        | \$ 1,379,327              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (476) | Replace line trap and disconnect switch at Keeney 500kV Sub - 5025 Line Terminal Upgrade                                    | b0272.1        | \$ 10,746           | \$ -                        | \$ 10,746                 | 3.79%            | \$ 407             | 6,162   | \$ 0.07                                      |
| (477) | Replace line trap and disconnect switch at Keeney 500kV Sub - 5025 Line Terminal Upgrade                                    | b0272.1 dfax   | \$ 10,746           | \$ -                        | \$ 10,746                 | 1.52%            | \$ 163             | 6,162   | \$ 0.03                                      |
| (478) | Add two additional breakers at Keeney 500 kV  | b0751          | \$ 249,572          | \$ -                        | \$ 249,572                | 3.79%            | \$ 9,459           | 6,162   | \$ 1.54                                      |
| (479) | Add two additional breakers at Keeney 500 kV  | b0751 dfax     | \$ 249,572          | \$ -                        | \$ 249,572                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (480) | Add a 2nd Harmony 230/138 kV transformer  | b0733          | \$ 1,071,450        | \$ -                        | \$ 1,071,450              | 0.00%            | \$ -               | 6,162   | \$ -   |
| (481) | Re-build the Glasgow - Cecil 138 kV circuit   | b1247          | \$ 722,339          | \$ -                        | \$ 722,339                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (482) | Interconnect the new Silver Run 230 kV substation with existing Red Lion - Cantanza and Red Lion - Cedar Creek 230 kV lines | b2633.10       | \$ 683,138          | \$ -                        | \$ 683,138                | 0.00%            | \$ -               | 6,162   | \$ -   |
|       | <b>Total</b>  |                | \$ 4,376,890        | \$ -                        | \$ 4,376,890.00           | \$ -             | \$ 10,029          |   | \$ 1.63                                      |
|       | Duquesne Light Company's Network Customers  | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (483) | Convert Forbes substation to 138 kV supply  | b0501-50503    | \$ 23,980,179       | \$ -                        | \$ 23,980,179             | 0.00%            | \$ -               | 6,162   | \$ -   |
| (484) | Reconductor both Collier - Woodville 138 kV lines   | b1022.2        | \$ 440,792          | \$ -                        | \$ 440,792                | 0.00%            | \$ -               | 6,162   | \$ -   |
| (485) | Reconductor Elrama to Wilson 138 kV line. 4.8 miles   | b3015.2        | \$ -                | \$ -                        | \$ -                      | 0.00%            | \$ -               | 6,162   | \$ -   |

|       |   |           |               |      |                  |       |           |       |          |
|-------|---|-----------|---------------|------|------------------|-------|-----------|-------|----------|
| (486) | Construct two new ties from a new First Energy substation to a new Duquesne substation by using two separate structures - Duquesne portion. | b3012.2   | \$ -          | \$ - | \$ -             | 0.00% | \$ -      | 6,162 |          |
| (487) | Install a third 345-138 kV autotransformer at Collier Substation. Currently s0321 and will be converted to baseline.                        | b1969     | \$ 1,547,076  | \$ - | \$ 1,547,076     | 0.00% | \$ -      | 6,162 |          |
| (488) | Reconductor approximately 7 miles of the Woodville - Peters (Z-117) 138 kV circuit  | b2689.1-2 | \$ 1,064,019  | \$ - | \$ 1,064,019     | 6.29% | \$ 66,927 | 6,162 | \$ 10.86 |
|       | Total   |           | \$ 27,032,066 | \$ - | \$ 27,032,066.00 |       | \$ 66,927 |       | \$ 10.86 |

| (A)   | (B)  | (C)             | (D)            | (E) = (C) + (D)     | (F)                         | (G) = (E) x (F)           | (H)              | (I) = (G) / (H)    |   |  |
|---|--|-----------------|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|---|--|
| Commonwealth Edison Company's Network Customers |  |                 | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (489)   | Construct a new Byron to Wayne 345 kV circuit  | b2141           | \$ 28,757,069  | \$ -                | \$ 28,757,069               | 0.00%                     | \$ -             | -                  | 6,162   | \$ -   |
| (490)   | Mitigate sag limitations on Loretto - Wilton Center 345 kV Line and replace station conductor at Wilton Center | b2728           | \$ 1,354,838   | \$ -                | \$ 1,354,838                | 0.00%                     | \$ -             | -                  | 6,162   | \$ -   |
| (491)   | Replace station equipment at Nelson, ESS H-471 and Quad Cities   | b2692.1-b2692.2 | \$ 1,387,726   | \$ -                | \$ 1,387,726                | 3.56%                     | \$ 49,403        | 6,162              | \$ 8.02   |  |
| (492)   |  |                 | \$ -           | \$ -                | \$ -                        |                           |                  |                    |   |  |
| (493)   |  |                 | \$ -           | \$ -                | \$ -                        |                           |                  |                    |   |  |
| (494)   |  |                 | \$ -           | \$ -                | \$ -                        |                           |                  |                    |   |  |
| (495)   |  |                 | \$ -           | \$ -                | \$ -                        |                           |                  |                    |   |  |
| (496)   |  |                 | \$ -           | \$ -                | \$ -                        |                           |                  |                    |   |  |
| (497)   |  |                 | \$ -           | \$ -                | \$ -                        |                           |                  |                    |   |  |
|   | Total  |                 | \$ 31,499,633  | \$ -                | \$ 31,499,633               |                           | \$ 49,403        |                    | \$ 8  |  |

| (A)   | (B)   | (C)   | (D)            | (E) = (C) + (D)     | (F)                         | (G) = (E) x (F)           | (H)              | (I) = (G) / (H)    |   |  |
|---|---|-------|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|---|--|
| Jersey Central Power & Light (Transmission) |   |       | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (498)                                       | Upgrade the Portland - Greystone 230kV circuit              | b0174 | \$ 1,417,447   | \$ -                | \$ 1,417,447                | 0.00%                     | \$ -             | -                  | 6,162   | \$ -   |
| (499)                                       | Reconductor the 8 mile Gilbert - Glen Gardner 230kV circuit | b0268 | \$ 698,797     | \$ -                | \$ 698,797                  | 0.00%                     | \$ -             | -                  | 6,162   | \$ -   |
| (500)                                       | Add a 2nd Raritan River 230/115 kV transformer              | b0726 | \$ 883,088     | \$ -                | \$ 883,088                  | 0.00%                     | \$ -             | -                  | 6,162   | \$ -   |
| (501)                                       | Build a new 230 kV circuit from Larabee to Oceanview        | b2015 | \$ 21,128,270  | \$ -                | \$ 21,128,270               | 0.00%                     | \$ -             | -                  | 6,162   | \$ -   |
|   | Total   |       | \$ 24,127,602  | \$ -                | \$ 24,127,602               |                           | \$ -             |                    |   |  |

| (A)                                       | (B)   | (C)            | (D)             | (E) = (C) + (D)     | (F)                         | (G) = (E) x (F)           | (H)              | (I) = (G) / (H)    |   |  |
|---|---|----------------|-----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|---|--|
| Mid-Atlantic Interstate Transmission, LLC |   |                | PJM Upgrade ID  | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (502)                                     | Install 230kV series reactor and 2-100MVAR PLC switched capacitors at Hunterstown, install a protection scheme that trips the 230/115 kV transformer with the outage of Hunterstown-Jackson 230kV | b0215          | \$ 2,205,097    | \$ -                | \$ 2,205,097                | 0.00%                     | \$ -             | -                  | 6,162   | \$ -   |
| (503)                                     | Install a 250 MVAR capacitor at Keystone 500 kV substation  | b0549          | \$ 292,181      | \$ -                | \$ 292,181                  | 3.79%                     | \$ 11,074        | 6,162              | \$ 1.80   |  |
| (504)                                     | Install a 250 MVAR capacitor at Keystone 500 kV substation  | b0549_dfax     | \$ 292,181      | \$ -                | \$ 292,181                  | 9.28%                     | \$ 27,114        | 6,162              | \$ 4.40   |  |
| (505)                                     | Install a 25 MVAR capacitor at Saxon 115 kV substation  | b0551          | \$ 238,086      | \$ -                | \$ 238,086                  | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (506)                                     | Install a 50 MVAR capacitor at Altoona 230 kV substation  | b0552          | \$ 191,104      | \$ -                | \$ 191,104                  | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (507)                                     | Install a 50 MVAR capacitor at Raystown 230 kV substation   | b0553          | \$ 168,814      | \$ -                | \$ 168,814                  | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (508)                                     | Install a 75 MVAR capacitor at East Towanda 230 kV substation   | b0557          | \$ 397,241      | \$ -                | \$ 397,241                  | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (509)                                     | Relocate the Erie South 345 kV line terminal  | b1993          | \$ 2,025,164    | \$ -                | \$ 2,025,164                | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (510)                                     | Convert Lewis Run-Farmers Valley to 230 kV using 1033.5 ACSR conductor. Project to be completed in conjunction with new Pierce Book Valley 345/230 kV transformation                              | b1994          | \$ 11,969,633   | \$ -                | \$ 11,969,633               | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (511)                                     | Loop the 2026 (TMI - Hosensack 500 kV) line in to the Lauschtown substation and upgrade relay at TMI 500 kV   | b2006.1.1      | \$ 319,214      | \$ -                | \$ 319,214                  | 3.79%                     | \$ 12,098        | 6,162              | \$ 1.96   |  |
| (512)                                     | Loop the 2026 (TMI - Hosensack 500 kV) line in to the Lauschtown substation and upgrade relay at TMI 500 kV   | b2006.1.1_dfax | \$ (144,816)    | \$ -                | \$ (144,816)                | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (513)                                     | Install 2nd Hunterstown 230/115 kV transformer  | b2452          | \$ 1,398,386    | \$ -                | \$ 1,398,386                | 15.75%                    | \$ 220,246       | 6,162              | \$ 35.74  |  |
| (514)                                     | Reconductor Hunterstown - Oxford 115 kV line  | b2452.1        | \$ 327,091      | \$ -                | \$ 327,091                  | 15.75%                    | \$ 51,517        | 6,162              | \$ 8.36   |  |
| (515)                                     | Tie in new Rice substation to Conemaugh-Hunterston 230 kV   | b2743.2        | \$ (166,596)    | \$ -                | \$ (166,596)                | 20.88%                    | \$ (34,785)      | 6,162              | \$ (5.65)   |  |
| (516)                                     | Upgrade terminal equipment at Conemaugh 500 kV: on the Conemaugh - Hunterston 230 kV circuit  | b2743.3        | \$ (57,114)     | \$ -                | \$ (57,114)                 | 20.88%                    | \$ (11,925)      | 6,162              | \$ (1.94)   |  |
| (517)                                     | Upgrade terminal equipment at Hunterston 500 kV: on the Conemaugh - Hunterston 230 kV circuit   | b2743.4        | \$ 4,214        | \$ -                | \$ 4,214                    | 20.88%                    | \$ 880           | 6,162              | \$ 0.14   |  |
| (518)                                     | Replace disconnect switch at Portland on the Portland-Kittatinny 230 kV circuit   | b0132.3        | \$ 26,433       | \$ -                | \$ 26,433                   | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (519)                                     | Improve the rating of the South Lebanon 230/69 kV transformer #1 by replacing South Lebanon 69 kV substation conductor with 1590 ACSR   | b1364          | \$ 21,693       | \$ -                | \$ 21,693                   | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (520)                                     | Install 23.8 MVAR capacitor at Wood Street 69 kV  | b1362          | \$ 11,856       | \$ -                | \$ 11,856                   | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (521)                                     | Isolate and bypass the 138 kV reactor at Germantown Substation  | b1816.4        | \$ 11,316       | \$ -                | \$ 11,316                   | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (522)                                     | Lincoln Substation: Upgrade the bus conductor and replace CTs.  | b2688.1        | \$ 2,519,692    | \$ -                | \$ 2,519,692                | 15.85%                    | \$ 399,371       | 6,162              | \$ 64.82  |  |
| (523)                                     | Replace wave trap and upgrade a bus section at Keystone 500kV - on the Keystone - New Jack's Mountain 500kV sub   | b0284.3        | \$ 2,486        | \$ -                | \$ 2,486                    | 3.79%                     | \$ 94            | 6,162              | \$ 0.02   |  |
| (524)                                     | Replace wave trap and upgrade a bus section at Keystone 500kV - on the Keystone - New Jack's Mountain 500kV sub   | b0284.3_dfax   | \$ 2,486        | \$ -                | \$ 2,486                    | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (525)                                     | Install 100 MVAR Fast Switched Capacitor Banks at Jack's Mountain 500kV substation  | b0369          | \$ 121,799      | \$ -                | \$ 121,799                  | 3.79%                     | \$ 4,616         | 6,162              | \$ 0.75   |  |
| (526)                                     | Install 100 MVAR Fast Switched Capacitor Banks at Jack's Mountain 500kV substation  | b0369_dfax     | \$ 121,799      | \$ -                | \$ 121,799                  | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (527)                                     | Reconductor the North Meshoppen - Oxbow - Lackawanna 230 kV circuit and upgrade terminal equipment (PENELEC portion)  | b2552.1        | \$ 18,443,736   | \$ -                | \$ 18,443,736               | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (528)                                     | Install a 120.75 kV 79.4 MVAR capacitor bank at Yorkana 115 kV  | b3311          | \$ -            | \$ -                | \$ -                        | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (529)                                     | Upgrade relay at South Reading on the 1072 230 V line   | b2006.2.1      | \$ (10,113,901) | \$ -                | \$ (10,113,901)             | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (530)                                     | Rebuild the Hunterston - Lincoln 115 kV line (No.962) (-2.6 mi.). Upgrade limiting terminal equipment at Hunterston and Lincoln   | b3145          | \$ 1,175,677    | \$ -                | \$ 1,175,677                | 14.54%                    | \$ 170,943       | 6,162              | \$ 27.74  |  |
| (531)                                     | Upgrade terminal equipment and required relay communication at TMI 500 kV: on the Peach Bottom - TMI 500 kV circuit   | b2752.4        | \$ (4,189)      | \$ -                | \$ (4,189)                  | 20.88%                    | \$ (875)         | 6,162              | \$ (0.14)   |  |
|   | Total   |                | \$ 31,800,761   | \$ -                | \$ 31,800,761               |                           | \$ 850,369       |                    | \$ 138  |  |

| (A)                 | (B)  | (C)          | (D)            | (E) = (C) + (D)     | (F)                         | (G) = (E) x (F)           | (H)              | (I) = (G) / (H)    |   |  |
|---------------------|--|--------------|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|---|--|
| PECO Energy Company |  |              | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (532)               | Install a new 500 kV Center Point substation in PECO by tapping the Elroy - Whitpain 500 kV circuit                      | b0269        | \$ 2,181,903   | \$ -                | \$ 2,181,903                | 3.79%                     | \$ 82,694        | 6,162              | \$ 13.42  |  |
| (533)               | Install a new 500 kV Center Point substation in PECO by tapping the Elroy - Whitpain 500 kV circuit                      | b0269_dfax   | \$ 2,181,903   | \$ -                | \$ 2,181,903                | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (534)               | Install a new 230 kV Center Point substation in PECO by tapping the North Wales - Perkiomen 230 kV circuit               | b0269.10     | \$ 2,010,557   | \$ -                | \$ 2,010,557                | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (535)               | Upgrade terminal equipment on the Richmond - Wanetta 230 kV line to achieve an emergency rating of 1162 MVA              | b1591        | \$ 619,069     | \$ -                | \$ 619,069                  | 2.79%                     | \$ 17,272        | 6,162              | \$ 2.80   |  |
| (536)               | Add a new 500kV breaker at Whitpain between #3 transformer and 5029 line   | b0269.6      | \$ 201,095     | \$ -                | \$ 201,095                  | 3.79%                     | \$ 7,621         | 6,162              | \$ 1.24   |  |
| (537)               | Add a new 500kV breaker at Whitpain between #3 transformer and 5029 line   | b0269.6_dfax | \$ 201,095     | \$ -                | \$ 201,095                  | 0.00%                     | \$ -             | 6,162              | \$ -  |  |
| (538)               | Replace two 500 kV circuit breakers and two wave traps at Elroy substation to increase rating of Elroy - Hosensack 500kV | b0171.1      | \$ 271,557     | \$ -                | \$ 271,557                  | 3.79%                     | \$ 10,292        | 6,162              | \$ 1.67   |  |

|              |   |                 |              |                      |             |                      |             |                |              |
|--------------|---|-----------------|--------------|----------------------|-------------|----------------------|-------------|----------------|--------------|
| (539)        | Replace two 500 kV circuit breakers and two wave traps at Elroy substation to increase rating of Elroy - Hosenack 500kV   | b0171.1_dfax    | \$ 271,557   | \$ 271,557           | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (540)        | Upgrade the PECO portion of the Camden - Richmond 230 kV to a six wire conductor  | b1590.1-b1590.2 | \$ 1,763,488 | \$ 1,763,488         | 1.93%       | \$ 34,035            | \$ 34,035   | 6,162          | \$ 5.52      |
| (541)        | Increase the rating of lines 220-39 and 220-43 (Linwood-Chichester 230kV lines) and install reactors on each line.  | b1900           | \$ 3,879,774 | \$ 3,879,774         | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (542)        | Rebuild Bryn Mawr-Plymouth Meeting 138 kV line (130-35 Line)  | b0727           | \$ 2,354,066 | \$ 2,354,066         | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (543)        | Install a 3rd Emile 230/138 kV transformer  | b2140           | \$ 2,218,052 | \$ 2,218,052         | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (544)        | Reconductor Chichester - Saville 138 kV line and upgrade terminal equipment   | b1182           | \$ 2,249,912 | \$ 2,249,912         | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (545)        | Install a second Wanetta 230/138 kV transformer on a separate bus section   | b1717           | \$ 1,476,440 | \$ 1,476,440         | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (546)        | Add a second 230/138 kV transformer at Chichester. Add an inductor in series with the parallel transformers   | b1178           | \$ 1,053,621 | \$ 1,053,621         | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (547)        | Increase Bradford - Planebrook 230 kV Ckt.220-31 line rating. Replace terminal equipment  | b0790           | \$ 223,213   | \$ 223,213           | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (548)        | Reconductor the North Wales - Hartman 230 kV circuit (220-71 Line)  | b0506           | \$ 270,677   | \$ 270,677           | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (549)        | Reconductor the North Wales - Whitpain 230 kV circuit (220-16 Line)   | b0505           | \$ 303,700   | \$ 303,700           | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (550)        | Increase Bradford - Planebrook 230 kV Ckt.220-02 line rating. Replace terminal equipment  | b0789           | \$ 305,756   | \$ 305,756           | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (551)        | Install 161MVAR capacitor at Planebrook 230kV substation  | b0206           | \$ 423,081   | \$ 423,081           | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (552)        | Install 161MVAR capacitor at Newlinville 230kV substation   | b0207           | \$ 568,798   | \$ 568,798           | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (553)        | Install 2% series reactor at Chichester substation on the Chichester - Mickleton 230kV circuit  | b0209           | \$ 321,844   | \$ 321,844           | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (554)        | Upgrade Chichester - Delco Tap 230kV and the PECO portion of the Delco Tap - Mickleton 230kV circuit  | b0264           | \$ 259,388   | \$ 259,388           | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (555)        | Reconductor Buckingham - Pleasant Valley 230kV; same impedance as existing line; ratings of 760MVA normal/882MVA emergency  | b0357           | \$ 250,265   | \$ 250,265           | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (556)        | Reconductor Richmond - Wanetta 230 kV and replace terminal equipment at Wanetta substation  | b1398.8         | \$ 196,121   | \$ 196,121           | 0.57%       | \$ 1,118             | \$ 1,118    | 6,162          | \$ 0.18      |
| (557)        | Install 600 MVAR Automatically switched capacitor banks at Elroy 500 kV substation (Two 300 MVAR cap banks)   | b0287           | \$ 333,093   | \$ 333,093           | 3.79%       | \$ 12,624            | \$ 12,624   | 6,162          | \$ 2.05      |
| (558)        | Install 600 MVAR Automatically switched capacitor banks at Elroy 500 kV substation (Two 300 MVAR cap banks)   | b0287_dfax      | \$ 333,093   | \$ 333,093           | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (559)        | Install 161MVAR capacitor Heaton 230kV substation   | b0208           | \$ 502,764   | \$ 502,764           | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (560)        | Increase ratings of Peach Bottom 500/230 kV transformer to 1479 MVA normal/1839 MVA emergency   | b2694           | \$ 1,687,622 | \$ 1,687,622         | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| (561)        | Upgrade substation equipment at Peach Bottom 500 kV (on the Peach Bottom - Conastone 500 kV circuit) to increase facility ratio to 2826 MVA normal and 3525 MVA emergency | b2766.2         | \$ 63,016    | \$ 63,016            | 3.79%       | \$ 2,388             | \$ 2,388    | 6,162          | \$ 0.39      |
| (562)        | Upgrade substation equipment at Peach Bottom 500 kV (on the Peach Bottom - Conastone 500 kV circuit) to increase facility ratio to 2826 MVA normal and 3525 MVA emergency | b2766.2_dfax    | \$ 63,016    | \$ 63,016            | 0.00%       | \$ -                 | \$ -        | 6,162          | \$ -         |
| <b>Total</b> |   |                 |              | <b>\$ 29,039,531</b> | <b>\$ -</b> | <b>\$ 29,039,531</b> | <b>\$ -</b> | <b>168,045</b> | <b>\$ 27</b> |

| (A)                                 | (B)  | (C)            | (D)                 | (E) = (C) + (D)             | (F)                       | (G) = (E) × (F)      | (H)                | (I) = (G) / (H)   |  |
|-------------------------------------|--|----------------|---------------------|-----------------------------|---------------------------|----------------------|--------------------|---|--|
| American Transmission Systems, Inc. |  | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share     | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (563)                               | Expand Alta into a 69 kV Switching Station networking Leaside, Longview, and Galion Subs at the existing Alta 69 kV Sub Site | b1587          | \$ 1,761,178        | \$ -                        | \$ 1,761,178              | 0.00%                | \$ -               | 6,162   | \$ -   |
| (564)                               | Re-conductor the Galion - GM Mansfield - Ontario - Cairns 138 kV line with 477 ACSS  | b1920          | \$ 2,784,510        | \$ -                        | \$ 2,784,510              | 0.00%                | \$ -               | 6,162   | \$ -   |
| (565)                               | Build new Toronto 345/138 kV substation by looping in the Sammis - Wyld Ridge 345 kV line and tie in four 138 kV lines       | b1977          | \$ 5,476,219        | \$ 5,476,219                | 0.00%                     | \$ -                 | \$ -               | 6,162   | \$ -   |
| (566)                               | Build a new West Fremont-Groton-Hayes 138kV line   | b1959          | \$ 13,470,147       | \$ 13,470,147               | 0.00%                     | \$ -                 | \$ -               | 6,162   | \$ -   |
| (567)                               | Reconductor limiting span of Lallendorf - Monroe 345kV (crossing of Maumee river)  | b2972          | \$ 591,059          | \$ 591,059                  | 0.00%                     | \$ -                 | \$ -               | 6,162   | \$ -   |
| (568)                               | McDowell-Campbell - Construct approximately 5.5 miles of 138 kV line   | b2124.4        | \$ 3,178,595        | \$ 3,178,595                | 0.00%                     | \$ -                 | \$ -               | 6,162   | \$ -   |
| (569)                               | McDowell Substation - Add a new 138 kV line exit   | b2124.1        | \$ 992,264          | \$ 992,264                  | 0.00%                     | \$ -                 | \$ -               | 6,162   | \$ -   |
| (570)                               | Campbell Substation - Construct a 138 kV ring bus and install a 138/69 kV autotransformer                                    | b2124.2        | \$ 2,213,227        | \$ 2,213,227                | 0.00%                     | \$ -                 | \$ -               | 6,162   | \$ -   |
| (571)                               | Build a new East Springfield - London #2 138 kV line   | b2435          | \$ 18,744,017       | \$ 18,744,017               | 0.00%                     | \$ -                 | \$ -               | 6,162   | \$ -   |
| (572)                               |  |                |                     |                             |                           |                      |                    |   |  |
| (573)                               |  |                |                     |                             |                           |                      |                    |   |  |
| (574)                               |  |                |                     |                             |                           |                      |                    |   |  |
| <b>Total</b>                        |  |                |                     | <b>\$ 49,211,217</b>        | <b>\$ -</b>               | <b>\$ 49,211,217</b> | <b>\$ -</b>        | <b>\$ -</b>   | <b>\$ -</b>                                  |

| (A)                           | (B)  | (C)            | (D)                 | (E) = (C) + (D)             | (F)                       | (G) = (E) × (F)  | (H)                | (I) = (G) / (H)   |  |
|-------------------------------|--|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|---|--|
| Transource West Virginia, LLC |  | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (575)                         | Establish the new Linden Road 138 kV substation tapping the Powell Mountain - Goff Run 138 kV line, construct 25 miles of new 138 kV line from Thorofare Creek to the new Linden Road 138 kV substation. | b2609.4        | \$ 9,346,941        | \$ -                        | \$ 9,346,941              | 0.00%            | \$ -               | 6,162   | \$ -   |
|                               | <b>Total</b>   |                | <b>\$ 9,346,941</b> | <b>\$ -</b>                 | <b>\$ 9,346,941</b>       | <b>\$ -</b>      | <b>\$ -</b>        | <b>\$ -</b>   | <b>\$ -</b>                                  |

| (A)                      | (B)  | (C)            | (D)                 | (E) = (C) + (D)             | (F)                       | (G) = (E) × (F)  | (H)                | (I) = (G) / (H)   |  |
|--------------------------|--|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|---|--|
| Transource Maryland, LLC |  | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (576)                    | Build new 230 kV double circuit line between Rice and Ringgold 230 kV, operated as a single circuit.         | b2743.5        | \$ 1,972,893        | \$ -                        | \$ 1,972,893              | 20.88%           | \$ 411,940         | 6,162   | \$ 66.85                                     |
| (577)                    | Build new 230 kV double circuit line between Furnace Run and Conastone 230 kV, operated as a single circuit. | b2752.5        | \$ 232,042,53       | \$ -                        | \$ 232,042,53             |                  |                    | 6,162   | \$ -   |
|                          | <b>Total</b>   |                | <b>\$ 2,204,936</b> | <b>\$ -</b>                 | <b>\$ 2,204,936</b>       | <b>\$ -</b>      | <b>\$ 411,940</b>  | <b>\$ 67</b>  | <b>\$ 67</b>                                 |

| (A)                          | (B)  | (C)            | (D)                  | (E) = (C) + (D)             | (F)                       | (G) = (E) × (F)  | (H)                 | (I) = (G) / (H)   |  |
|------------------------------|--|----------------|----------------------|-----------------------------|---------------------------|------------------|---------------------|---|--|
| Transource Pennsylvania, LLC |  | PJM Upgrade ID | Revenue Requirement  | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges  | Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW) | Transmission Enhancement Charge (\$/MW-Year) |
| (578)                        | Build new 230 kV double circuit line between Rice and Ringgold 230 kV, operated as a single circuit.   | b2743.5        | \$ 12,339,042        | \$ -                        | \$ 12,339,042             | 20.88%           | \$ 2,576,392        | 6,162   | \$ 418.13                                    |
| (579)                        | Tap the Conemaugh - Hunterstown 500 kV line & create new Rice 500 kV & 230 kV stations. Install two 500/230 kV transformers, operated together.  | b2743.1        | \$ -                 | \$ -                        | \$ 0.00%                  | \$ -             | \$ -                | 6,162   | \$ -   |
| (580)                        | Build new 230 kV double circuit line between Furnace Run and Conastone 230 kV, operated as a single circuit.   | b2752.5        | \$ -                 | \$ -                        | \$ 0.00%                  | \$ -             | \$ -                | 6,162   | \$ -   |
| (581)                        | Tap the Peach Bottom - TMI 500 kV line & create new Furnace Run 500 kV & 230 kV stations. Install two 500/230 kV transformers, operated together.  | b2752.1        | \$ -                 | \$ -                        | \$ 0.00%                  | \$ -             | \$ -                | 6,162   | \$ -   |
| (582)                        | Build New North Delta 500 kV substation (four bay breaker and half configuration) - the substation will include 12 - 500kV breakers and one 500/230 kV transformer, will allow the termination of six - 500 kV lines | b3737.47       | \$ 364,041           | \$ 364,041                  | 3.79%                     | \$ 13,797        | \$ 13,797           | 6,162   | \$ 2.24                                      |
| (583)                        |  | b3737.47_dfax  | \$ 364,041           | \$ 364,041                  | 0.00%                     | \$ -             | \$ -                | 6,162   | \$ -   |
| (584)                        |  | b3737.47_pub   | \$ 1,995,759         | \$ 1,995,759                | 0.00%                     | \$ -             | \$ -                | 6,162   | \$ -   |
|                              | <b>Total</b>   |                | <b>\$ 15,062,883</b> | <b>\$ -</b>                 | <b>\$ 15,062,883</b>      | <b>\$ -</b>      | <b>\$ 2,590,189</b> | <b>\$ 420</b>   | <b>\$ 420</b>                                |

| Silver Run Electric, Inc.  |  | PJM Upgrade ID  | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | 6161.7 | Transmission Enhancement Charge (\$/MW-Year) |
|--|--|-----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|--------|--|
| (585) Build a new 230 kV transmission line between Hope Creek and Silver Run |  | b2633.1-b2633.2 | \$ 22,578,434       | \$ -                        | \$ 22,578,434             | 0.00%            | \$ -               | 6,162  | \$ -   |
| (586) Total  |  |                 | \$ 22,578,434       | \$ -                        | \$ 22,578,434             |                  | \$ -               |        | \$ -   |

| Northern Indiana Public Service Company  |  | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | 6161.7 | Transmission Enhancement Charge (\$/MW-Year) |
|--|--|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|--------|--|
| (587) Reconfigure Munster 345kV as ring bus                                      |  | b2971          | \$ 799,509          |                             | \$ 799,509                | 5.80%            | \$ 46,372          | 6,162  | \$ 7.53                                      |
| (588) Reconducto Michigan City - Bosserman 138kV                                 |  | b2973          | \$ 758,112          |                             | \$ 758,112                | 5.05%            | \$ 38,285          | 6,162  | \$ 6.21                                      |
| (589) Replace terminal equipment at Reynolds on the Reynolds - Magnetation 138kV |  | b2974          | \$ 6,163            |                             | \$ 6,163                  | 0.00%            | \$ -               | 6,162  | \$ -   |
| (590) Reconducto Roxana - Praxair 138kV  |  | b2975          | \$ 889,793          |                             | \$ 889,793                | 1.53%            | \$ 13,614          | 6,162  | \$ 2.21                                      |
| (591) Rebuild Michigan City-Trail Creek - Bosserman 138 kV (10.7 mi)             |  | b3142          | \$ 3,977,618        |                             | \$ 3,977,618              | 0.00%            | \$ -               | 6,162  | \$ -   |
| Total  |  |                | \$ 6,431,195        | \$ -                        | \$ 6,431,195              |                  | \$ 98,270          |        | \$ 16  |

| Midcontinent Independent System Operator, Inc. (MISO)         |  | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | 6161.7 | Transmission Enhancement Charge (\$/MW-Year) |
|---|--|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|--------|--|
| (592) Upgrade terminal equipment on Gibson - Petersburg 345kV |  | b3053          | \$ 673,826          | \$ -                        | \$ 673,826                | 0.00%            | \$ -               | 6,162  | \$ -   |
| Total   |  |                | \$ 673,826          | \$ -                        | \$ 673,826                |                  | \$ -               |        | \$ -   |

| The Dayton Power & Light Company                                |  | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | 6161.7 | Transmission Enhancement Charge (\$/MW-Year) |
|---|--|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|--------|--|
| (593) Add a 345/69 kV transformer at Dayton's Peoria 345 kV bus |  | b1570          | \$ 2,706,239        |                             | \$ 2,706,239              |                  | \$ -               | 6,162  | \$ -   |
| Total   |  |                | \$ 2,706,239        | \$ -                        | \$ 2,706,239              |                  | \$ -               |        | \$ -   |

| South FirstEnergy Operating Companies  |  | PJM Upgrade ID   | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | 6161.7 | Transmission Enhancement Charge (\$/MW-Year) |
|--|--|------------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|--------|--|
| (594) Replace Fort Martin 500 kV breaker 'FL-1'  |  | b0577            | \$ -                |                             | \$ -                      | 3.79%            | \$ -               | 6,162  | \$ -   |
| (595) Replace Fort Martin 500 kV breaker 'FL-1'  |  | b0577_dfax       | \$ -                |                             | \$ -                      | 0.00%            | \$ -               | 6,162  | \$ -   |
| (596) Terminate the Powell Mountain and Goff Run lines into the new Chloe substation and perform any associated relay upgrades or modifications required at Powell Mountain and Goff run to accommodate new substation |  | b2609.5          | \$ 380,335          |                             | \$ 380,335                | 0.00%            | \$ -               | 6,162  | \$ -   |
| (597) Reconducto Doubs - Dickerson and Doubs - Aqueduct - Dickerson 230 kV to 1200MVA  |  | b0238            | \$ 497,095          |                             | \$ 497,095                | 49.68%           | \$ 246,957         | 6,162  | \$ 40.08                                     |
| (598) Convert Doubs - Monocacy 138kV facilities to 230kV operation - Phase 2 of b0322  |  | b0373            | \$ 359,948          |                             | \$ 359,948                | 0.00%            | \$ -               | 6,162  | \$ -   |
| (599) Terminal Equipment upgrade at Doubs substation   |  | b1507.2          | \$ 10,164           |                             | \$ 10,164                 | 3.79%            | \$ 385             | 6,162  | \$ 0.06                                      |
| (600) Terminal Equipment upgrade at Doubs substation   |  | b1507.2_dfax     | \$ 10,164           |                             | \$ 10,164                 | 7.14%            | \$ 726             | 6,162  | \$ 0.12                                      |
| (601) Mt Storm - Doubs transmission line rebuild in Maryland - Total line mileage for APS is 2.71 miles  |  | b1507.3          | \$ 1,302,519        |                             | \$ 1,302,519              | 3.79%            | \$ 49,365          | 6,162  | \$ 8.01                                      |
| (602) Mt Storm - Doubs transmission line rebuild in Maryland - Total line mileage for APS is 2.71 miles  |  | b1507.3_dfax     | \$ 1,302,519        |                             | \$ 1,302,519              | 7.14%            | \$ 93,000          | 6,162  | \$ 15.09                                     |
| (603) Carroll Substation: Replace the Germantown 138 kV wave trap, upgrade the bus conductor and adjust CT ratios.   |  | b2688.3          | \$ 86,221           |                             | \$ 86,221                 | 15.85%           | \$ 13,666          | 6,162  | \$ 2.22                                      |
| (604) Replace Meadow Brook 138kV breaker MD-10'  |  | b0347.17-32      | \$ 167,533          |                             | \$ 167,533                | 3.79%            | \$ 6,350           | 6,162  | \$ 1.03                                      |
| (605) Replace Meadow Brook 138kV breaker MD-10'  |  | b0347.17-32_dfax | \$ 167,533          |                             | \$ 167,533                | 10.11%           | \$ 16,938          | 6,162  | \$ 2.75                                      |
| (606) Reconducto 14.3 miles of 556 ACSR with 795 ACSR from Old Chapel to Millville 138 kV and upgrade line risers at Old Chapel 138 kV and Millville 138 kV and replace 1200 A wave trap at Millville 138 kV           |  | b1835            | \$ 1,972            |                             | \$ 1,972                  | 13.69%           | \$ 270             | 6,162  | \$ 0.04                                      |
| (607)  |  |                  | \$ -                |                             | \$ -                      |                  |                    |        |  |
| (608)  |  |                  | \$ -                |                             | \$ -                      |                  |                    |        |  |
| (609)  |  |                  | \$ -                |                             | \$ -                      |                  |                    |        |  |
| (610)  |  |                  | \$ -                |                             | \$ -                      |                  |                    |        |  |
| (611)  |  |                  | \$ -                |                             | \$ -                      |                  |                    |        |  |
| (612)  |  |                  | \$ -                |                             | \$ -                      |                  |                    |        |  |
| Total  |  |                  | \$ 4,286,002        | \$ -                        | \$ 4,286,002              |                  | \$ 427,656         |        | \$ 69  |

| Keystone Appalachian Transmission Company |  | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | 6161.7 | Transmission Enhancement Charge (\$/MW-Year) |
|---|--|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|--------|--|
| (613)                                     |  | b1022.11       | \$ 69,793           |                             | \$ 69,793                 | 0.00%            | \$ -               | 6,162  | \$ -   |
| (614)                                     |  | b1022.5        | \$ 87,742           |                             | \$ 87,742                 | 0.00%            | \$ -               | 6,162  | \$ -   |
| (615)                                     |  | b3006          | \$ 17,589,173       |                             | \$ 17,589,173             | 0.00%            | \$ -               | 6,162  | \$ -   |
| (616)                                     |  | b3011.2        | \$ 136,904          |                             | \$ 136,904                | 0.00%            | \$ -               | 6,162  | \$ -   |
| (617)                                     |  | b3011.5        | \$ 180,422          |                             | \$ 180,422                | 0.00%            | \$ -               | 6,162  | \$ -   |
| (618)                                     |  | b2965          | \$ 444,959          |                             | \$ 444,959                | 0.00%            | \$ -               | 6,162  | \$ -   |
| (619)                                     |  | b3214          | \$ 4,144,214        |                             | \$ 4,144,214              | 0.00%            | \$ -               | 6,162  | \$ -   |
| (620)                                     |  | b3717.1        | \$ 561,416          |                             | \$ 561,416                | 0.00%            | \$ -               | 6,162  | \$ -   |
| Total                                     |  |                | \$ 23,214,622       | \$ -                        | \$ 23,214,622             |                  | \$ -               |        | \$ -   |

| NextEra Energy Transmission MidAtlantic, Inc.        |  | PJM Upgrade ID | Revenue Requirement | Prior Period Reconciliation | Total Revenue Requirement | Pepco Zone Share | Pepco Zone Charges | 6161.7 | Transmission Enhancement Charge (\$/MW-Year) |
|--|--|----------------|---------------------|-----------------------------|---------------------------|------------------|--------------------|--------|--|
| (621)  |  | s2509/s2631    | \$ 28,676,042       | \$ -                        | \$ 28,676,042             | 0.00%            | \$ -               | 6,162  | \$ -   |
| (622)  |  | b3775.2_rel    | \$ 1,471,283        | \$ -                        | \$ 1,471,283              | 0.00%            | \$ -               | 6,162  | \$ -   |
| (623)  |  | b3775.2_mkt    | \$ 1,642,543        | \$ -                        | \$ 1,642,543              | 3.91%            | \$ 64,223          | 6,162  | \$ 10.42                                     |
| (624)  |  | b3800.102      | \$ 1,993,174        | \$ -                        | \$ 1,993,174              | 3.79%            | \$ 75,541          | 6,162  | \$ 12.26                                     |
| (625)  |  | b3800.102_dfax | \$ 1,993,174        | \$ -                        | \$ 1,993,174              | 12.68%           | \$ 252,734         | 6,162  | \$ 41.02                                     |
| (626)  |  | b3800.106      | \$ 60,882           | \$ -                        | \$ 60,882                 | 3.79%            | \$ 2,307           | 6,162  | \$ 0.37                                      |
| (627)  |  | b3800.106_dfax | \$ 60,882           | \$ -                        | \$ 60,882                 | 0.00%            | \$ -               | 6,162  | \$ -   |
| NextEra Energy Transmission MidAtlantic, Inc. Totals |  |                | \$ 35,897,979       | \$ -                        | \$ 35,897,979             |                  | \$ 394,807         |        | \$ 64  |

|       |                               |  |  |  |    |            |  |    |       |
|-------|-------------------------------|--|--|--|----|------------|--|----|-------|
| (628) | Grand Totals - Non-Pepco TECs |  |  |  | \$ | 43,778,229 |  | \$ | 7,105 |
|-------|-------------------------------|--|--|--|----|------------|--|----|-------|

## **Attachment D**

I. 2025 Pepco Network Integration Transmission Service (\$/MW-Year)

|   | Pepco           | <b>Notes:</b>   |
|---|-----------------|---|
| (1) Transmission Service Annual Revenue Requirement                                     | \$ 355,800,393  | Source: Line (172), Attachment H-9A of Potomac Electric Power Company, Docket No. ER09-1159 Information Filing of 2025 Formula Rate Annual Update |
| (2) Total Schedule 12 Pepco Zone TEC  | \$ (31,066,932) | Source: Column (E), Line (31) Below   |
| (3) Total Schedule 12 Pepco Zone TEC - Pepco Share                                      | \$ 23,674,490   | Source: Column (G), Line (31) Below   |
| (4) Total Transmission Costs  | \$ 348,407,951  | Calculation: Line (4) = Line (1) + Line (2) + Line (3)  |
| (5) Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW)                 |                 | 6,162 Source: PJM Network Transmission Service Peak Loads for 2025  |
| (6) 2025 Pepco Network Integration Transmission Service (\$/MW-Year) - Excluding SMECO  | \$ 56,544.13    | Calculation: Line (4) / Line (5)  |
|   |                 | <b>SMECO</b>  |
| (7) Transmission Service Annual Revenue Requirement                                     | \$ 17,086,212   | Source: Attachment H-9C, Annual Transmission Rate - Southern Maryland Electric Cooperative, Inc. For Network Integration Transmission Service     |
| (8) Pepco Zone - PJM Network Transmission Service Peak Load (2025) (MW)                 |                 | 6,162 Source: PJM Network Transmission Service Peak Loads for 2025  |
| (9) 2025 Pepco Network Integration Transmission Service (\$/MW-Year) - SMECO Only       | \$ 2,772.97     | Calculation: Line (9) = Line (7) / Line (8)   |
| (10) 2025 Pepco Network Integration Transmission Service (\$/MW-Year) - Including SMECO | \$ 59,317.10    | Line (10) = Line (6) + Line (9)   |

II. Pepco Zone - Required Transmission Enhancements

PJM Schedule 12 - Transmission Enhancement Charges for June 2025 - May 2026 for Pepco Zone Required Transmission Enhancements

| (A)<br>Pepco   | (B)<br>PJM Upgrade ID | (C)<br>Revenue Requirement | (D)<br>Prior Period Reconciliation | (E) = (C) + (D) | (F)<br>Pepco Zone Share | (G) = (E) x (F)<br>Pepco Zone Charges |
|--|-----------------------|----------------------------|------------------------------------|-----------------|-------------------------|---------------------------------------|
| (11) ID  | Requirement           | \$ 2,002,373.00            | \$ -                               | \$ 2,002,373    | 52.46%                  | \$ 1,050,445                          |
| (12) 0   | 0                     | \$ 94,399.00               | \$ -                               | \$ 94,399       | 3.79%                   | \$ 3,578                              |
| (13) b0241.3   | \$ 1,379,327.00       | \$ 94,399.00               | \$ -                               | \$ 94,399       | 2.44%                   | \$ 2,303                              |
| (14) b0272.1   | \$ 10,746.00          | \$ 94,399.00               | \$ -                               | \$ 94,399       | 3.79%                   | \$ 3,578                              |
| (15) b0272.1 dfax  | \$ 10,746.00          | \$ 94,399.00               | \$ -                               | \$ 94,399       | 2.44%                   | \$ 2,303                              |
| (16) b0751   | \$ 249,572.00         | \$ 94,399.00               | \$ -                               | \$ 94,399       | 3.79%                   | \$ 3,578                              |
| (17) b0751 dfax  | \$ 249,572.00         | \$ 94,399.00               | \$ -                               | \$ 94,399       | 2.44%                   | \$ 2,303                              |
| (18) b0733   | \$ 1,071,450.00       | \$ 95,556.50               | \$ -                               | \$ 95,557       | 3.79%                   | \$ 3,622                              |
| (19) b1247   | \$ 722,339.00         | \$ 95,556.50               | \$ -                               | \$ 95,557       | 2.44%                   | \$ 2,332                              |
| (20) b2633.10  | \$ 683,138.00         | \$ 1,638,855.00            | \$ -                               | \$ 1,638,855    | 96.49%                  | \$ 1,581,331                          |
| (21) TOTAL   |                       | \$ 4,376,890.00            | \$ 3,049,937.00                    | \$ 3,049,937    | 89.15%                  | \$ 2,719,019                          |
| (22) Required Transmission Enhancements owned by: PEPSCO's Network Customers | 0                     | \$ 5,699,523.00            | \$ -                               | \$ 5,699,523    | 74.86%                  | \$ 4,266,663                          |
| (23) PJM   | Annual                | \$ 508,545.00              | \$ -                               | \$ 508,545      | 69.43%                  | \$ 353,083                            |
| (24) Upgrade   | Revenue               | \$ 2,035,287.00            | \$ -                               | \$ 2,035,287    | 53.74%                  | \$ 1,093,763                          |
| (25) ID  | Requirement           | \$ 3,093,357.00            | \$ -                               | \$ 3,093,357    | 63.67%                  | \$ 1,969,540                          |
| (26) 0   | 0                     | \$ 5,460,811.00            | \$ -                               | \$ 5,460,811    | 95.26%                  | \$ 5,201,969                          |
| (27) b0367.1-2   | \$ 2,002,373.00       | \$ 920,160.00              | \$ -                               | \$ 920,160      | 64.22%                  | \$ 590,927                            |
| (28) b0512.7   | \$ 94,399.00          | \$ 844,383.00              | \$ -                               | \$ 844,383      | 41.86%                  | \$ 353,459                            |
| (29) b0512.7 dfax  | \$ 94,399.00          | \$ 4,065,263.00            | \$ -                               | \$ 4,065,263    | 95.26%                  | \$ 3,872,570                          |
| (30) b0512.8   | \$ 94,399.00          | \$ 990,931.00              | \$ -                               | \$ 990,931      | 60.36%                  | \$ 598,126                            |
| (31) Pepco Totals  |                       | \$ 31,066,932              | \$ -                               | \$ 31,066,932   |                         | \$ 23,674,490                         |

## Attachment E

Potomac Electric Power Company  
Maryland  
July 7, 2025 Retail Transmission Rate Filing

Attachment E  
Page 1 of 1

Summary of June 2025 - December 2025 Settlement Adjustments  
BLI-1115 - Transmission Enhancement Charge Adjustments (Black Box)

| (B)                                    |   |
|--|---|
| Jurisdiction                           | Total Monthly TEC Adjustment (Years 5 - 10) |
| (1) Pepco MD                           | \$ 492,989.59                               |
| (2) Pepco DC                           | \$ 339,055.85                               |
| (3) Pepco SMECO                        | \$ 117,694.86                               |
| (4) <b>Pepco - Total</b>               | <b>\$ 949,740.30</b>                        |
| (5) <b>Pepco - Jun to Dec 2025</b>     | <b>\$ 6,648,182.10</b>                      |
| (6) <b>Transmission Peak Load (MW)</b> | <b>6,162</b>                                |
| (7) <b>Pepco - Total</b>               | <b>\$ 1,078.95</b>                          |

Calculation: Line (4) = Line (1) + Line (2) + Line (3)

Calculation: Line (5) = Line (4) \* 7

Source: PJM Network Transmission Service Peak Loads for 2025

Calculation: Line (7) = Line (5) divided by Line (6)

Notes:

- (B) Source: July 30, 2018 Letter Re: PJM Interconnection L.L.C. Docket No. EL05-121-009 and ER18-2102-001  
eTariff Compliance Filing for Schedule 12 and Schedule 12-Appendices , Attachment B, Schedule 12-C Appendix C.

## **Attachment F**

Potomac Electric Power Company  
 Maryland  
 July 7, 2025 Retail Transmission Rate Filing  
 Proposed Transmission Rates Due To FERC Formula Rate Change Effective 9/1/2025  
 Present Revenue (Rates Effective September 1, 2025)  
 Billing Determinants (2024)

Attachment F  
 Page 1 of 14

Schedule R

|                      | (A)<br>Billing<br>Determinants | (B)<br>Present<br>Rate <sup>1</sup> | (C)<br>Present<br>Revenue | (D)<br>Rate<br>Adjustment | (E)<br>Proposed<br>Rate <sup>1</sup> | (F)<br>Proposed<br>Revenue | (G)<br>Percent<br>Change |
|----------------------|--------------------------------|-------------------------------------|---------------------------|---------------------------|--------------------------------------|----------------------------|--------------------------|
| <b>Transmission</b>  |                                |                                     |                           |                           |                                      |                            |                          |
| Kilowatt-hour Charge |                                |                                     |                           |                           |                                      |                            |                          |
| Annual kWh           | 4,674,577,688                  | \$ 0.01951                          | \$ 91,201,011             | \$ 0.001501               | \$ 0.02101                           | \$ 98,217,490              | 7.69%                    |
| Total Transmission   |                                |                                     | \$ 91,201,011             |                           |                                      | \$ 98,217,490              |                          |

Transmission Rate Change - Kilowatt-hour charge \$ 0.001501

Transmission Revenue Percent Change Calculation

|   |               |
|---|---------------|
| Proposed Transmission Revenue Increase/Decrease | \$ 7,016,479  |
| Present Transmission Revenue                    | \$ 91,201,011 |
| Proposed Transmission Revenue                   | \$ 98,217,490 |
| Percent Change                                  | 7.69%         |

**Residential Time of Use ("R-TOU-P")**

\*Based on Residential retail transmission rate

|  | Present<br>Summer<br>06/01/25-08/31/25 | Present<br>Winter<br>02/01/25-05/31/25 | Proposed<br>Summer<br>09/01/25-09/30/25 | Proposed<br>Winter<br>02/01/25-05/31/25 |
|--|--|--|---|---|
| <b>Generation &amp; Transmission</b>       |  |  |   |   |
| On-Peak                                    | \$ 0.28656                             | \$ 0.20418                             | \$ 0.29398                              | \$ 0.21087                              |
| Off-Peak                                   | \$ 0.07571                             | \$ 0.09651                             | \$ 0.07571                              | \$ 0.09651                              |
| Admin Charge***                            | \$ 0.00515                             | \$ 0.00589                             | \$ 0.00515                              | \$ 0.00589                              |
| <b>Total Generation &amp; Transmission</b> |  |  |   |   |
| On-Peak                                    | \$ 0.29171                             | \$ 0.21007                             | \$ 0.29913                              | \$ 0.21676                              |
| Off-Peak                                   | \$ 0.08086                             | \$ 0.10240                             | \$ 0.08086                              | \$ 0.10240                              |

\*R-TOU-P includes retail transmission in the SOS on/off peak rates

\*\*Proposed winter rates for comparison purposes only

\*\*\*The Admin Charge rates typically change every February, June and October.

FN1 - The Present Rate and Proposed transmission rates apply to the Residential, R-PIV, PIV and R-TOU-P rate schedules.

Potomac Electric Power Company  
 Maryland  
 July 7, 2025 Retail Transmission Rate Filing  
 Proposed Transmission Rates Due To FERC Formula Rate Change Effective 9/1/2025  
 Present Revenue (Rates Effective September 1, 2025)  
 Billing Determinants (2024)

Attachment F  
 Page 2 of 14

Schedule RTM

|  | (A)<br>Billing<br>Determinants | (B)<br>Present<br>Rate | (C)<br>Present<br>Revenue | (D)<br>Rate<br>Adjustment | (E)<br>Proposed<br>Rate | (F)<br>Proposed<br>Revenue | (G)<br>Percent<br>Change |
|--|--------------------------------|------------------------|---------------------------|---------------------------|-------------------------|----------------------------|--------------------------|
| <b>Transmission</b>                                    |                                |                        |                           |                           |                         |                            |                          |
| Kilowatt-hour Charge                                   |                                |                        |                           |                           |                         |                            |                          |
| Annual kWh   | 803,426,887                    | \$ 0.01978             | \$ 15,891,784             | \$ 0.00114                | \$ 0.02092              | \$ 16,804,518              | 5.74%                    |
| Total Transmission                                     |                                |                        | \$ 15,891,784             |                           |                         | \$ 16,804,518              |                          |
| <b>Transmission Rate Change - Kilowatt-hour charge</b> |                                |                        | \$ 0.00114                |                           |                         |                            |                          |
| <b>Transmission Revenue Percent Change Calculation</b> |                                |                        |                           |                           |                         |                            |                          |
| Proposed Transmission Revenue Increase/Decrease        |                                |                        | \$ 912,735                |                           |                         |                            |                          |
| Present Transmission Revenue                           |                                |                        | \$ 15,891,784             |                           |                         |                            |                          |
| Proposed Transmission Revenue                          |                                |                        | \$ 16,804,518             |                           |                         |                            |                          |
| Percent Change   |                                |                        | 5.74%                     |                           |                         |                            |                          |

Potomac Electric Power Company  
 Maryland  
 July 7, 2025 Retail Transmission Rate Filing  
 Proposed Transmission Rates Due To FERC Formula Rate Change Effective 9/1/2025  
 Present Revenue (Rates Effective September 1, 2025)  
 Billing Determinants (2024)

Attachment F  
 Page 3 of 14

**Schedule GS & EV**

|  | (A)<br>Billing<br>Determinants | (B)<br>Present<br>Rate | (C)<br>Present<br>Revenue | (D)<br>Rate<br>Adjustment | (E)<br>Proposed<br>Rate | (F)<br>Proposed<br>Revenue | (G)<br>Percent<br>Change |
|--|--------------------------------|------------------------|---------------------------|---------------------------|-------------------------|----------------------------|--------------------------|
| <b>Transmission</b>                                    |                                |                        |                           |                           |                         |                            |                          |
| Kilowatt-hour Charge                                   |                                |                        |                           |                           |                         |                            |                          |
| Annual kWh   | 318,441,566                    | \$ 0.01302             | \$ 4,146,109              | \$ 0.00121                | \$ 0.01423              | \$ 4,532,792               | 9.33%                    |
| Total Transmission                                     |                                |                        | \$ 4,146,109              |                           |                         | \$ 4,532,792               |                          |
| <b>Transmission Rate Change</b>                        |                                |                        | \$ 0.00121                |                           |                         |                            |                          |
| <b>Transmission Revenue Percent Change Calculation</b> |                                |                        | \$ 386,683                |                           |                         |                            |                          |
| Proposed Transmission Revenue Increase/Decrease        |                                |                        | \$ 386,683                |                           |                         |                            |                          |
| Present Transmission Revenue                           |                                |                        | \$ 4,146,109              |                           |                         |                            |                          |
| Proposed Transmission Revenue                          |                                |                        | \$ 4,532,792              |                           |                         |                            |                          |
| Percent Change   |                                |                        | 9.33%                     |                           |                         |                            |                          |

Potomac Electric Power Company  
 Maryland  
 July 7, 2025 Retail Transmission Rate Filing  
 Proposed Transmission Rates Due To FERC Formula Rate Change Effective 9/1/2025  
 Present Revenue (Rates Effective September 1, 2025)  
 Billing Determinants (2024)

Attachment F  
 Page 4 of 14

Schedule T

|  | (A)<br>Billing<br>Determinants | (B)<br>Present<br>Rate | (C)<br>Present<br>Revenue | (D)<br>Rate<br>Adjustment | (E)<br>Proposed<br>Rate | (F)<br>Proposed<br>Revenue | (G)<br>Percent<br>Change |
|--|--------------------------------|------------------------|---------------------------|---------------------------|-------------------------|----------------------------|--------------------------|
| <b>Transmission</b>                                    |                                |                        |                           |                           |                         |                            |                          |
| Kilowatt-hour Charge                                   |                                |                        |                           |                           |                         |                            |                          |
| Annual kWh   | 13,012,866                     | \$ 0.00939             | \$ 122,191                | \$0.00124                 | \$ 0.01063              | \$ 138,346                 | 13.22%                   |
| Total Transmission                                     |                                |                        | \$ 122,191                |                           |                         | \$ 138,346                 |                          |
| <b>Transmission Rate Change</b>                        |                                |                        | \$ 0.00124                |                           |                         |                            |                          |
| <b>Transmission Revenue Percent Change Calculation</b> |                                |                        |                           |                           |                         |                            |                          |
| Proposed Transmission Revenue Increase/Decrease        |                                |                        | \$ 16,156                 |                           |                         |                            |                          |
| Present Transmission Revenue                           |                                |                        | \$ 122,191                |                           |                         |                            |                          |
| Proposed Transmission Revenue                          |                                |                        | \$ 138,346                |                           |                         |                            |                          |
| Percent Change   |                                |                        | 13.22%                    |                           |                         |                            |                          |

Potomac Electric Power Company  
 Maryland  
 July 7, 2025 Retail Transmission Rate Filing  
 Proposed Transmission Rates Due To FERC Formula Rate Change Effective 9/1/2025  
 Present Revenue (Rates Effective September 1, 2025)  
 Billing Determinants (2024)

Attachment F  
 Page 5 of 14

Schedules SL

|  | (A)<br>Billing<br>Determinants | (B)<br>Present<br>Rate | (C)<br>Present<br>Revenue | (D)<br>Rate<br>Adjustment | (E)<br>Proposed<br>Rate | (F)<br>Proposed<br>Revenue | (G)<br>Percent<br>Change |
|--|--------------------------------|------------------------|---------------------------|---------------------------|-------------------------|----------------------------|--------------------------|
| <b>Transmission</b>                                    |                                |                        |                           |                           |                         |                            |                          |
| Kilowatt-hour Charge                                   |                                |                        |                           |                           |                         |                            |                          |
| Annual kWh   | 56,770,354                     | \$ 0.00004             | \$ 2,271                  | \$0.00003                 | \$ 0.00007              | \$ 4,198                   | 84.89%                   |
| Total Transmission                                     |                                |                        | \$ 2,271                  |                           |                         | \$ 4,198                   |                          |
| <b>Transmission Rate Change</b>                        |                                |                        | \$ 0.00003                |                           |                         |                            |                          |
| <b>Transmission Revenue Percent Change Calculation</b> |                                |                        |                           |                           |                         |                            |                          |
| Proposed Transmission Revenue Increase/Decrease        |                                |                        | \$ 1,928                  |                           |                         |                            |                          |
| Present Transmission Revenue                           |                                |                        | \$ 2,271                  |                           |                         |                            |                          |
| Proposed Transmission Revenue                          |                                |                        | \$ 4,198                  |                           |                         |                            |                          |
| Percent Change   |                                |                        | 84.89%                    |                           |                         |                            |                          |

Potomac Electric Power Company  
 Maryland  
 July 7, 2025 Retail Transmission Rate Filing  
 Proposed Transmission Rates Due To FERC Formula Rate Change Effective 9/1/2025  
 Present Revenue (Rates Effective September 1, 2025)  
 Billing Determinants (2024)

Attachment F  
 Page 6 of 14

Schedule TN

|  | (A)<br>Billing<br>Determinants | (B)<br>Present<br>Rate | (C)<br>Present<br>Revenue | (D)<br>Rate<br>Adjustment | (E)<br>Proposed<br>Rate | (F)<br>Proposed<br>Revenue | (G)<br>Percent<br>Change |
|--|--------------------------------|------------------------|---------------------------|---------------------------|-------------------------|----------------------------|--------------------------|
| <b>Transmission</b>                                    |                                |                        |                           |                           |                         |                            |                          |
| Kilowatt-hour Charge                                   |                                |                        |                           |                           |                         |                            |                          |
| Annual kWh   | 18,022,203                     | \$ 0.00768             | \$ 138,411                | \$ 0.00133                | \$ 0.00901              | \$ 162,386                 | 17.32%                   |
| Total Transmission                                     |                                |                        | \$ 138,411                |                           |                         | \$ 162,386                 |                          |
| <b>Transmission Rate Change</b>                        |                                |                        | \$ 0.00133                |                           |                         |                            |                          |
| <b>Transmission Revenue Percent Change Calculation</b> |                                |                        |                           |                           |                         |                            |                          |
| Proposed Transmission Revenue Increase/Decrease        |                                |                        | \$ 23,976                 |                           |                         |                            |                          |
| Present Transmission Revenue                           |                                |                        | \$ 138,411                |                           |                         |                            |                          |
| Proposed Transmission Revenue                          |                                |                        | \$ 162,386                |                           |                         |                            |                          |
| Percent Change   |                                |                        | 17.32%                    |                           |                         |                            |                          |

Potomac Electric Power Company  
 Maryland  
 July 7, 2025 Retail Transmission Rate Filing  
 Proposed Transmission Rates Due To FERC Formula Rate Change Effective 9/1/2025  
 Present Revenue (Rates Effective September 1, 2025)  
 Billing Determinants (2024)

Attachment F  
 Page 7 of 14

Schedule MGT-LV

|  | (A)<br>Billing<br>Determinants | (B)<br>Present<br>Rate | (C)<br>Present<br>Revenue      | (D)<br>Rate<br>Adjustment | (E)<br>Proposed<br>Rate | (F)<br>Proposed<br>Revenue     | (G)<br>Percent<br>Change |
|--|--------------------------------|------------------------|--------------------------------|---------------------------|-------------------------|--------------------------------|--------------------------|
| <b>Transmission</b>                        |                                |                        |                                |                           |                         |                                |                          |
| Kilowatt-hour Charge<br>Annual kWh         | 4,249,263.490                  | \$ 0.00766             | \$ 32,549,358                  | \$0.00097                 | \$ 0.00863              | \$ 36,650,170                  | 12.60%                   |
| Kilowatt Charge<br>On Peak<br>Summer       | 3,741,775                      | \$ 1.6946              | \$ 6,340,812                   | \$0.2135                  | \$ 1.9081               | \$ 7,139,675                   | 12.60%                   |
| Maximum<br>Annual kW<br>Total Transmission | 11,464,995                     | \$ 1.2336              | \$ 14,143,218<br>\$ 53,033,388 | \$0.1554                  | \$ 1.3890               | \$ 15,925,086<br>\$ 59,714,931 | 12.60%                   |

Transmission Rate Change

Transmission Revenue Percent Change Calculation

|   |               |
|---|---------------|
| Proposed Transmission Revenue Increase/Decrease | \$ 6,681,543  |
| Present Transmission Revenue                    | \$ 53,033,388 |
| Proposed Transmission Revenue                   | \$ 59,714,931 |
| Percent Change                                  | 12.60%        |

Potomac Electric Power Company  
 Maryland  
 July 7, 2025 Retail Transmission Rate Filing  
 Proposed Transmission Rates Due To FERC Formula Rate Change Effective 9/1/2025  
 Present Revenue (Rates Effective September 1, 2025)  
 Billing Determinants (2024)

Attachment F  
 Page 8 of 14

Schedule MGT- 3A

|                                      | (A)<br>Billing<br>Determinants | (B)<br>Present<br>Rate | (C)<br>Present<br>Revenue | (D)<br>Rate<br>Adjustment | (E)<br>Proposed<br>Rate | (F)<br>Proposed<br>Revenue | (G)<br>Percent<br>Change |
|--------------------------------------|--------------------------------|------------------------|---------------------------|---------------------------|-------------------------|----------------------------|--------------------------|
| <b>Transmission</b>                  |                                |                        |                           |                           |                         |                            |                          |
| Kilowatt-hour Charge<br>Annual kWh   | 84,969,182                     | \$ 0.00703             | \$ 597,333                | \$0.00147                 | \$ 0.00850              | \$ 722,288                 | 20.92%                   |
| Kilowatt Charge<br>On Peak<br>Summer | 77,276                         | \$ 1.5294              | \$ 118,186                | \$0.3199                  | \$ 1.8493               | \$ 142,909                 | 20.92%                   |
| Maximum<br>Annual kW                 | 222,954                        | \$ 1.1249              | \$ 250,801                | \$0.2353                  | \$ 1.3602               | \$ 303,265                 | 20.92%                   |
| Total Transmission                   |                                |                        | \$ 966,320                |                           |                         | \$ 1,168,462               |                          |

Transmission Rate Change

Transmission Revenue Percent Change Calculation

|   |              |
|---|--------------|
| Proposed Transmission Revenue Increase/Decrease | \$ 202,142   |
| Present Transmission Revenue                    | \$ 966,320   |
| Proposed Transmission Revenue                   | \$ 1,168,462 |
| Percent Change                                  | 20.92%       |

Potomac Electric Power Company

Maryland

July 7, 2025 Retail Transmission Rate Filing

Proposed Transmission Rates Due To FERC Formula Rate Change Effective 9/1/2025

Present Revenue (Rates Effective September 1, 2025)

Billing Determinants (2024)

**Schedule GT-LV**

|                      | (A)<br>Billing<br>Determinants | (B)<br>Present<br>Rate | (C)<br>Present<br>Revenue | (D)<br>Rate<br>Adjustment | (E)<br>Proposed<br>Rate | (F)<br>Proposed<br>Revenue | (G)<br>Percent<br>Change |
|----------------------|--------------------------------|------------------------|---------------------------|---------------------------|-------------------------|----------------------------|--------------------------|
| <b>Transmission</b>  |                                |                        |                           |                           |                         |                            |                          |
| Kilowatt-hour Charge |                                |                        |                           |                           |                         |                            |                          |
| Annual kWh           | 913,942,880                    | \$ 0.00691             | \$ 6,315,345              | \$0.00082                 | \$ 0.00773              | \$ 7,066,100               | 11.89%                   |
| Kilowatt Charge      |                                |                        |                           |                           |                         |                            |                          |
| On Peak              |                                |                        |                           |                           |                         |                            |                          |
| Summer               | 814,906                        | \$ 1.8335              | \$ 1,494,130              | \$0.2180                  | \$ 2.0515               | \$ 1,671,749               | 11.89%                   |
| Maximum              |                                |                        |                           |                           |                         |                            |                          |
| Annual kW            | 2,328,829                      | \$ 1.3543              | \$ 3,153,933              | \$0.1610                  | \$ 1.5153               | \$ 3,528,866               | 11.89%                   |
| Total Transmission   |                                |                        | \$ 10,963,409             |                           |                         | \$ 12,266,715              |                          |

**Transmission Rate Change**

**Transmission Revenue Percent Change Calculation**

|   |               |
|---|---------------|
| Proposed Transmission Revenue Increase/Decrease | \$ 1,303,307  |
| Present Transmission Revenue                    | \$ 10,963,409 |
| Proposed Transmission Revenue                   | \$ 12,266,715 |
| Percent Change                                  | 11.89%        |

Potomac Electric Power Company

Maryland

July 7, 2025 Retail Transmission Rate Filing

Proposed Transmission Rates Due To FERC Formula Rate Change Effective 9/1/2025

Present Revenue (Rates Effective September 1, 2025)

Billing Determinants (2024)

**Schedule GT-3A**

|                      | (A)<br>Billing<br>Determinants | (B)<br>Present<br>Rate | (C)<br>Present<br>Revenue | (D)<br>Rate<br>Adjustment | (E)<br>Proposed<br>Rate | (F)<br>Proposed<br>Revenue | (G)<br>Percent<br>Change |
|----------------------|--------------------------------|------------------------|---------------------------|---------------------------|-------------------------|----------------------------|--------------------------|
| <b>Transmission</b>  |                                |                        |                           |                           |                         |                            |                          |
| Kilowatt-hour Charge |                                |                        |                           |                           |                         |                            |                          |
| Annual kWh           | 1,684,200,394                  | \$ 0.00661             | \$ 11,132,565             | \$0.00076                 | \$ 0.00737              | \$ 12,405,660              | 11.44%                   |
| Kilowatt Charge      |                                |                        |                           |                           |                         |                            |                          |
| On Peak              |                                |                        |                           |                           |                         |                            |                          |
| Summer               | 1,373,961                      | \$ 1.7925              | \$ 2,462,825              | \$0.2050                  | \$ 1.9975               | \$ 2,744,468               | 11.44%                   |
| Maximum              |                                |                        |                           |                           |                         |                            |                          |
| Annual kW            | 3,393,254                      | \$ 1.3405              | \$ 4,548,657              | \$0.1533                  | \$ 1.4938               | \$ 5,068,831               | 11.44%                   |
| Total Transmission   |                                |                        | \$ 18,144,047             |                           |                         | \$ 20,218,959              |                          |

**Transmission Rate Change**

**Transmission Revenue Percent Change Calculation**

|   |               |
|---|---------------|
| Proposed Transmission Revenue Increase/Decrease | \$ 2,074,913  |
| Present Transmission Revenue                    | \$ 18,144,047 |
| Proposed Transmission Revenue                   | \$ 20,218,959 |
| Percent Change                                  | 11.44%        |

Potomac Electric Power Company  
 Maryland  
 July 7, 2025 Retail Transmission Rate Filing  
 Proposed Transmission Rates Due To FERC Formula Rate Change Effective 9/1/2025  
 Present Revenue (Rates Effective September 1, 2025)  
 Billing Determinants (2024)

Attachment F  
 Page 11 of 14

Schedule GT-3B

|                                      | (A)<br>Billing<br>Determinants | (B)<br>Present<br>Rate | (C)<br>Present<br>Revenue | (D)<br>Rate<br>Adjustment | (E)<br>Proposed<br>Rate | (F)<br>Proposed<br>Revenue | (G)<br>Percent<br>Change |
|--------------------------------------|--------------------------------|------------------------|---------------------------|---------------------------|-------------------------|----------------------------|--------------------------|
| <b>Transmission</b>                  |                                |                        |                           |                           |                         |                            |                          |
| Kilowatt-hour Charge<br>Annual kWh   | 287,008,915                    | \$ 0.00586             | \$ 1,681,872              | \$0.00117                 | \$ 0.00703              | \$ 2,017,829               | 19.98%                   |
| Kilowatt Charge<br>On Peak<br>Summer | 221,584                        | \$ 1.5361              | \$ 340,375                | \$0.3068                  | \$ 1.8429               | \$ 408,366                 | 19.98%                   |
| Maximum<br>Annual kW                 | 584,395                        | \$ 1.1299              | \$ 660,308                | \$0.2257                  | \$ 1.3556               | \$ 792,205                 | 19.98%                   |
| Total Transmission                   |                                |                        | \$ 2,682,555              |                           |                         | \$ 3,218,399               |                          |

Transmission Rate Change

| <u>Transmission Revenue Percent Change Calculation</u>     |
|--|
| Proposed Transmission Revenue Increase/Decrease \$ 535,844 |
| Present Transmission Revenue \$ 2,682,555                  |
| Proposed Transmission Revenue \$ 3,218,399                 |
| Percent Change 19.98%                                      |

Potomac Electric Power Company  
 Maryland  
 July 7, 2025 Retail Transmission Rate Filing  
 Proposed Transmission Rates Due To FERC Formula Rate Change Effective 9/1/2025  
 Present Revenue (Rates Effective September 1, 2025)  
 Billing Determinants (2024)

Attachment F  
 Page 12 of 14

Schedule RT

|                                    | (A)<br>Billing<br>Determinants | (B)<br>Present<br>Rate | (C)<br>Present<br>Revenue | (D)<br>Rate<br>Adjustment | (E)<br>Proposed<br>Rate | (F)<br>Proposed<br>Revenue | (G)<br>Percent<br>Change |
|------------------------------------|--------------------------------|------------------------|---------------------------|---------------------------|-------------------------|----------------------------|--------------------------|
| <b>Transmission</b>                |                                |                        |                           |                           |                         |                            |                          |
| Kilowatt-hour Charge<br>Annual kWh | 249,365,346                    | \$ 0.00575             | \$ 1,433,851              | \$0.00127                 | \$ 0.00702              | \$ 1,749,353               | 22.00%                   |
| Kilowatt Charge<br>On Peak         |                                |                        |                           |                           |                         |                            |                          |
| Summer                             | 190,288                        | \$ 1.0019              | \$ 190,649                | \$0.22046                 | \$ 1.2224               | \$ 232,599                 | 22.00%                   |
| Maximum<br>Annual kW               | 466,011                        | \$ 0.7207              | \$ 335,854                | \$0.15858                 | \$ 0.8793               | \$ 409,755                 | 22.00%                   |
| Total Transmission                 |                                |                        | \$ 1,960,354              |                           |                         | \$ 2,391,707               |                          |

Transmission Rate Change

| <u>Transmission Revenue Percent Change Calculation</u>     |
|--|
| Proposed Transmission Revenue Increase/Decrease \$ 431,353 |
| Present Transmission Revenue \$ 1,960,354                  |
| Proposed Transmission Revenue \$ 2,391,707                 |
| Percent Change 22.00%                                      |

Potomac Electric Power Company  
 Maryland  
 July 7, 2025 Retail Transmission Rate Filing  
 Proposed Transmission Rates Due To FERC Formula Rate Change Effective 9/1/2025  
 Present Revenue (Rates Effective September 1, 2025)  
 Billing Determinants (2024)

Attachment F  
 Page 13 of 14

Schedule OL

|                     | (A)<br>Billing<br>Determinants | (B)<br>Present<br>Rate | (C)<br>Present<br>Revenue | (D)<br>Rate<br>Adjustment | (E)<br>Proposed<br>Rate | (F)<br>Proposed<br>Revenue | (G)<br>Percent<br>Change |
|---------------------|--------------------------------|------------------------|---------------------------|---------------------------|-------------------------|----------------------------|--------------------------|
| <b>Transmission</b> |                                |                        |                           |                           |                         |                            |                          |
| Per Lamp Charge     |                                |                        |                           |                           |                         |                            |                          |
| 100 Watt            | \$ -                           | \$ -                   | \$ -                      | \$ -                      | \$ -                    | \$ -                       | 0%                       |
| 150 Watt            | \$ -                           | \$ -                   | \$ -                      | \$ -                      | \$ -                    | \$ -                       | 0%                       |
| 250 Watt            | \$ -                           | \$ -                   | \$ -                      | \$ -                      | \$ -                    | \$ -                       | 0%                       |
| Total Transmission  |                                |                        | \$ -                      |                           |                         | \$ -                       |                          |

Transmission Rate Change

Transmission Revenue Percent Change Calculation

|   |       |
|---|-------|
| Proposed Transmission Revenue Increase/Decrease | \$ -  |
| Present Transmission Revenue                    | \$ -  |
| Proposed Transmission Revenue                   | \$ -  |
| Percent Change                                  | 0.00% |

**Potomac Electric Power Company  
Maryland**

**Attachment F  
Page 14 of 14**

**July 7, 2025 Retail Transmission Rate Filing  
Transmission Peak Load Contribution (2024)**

|      | <b>(A)</b>           | <b>(B)</b>          |
|------|----------------------|---------------------|
|      | <b>Rate Schedule</b> | <b>TPLC (kW)</b>    |
| (1)  | Residential          | 1,450,405           |
| (2)  | RTM                  | 248,157             |
| (3)  | GS                   | 66,937              |
| (4)  | T                    | 2,043               |
| (5)  | SL                   | 62                  |
| (6)  | TN                   | 2,398               |
| (7)  | MGT-LV               | 881,827             |
| (8)  | MGT-HV               | 17,255              |
| (9)  | GT-LV                | 181,146             |
| (10) | GT-3A                | 298,579             |
| (11) | GT-3B                | 47,527              |
| (12) | RT                   | 35,319              |
| (13) | OL                   | -                   |
| (14) | <b>Total</b>         | <b>3,231,655.00</b> |

**(C)**

**Notes:**

- (B) Source: Internal Company Records  
(C) Inclusive of GS LV and EV TPLC

## **Attachment G**

| Residential   |    | Current<br>Rates | Proposed<br>Rates 9/1/2025 | Current<br>Bill | Proposed<br>Bill              |
|---|----|------------------|----------------------------|-----------------|-------------------------------|
|   |    |                  |                            | 824             | 824                           |
|   |    |                  |                            | kWh             |                               |
| <b>Summer Distribution Services</b>   |    |                  |                            |                 |                               |
| (1) Customer Charge   | \$ | 8.44             | \$                         | 8.44            | \$ 8.44                       |
| (2) Rider RDM eff. 4/1/2024 Energy  | \$ | -                | \$                         | -               | \$ -                          |
| (3) All Kwh   | \$ | 0.08760          | \$                         | 0.08760         | \$ 72.18 \$ 72.18             |
| (4) Rider RDM eff. 4/1/2024   | \$ | -                | \$                         | -               | \$ -                          |
| (5) Delivery Tax - eff 4/2000   | \$ | 0.00062          | \$                         | 0.00062         | \$ 0.51 \$ 0.51               |
| (6) Environmental Surcharge - eff. 7/1/2025                                     | \$ | 0.000151         | \$                         | 0.00015         | \$ 0.12 \$ 0.12               |
| (7) Montgomery County Surcharge - eff. 7/1/2025                                 | \$ | 0.0113227        | \$                         | 0.01132         | \$ 9.33 \$ 9.33               |
| (8) EmPower MD - eff. 1/1/2025 Rider MYP Adjustment - eff. 4/1/2025 - 3/31/2026 | \$ | 0.01379          | \$                         | 0.01379         | \$ 11.36 \$ 11.36             |
| (9) Universal Service Charge - eff. 6/1/2019                                    | \$ | 0.32000          | \$                         | 0.32000         | \$ 0.32 \$ 0.32               |
| (10) Admin. Credit - 12 month average 6/2025                                    | \$ | (0.00100)        | \$                         | (0.00100)       | \$ (0.82) \$ (0.82)           |
| (11) BSA - 12 month average 6/2025 GRT (Dist & Surcharges)                      | \$ | (0.001706)       | \$                         | (0.00171)       | \$ (1.41) \$ (1.41)           |
|   |    | 2.04080%         |                            | 2.04080%        | \$ 1.87 \$ 1.87               |
| Distribution Services Total   |    |                  |                            |                 | \$ 102.65 \$ 102.65           |
| <b>Transmission Services</b>  |    |                  |                            |                 |                               |
| (12) All Kwh GRT  | \$ | 0.01951          | \$                         | 0.02101         | \$ 16.08 \$ 17.31             |
|   |    | 2.04080%         |                            | 2.04080%        | \$ 0.33 \$ 0.35               |
| Transmission Services Total   |    |                  |                            |                 | \$ 16.41 \$ 17.66 \$ (1.25)   |
| <b>Generation Services</b>  |    |                  |                            |                 |                               |
| Rates eff. 6/1/2025 - 9/30/2025   |    |                  |                            |                 |                               |
| (13) All Kwh  | \$ | 0.10397          | \$                         | 0.10397         | \$ 85.67 \$ 85.67             |
| (14) Energy PCA - 12 month average ye 6/2025 Generation Services Total          | \$ | (0.0030722)      | \$                         | (0.00307)       | \$ (2.53) \$ (2.53)           |
|   |    |                  |                            |                 | \$ 83.14 \$ 83.14             |
| <b>Total Bill</b>   |    |                  |                            |                 | \$ 202.20 \$ 203.45 \$ (1.25) |

Pepco  
Maryland  
Rates effective September 1, 2025

Attachment G

| Residential  |    | Current<br>Rates | Proposed<br>Rates 9/1/2025 | Current<br>Bill        | Proposed<br>Bill |        |        |        |        |
|--|----|------------------|----------------------------|------------------------|------------------|--------|--------|--------|--------|
|  |    |                  |                            | 824                    | kWh              | 824    |        |        |        |
| <b>Winter Distribution Services</b>  |    |                  |                            |                        |                  |        |        |        |        |
| (15) Customer Charge   | \$ | 8.44             | \$                         | 8.44                   | \$               | 8.44   |        |        |        |
| (16) Rider RDM eff. 4/1/2024 Energy  | \$ | -                | \$                         | -                      | \$               | -      |        |        |        |
| (17) All Kwh   | \$ | 0.04328          | \$                         | 0.04328                | \$               | 35.66  |        |        |        |
| (18) Rider RDM eff. 4/1/2024   | \$ | -                | \$                         | -                      | \$               | -      |        |        |        |
| (19) Delivery Tax - eff 4/2000   | \$ | 0.00062          | \$                         | 0.00062                | \$               | 0.51   |        |        |        |
| (20) Environmental Surcharge - eff. 7/1/2025                                     | \$ | 0.000151         | \$                         | 0.00015                | \$               | 0.12   |        |        |        |
| (21) Montgomery County Surcharge - eff. 7/1/2025                                 | \$ | 0.0113227        | \$                         | 0.01132                | \$               | 9.33   |        |        |        |
| (22) EmPower MD - eff. 1/1/2025 Rider MYP Adjustment - eff. 4/1/2025 - 3/31/2026 | \$ | 0.01379          | \$                         | 0.01379                | \$               | 11.36  |        |        |        |
| (23) Universal Service Charge - eff. 6/1/2020                                    | \$ | 0.32000          | \$                         | 0.32000                | \$               | 0.32   |        |        |        |
| (24) Admin. Credit - 12 month average 6/2025                                     | \$ | (0.00100)        | \$                         | (0.00100)              | \$               | (0.82) |        |        |        |
| (25) BSA - 12 month average 6/2025 GRT (Dist & Surcharges)                       | \$ | (0.001706)       | \$                         | (0.00171)              | \$               | (1.41) |        |        |        |
|  |    | 2.04080%         |                            | 2.04080%               | \$               | 1.12   |        |        |        |
| Distribution Services Total  |    |                  |                            | \$                     | 65.38            | \$     | 65.38  | \$     | -      |
| <b>Transmission Services</b>   |    |                  |                            |                        |                  |        |        |        |        |
| (26) All Kwh GRT   | \$ | 0.01951          | \$                         | 0.02101                | \$               | 16.08  |        |        |        |
|  |    | 2.04080%         |                            | 2.04080%               | \$               | 0.33   |        |        |        |
| Transmission Services Total  |    |                  |                            | \$                     | 16.41            | \$     | 17.66  | \$     | (1.25) |
| <b>Generation Services</b>   |    |                  |                            |                        |                  |        |        |        |        |
| Rates eff. 10/1/2025 - 5/31/2026   |    |                  |                            |                        |                  |        |        |        |        |
| (27) All Kwh   | \$ | 0.10704          | \$                         | 0.10704                | \$               | 88.20  |        |        |        |
| (28) Energy PCA - 12 month average ye 6/2025                                     | \$ | (0.0030722)      | \$                         | (0.00307)              | \$               | (2.53) |        |        |        |
| Generation Services Total  |    |                  |                            | \$                     | 85.67            | \$     | 85.67  |        |        |
| <b>Total Bill</b>  |    |                  |                            | \$                     | 167.46           | \$     | 168.71 | \$     | (1.25) |
|  |    |                  |                            | <b>Annualized Bill</b> | \$               | 181.94 | \$     | 183.19 |        |
|  |    |                  |                            | <b>Per kWh</b>         | \$               | 0.2208 | \$     | 0.2223 |        |
|  |    |                  |                            | <b>\$ Bill Impact</b>  | \$               |        |        | 1.25   |        |
|  |    |                  |                            | <b>% Bill Impact</b>   | \$               |        |        | 0.69%  |        |

**Notes:**

For all current transmission rates as well as distribution, generation, and surcharge rates please refer to Pepco's current Electric Tariff

For proposed transmission rates refer to Attachment F column K

Current and proposed bills based on Case No. 9702 Compliance Bill Impacts Average (Mean) residential average usage of 824 kwh